

**Power System Operation Corporation Limited
National Load Despatch Centre**



From: The Shift Charge Manager, NLDC

To: The Shift Charge Manager, ERLDC/NERLDC

Date: 03/05/2023

Time: 11:59:11

Sl.No	Corridor	Current TTC(MW)	Current ATC(MW)	Revised TTC(MW)	Revised ATC(MW)	Change in ATC(MW)	Date for which Revision is done(dd-mm-yyyy)	Time Block for Revision(From TB)	Time Block for Revision(To TB)	Reason for Revision/Event for which TTC/ATC Revision is being done	Date of occurrence of event(dd-mm-yyyy)	Time of occurrence of event(HH:MM)	Date of intimation of event to NLDC by Utility(dd-mm-yyyy)	Time of intimation of event to NLDC by Utility(HH:MM)
1	ER-NER	1660	1600	1360	1300	-300	2023-05-03	50	72	Due to ESD of 400KV APD-Bongaigaon	2023-05-03	12:15:00	2023-05-03	12:15:00
2	ER-NER	1490	1430	1190	1130	-300	2023-05-03	73	88	Due to ESD of 400KV APD-Bongaigaon	2023-05-03	12:15:00	2023-05-03	12:15:00
3	ER-NER	1660	1600	1360	1300	-300	2023-05-03	89	96	Due to ESD of 400KV APD-Bongaigaon	2023-05-03	12:15:00	2023-05-03	12:15:00
4	NER_IMPORT	1160	1100	860	800	-300	2023-05-03	50	72	Due to ESD of 400KV	2023-05-03	12:15:00	2023-05-03	12:15:00

Sl.No	Corridor	Current TTC(MW)	Current ATC(MW)	Revised TTC(MW)	Revised ATC(MW)	Change in ATC(MW)	Date for which Revision is done(dd-mm-yyyy)	Time Block for Revision(From TB)	Time Block for Revision(To TB)	Reason for Revision/Event for which TTC/ATC Revision is being done	Date of occurrence of event(dd-mm-yyyy)	Time of occurrence of event(HH:MM)	Date of intimation of event to NLDC by Utility(dd-mm-yyyy)	Time of intimation of event to NLDC by Utility(HH:MM)
										APD-Bo ngaigao n				
5	NER_IMPORT	990	930	690	630	-300	2023-05-03	73	88	Due to ESD of 400KV APD-Bo ngaigao n	2023-05-03	12:15:00	2023-05-03	12:15:00
5	NER_IMPORT	1160	1100	860	800	-300	2023-05-03	89	96	Due to ESD of 400KV APD-Bo ngaigao n	2023-05-03	12:15:00	2023-05-03	12:15:00

SCE-NLDC