

GRID CONTROLLER OF INDIA LIMITED  
National Load Despatch Centre



From: The Shift Charge Manager, NLDC

To: The Shift Charge Manager, NRLDC/WRLDC/ERLDC

Date: 5/26/2023  
Time: 12:05:11 AM

Sl.No	Corridor	Current TTC(MW)	Current ATC(MW)	Revised TTC(MW)	Revised ATC(MW)	Change in ATC (MW)	Date for which Revision is done(dd-mm-yyyy)	Time Block for Revision(From TB)	Time Block for Revision(To TB)	Reason for Revision/Event for which TTC/ATC Revision is being done
1	WR-NR	17800	16800	17350	16350	-450	2023-05-26	5	96	Due to the Tripping of 765 kV Phagi Bhiwani ckt 1 and 765 kV Phagi Gwalior Ckt 1
2	ER-NR	8000	7600	7800	7400	-200	2023-05-26	5	96	Due to the Tripping of 765 kV Phagi Bhiwani ckt 1 and 765 kV Phagi Gwalior Ckt 1
3	NR_IMPORT	25800	24400	25150	23750	-650	2023-05-26	5	96	Due to the Tripping of 765 kV Phagi Bhiwani ckt 1 and 765 kV Phagi Gwalior Ckt 1

SCE-NLDC