

GRID CONTROLLER OF INDIA LIMITED  
National Load Despatch Centre



From: The Shift Charge Manager, NLDC

To: The Shift Charge Manager, NRLDC/WRLDC/ERLDC

Date: 5/27/2023  
Time: 7:05:32 AM

Sl.No	Corridor	Current TTC(MW)	Current ATC(MW)	Revised TTC(MW)	Revised ATC(MW)	Change in ATC (MW)	Date for which Revision is done(dd-mm-yyyy)	Time Block for Revision(From TB)	Time Block for Revision(To TB)	Reason for Revision/Event for which TTC/ATC Revision is being done
1	WR-NR	17100	16100	14550	13550	-2550	2023-05-27	34	48	Emergency shutdown of champa - kurukshetra bipole
2	ER-NR	7800	7400	7450	7050	-350	2023-05-27	34	48	Emergency shutdown of champa - kurukshetra bipole
3	NR_IMPORT	24900	23500	22000	20600	-2900	2023-05-27	34	48	Emergency shutdown of champa - kurukshetra bipole

SCE-NLDC