

**National Load Despatch Centre**  
**Total Transfer Capability for August 2012**

Issue Date: 27/04/2012

Issue Time: 1100 hrs

Revision No. 0

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Comments
NR-WR	1st August 2012 to 31st August 2012	00-24	1900	200	1700	286	1414	
WR-NR	1st August 2012 to 31st August 2012	00-24	2200	200	2000	260	1740	
NR-ER	1st August 2012 to 31st August 2012	00-17	800	200	600	0	600	
		23-24	900		700		700	
ER-NR	1st August 2012 to 31st August 2012	00-24	5000	300	4700	1158	3542	
WR-ER	1st August 2012 to 31st August 2012	00-24	1000	300	700	0	700	
ER-WR	1st August 2012 to 31st August 2012	00-24	1000	300	700	650	50	
WR-SR	1st August 2012 to 31st August 2012	00-24	800	0	800	800	0	LTA of 231 MW from Jhajar to AP. MTOA of 750 MW towards SR (not path specific)
SR-WR	1st August 2012 to 31st August 2012	00-24	900	0	900	0	900	
ER-SR	1st August 2012 to 27th August 2012	00-24	970	0	970	340	630	149 MW allocation from ER ISGS to SR. MTOA of 750 MW towards SR (not path specific)
	28th August 2012 to 31st August 2012	00-24	530		530		190	
SR-ER	1st August 2012 to 27th August 2012	00-17	800	0	800	148	652	
		23-24	900		900		752	
	28th August 2012 to 31st August 2012	00-17	800		800	197	603	
		23-24	900		900		703	
ER-NER	1st August 2012 to 31st August 2012	00-17	490	35	455	135	320	
		23-24	450			138	317	
NER-ER	1st August 2012 to 31st August 2012	00-17	550	100	450	0	450	
		23-24	530		430		430	
S1-S2	1st August 2012 to 31st August 2012	00-10	5800	100	5700	3800	1900	
		10-24	5500		5400		1600	
JPL Complex	1st August 2012 to 31st August 2012	00-24	1030	0	1030	0	1030	
Import TTC for DD&DNH	1st August 2012 to 31st August 2012	00-24	980	0	980	LTA and MTOA as per ex-pp schedule		

- 1) ER-SR TTC declared at Talcher Interconnector and Gazuwaka HVDC B/B seam  
2) ^ S1 comprises of AP and Karnataka; S2 comprises of Tamil Nadu, Kerala and Pondicherry

## Limiting Constraints

Corridor	Constraint
<b>NR-WR</b>	(n-1) contingency of 400kV Bina(PG)-Bina(MP)
<b>WR-NR</b>	(n-1) contingency of 400kV Bina-Gwalior
<b>NR-ER</b>	(n-1) contingency of 400 kV Pusauli-Biharsharif
<b>ER-NR</b>	(n-1) contingency of 400 kV Purnea-Muzaffarpur
<b>WR-ER</b>	(n-1) contingency of 400 kV Maithon-Kahalgaon Highloading of 220kV Korba(E)-Raigarh
<b>ER-WR</b>	High loading of 400 kV Raipur-Bhadrawati T/C, Bhilai-Bhadrawati S/C, Bhilai-Koradi and Bhilai-Seoni (n-1) contingency of 400kV Rourkela-Jamshedpur
<b>WR-SR</b>	High loading of 400 kV Raipur-Bhadravati T/C and Bhilai-Bhadrawati S/C (n-1) contingency of 400 kV Vijaywada-Nellore*
<b>SR-WR</b>	(n-1) contingency of Chandrapur-Parli
<b>ER-SR</b>	(n-1) contingency of 400 kV Vijaywada-Nellore* Low Voltage in Chennai Area*
<b>SR-ER</b>	(n-1) contingency of 400 kV Maithon-Kahalgaon* (n-1) contingency of 400 kV Kadappa-Kolar and Neyvelli- Sriperumbudur
<b>ER-NER</b>	(n-1) contingency of 400 kV Binaguri-Bongaigaon High Loading of 220 kV BTPS-Agia High Loading of 220 kV Balipara-Samaguri High Loading of 400/220 kV 315 MVA ICT at Misa*
<b>NER-ER</b>	(n-1) contingency of 400 kV Purnea-Muzaffarpur High Loading of 220 kV BTPS-Agia High Loading of 220 kV Balipara-Samaguri High Loading of 400/220 kV 315 MVA ICT at Misa*
<b>S1-S2</b>	(n-1) contingency of 400 kV Hosur-Salem

\*Primary constraints

**Simultaneous Import Capability**

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Comments
ER								
NR	1st August 2012 to 31st August 2012	00-24	6200	500	5700	1418	4282	
NER	1st August 2012 to 31st August 2012	00-17	490	35	455	135	320	
		23-24	450			138	317	
WR								
SR	1st August 2012 to 27th August 2012	00-24	1770	0	1770	1140	630	
	28th August 2012 to 31st August 2012	00-24	1330		1330		190	

**Simultaneous Export Capability**

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Comments
ER								
NR	1st August 2012 to 31st August 2012	00-24	2300	500	1800	286	1514	
NER	1st August 2012 to 31st August 2012	00-17	550	100	450	0	450	
		23-24	530		430		430	
WR								
SR	1st August 2012 to 27th August 2012	00-17	1700	0	1700	148	1552	
		23-24	1800		1800		1652	
	28th August 2012 to 31st August 2012	00-17	1700		1700	197	1503	
		23-24	1800		1800		1603	

## Limiting Constraints

<b>NR</b>	<b>Import</b>	(n-1) contingency of 400 kV Purnea Muzaffarpur* (n-1) contingency of 400kV Bina-Gwalior
	<b>Export</b>	(n-1) contingency of 400 kV Kahalgaon-Maithon
<b>NER</b>	<b>Import</b>	High Loading of 220 kV BTPS-Agia High Loading of 220 kV Balipara-Samaguri High Loading of 400/220 kV 315 MVA ICT at Misa* (n-1) contingency of 400 kV Binaguri-Bongaigaon
	<b>Export</b>	High Loading of 220 kV BTPS-Agia High Loading of 220 kV Balipara-Samaguri High Loading of 400/220 kV 315 MVA ICT at Misa (n-1) contingency of 400 kV Purnea-Muzaffarpur*
<b>SR</b>	<b>Import</b>	High loading of 400 kV Raipur-Bhadravati T/C and Bhilai-Bhadrawati S/C Low Voltage in Chennai Area (n-1) contingency of 400 kV Vijaywada-Nellore
	<b>Export</b>	(n-1) contingency of Chandrapur-Parli (n-1) contingency of 400 kV Maithon Kahalgaon (n-1) contingency of 400 kV Kadappa-Kolar and neyvelli- Sriperumbudur

## ASSUMPTIONS IN BASECASE

S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
<b>I</b>	<b>NORTHERN REGION</b>				
1	Punjab	7522	7600	2825	2665
2	Haryana	5743	5453	3293	3293
3	Rajasthan	5938	5977	3398	3357
4	Delhi	4474	4037	1259	1259
5	Uttar Pradesh	9714	9534	4253	3958
6	Jammu & Kashmir	1873	1773	586	615
7	Uttarakhand	1560	1100	955	929
8	Himachal Pradesh	1030	970	745	745
9	Chandigarh	279	203	0	0
10	ISGS			18020	16510
	<b>Total NR</b>	<b>38133</b>	<b>36647</b>	<b>35334</b>	<b>33331</b>
<b>II</b>	<b>EASTERN REGION</b>				
1	West Bengal	6250	4930	4617	3942
2	Jharkhand	900	700	390	390
3	Orissa	3300	2400	2707	2092
4	Bihar	1650	1300	130	130
5	Damodar Valley Corporation	2200	1900	1551	1551
6	Sikkim	60	60	0	0
7	Bhutan	110	110	1400	1400
8	ISGS			6236	6236
	<b>Total ER</b>	<b>14470</b>	<b>11400</b>	<b>17031</b>	<b>15741</b>
<b>III</b>	<b>WESTERN REGION</b>				
1	Chattisgarh	2444	1983	2646	1477
2	Madhya Pradesh	4925	3944	2991	2687
3	Maharashtra	14032	10167	10978	7763
4	Gujarat	8503	6100	7765	5617
5	Goa	280	176		
6	Daman and Diu	206	209		
7	Dadra and Nagar Haveli	510	480		
8	ISGS			11071	10127
	<b>Total WR</b>	<b>30901</b>	<b>23059</b>	<b>35451</b>	<b>27671</b>
<b>IV</b>	<b>SOUTHERN REGION</b>				
1	Andhra Pradesh	10612	9050	6576	5220
2	Tamil Nadu	9900	8700	4856	4076
3	Karnataka	7700	5200	5297	3508
4	Kerala	2700	2200	1890	1050
5	Pondy	290	230		
6	Goa	80	60		
7	ISGS			9800	8950
	<b>Total SR</b>	<b>31282</b>	<b>25440</b>	<b>28419</b>	<b>22804</b>
<b>V</b>	<b>NORTH-EASTERN REGION</b>				
1	Manipur	115	92	0	0
2	Meghalaya	258	180	120	70
3	Mizoram	70	40	0	0
4	Nagaland	70	60	15	15
5	Assam	950	824	240	220
6	Tripura	180	100	105	100
7	Arunachal Pradesh	124	83	0	0
8	ISGS			1292	682
	<b>Total NER</b>	<b>1767</b>	<b>1379</b>	<b>1772</b>	<b>1087</b>
	<b>Total All India</b>	<b>116552</b>	<b>97925</b>	<b>118007</b>	<b>100634</b>