

**National Load Despatch Centre
Total Transfer Capability for January 2012**

Issue Date: 04/01/2012

Issue Time: 1100 hrs

Revision No. 1

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Comments
NR-WR	1st January 2012 to 31st January 2012	00-24	1900	200	1700	286	1414	
WR-NR	1st January 2012 to 31st January 2012	00-24	2000	200	1800	0	1800	
NR-ER	1st January 2012 to 31st January 2012	00-17	800	200	600	0	600	
		23-24						
		17-23	900		700		700	
ER-NR	5th January 2012 to 31st January 2012	00-17	2150	300	1850	977	873	Revised due to low generation at Tala, Chukha, Teesta and NER
		23-24						
		17-23	2450		2150		1173	
WR-ER	1st January 2012 to 31st January 2012	00-17	900	300	600	0	600	
		23-24						
		17-23	1000		700		700	
ER-WR#	5th January 2012 to 31st January 2012	00-24	950	300	650	427	223	Revised due to low generation at Korba NTPC because of ash handling problem
WR-SR	1st January 2012 to 31st January 2012	00-24	800	0	800	242	558	
SR-WR	1st January 2012 to 31st January 2012	00-24	850	0	850	0	850	
ER-SR	1st January 2012 to 31st January 2012	00-05 10-19	120	0	120	120	0	
		05-10 19-24	530		530		410	
SR-ER	1st January 2012 to 31st January 2012	00-17	700	0	700	197	503	
		23-24						
		17-23	800		800		603	
ER-NER	5th January 2012 to 31st January 2012	00-17	300	50	250	204	46	Revised due to low generation at Tala, Chukha, Teesta and NER
		23-24						
		17-23	350		300		92	
NER-ER	1st January 2012 to 31st January 2012	00-24	570	100	470	0	470	
S1-S2	1st January 2012 to 31st January 2012	00-24	5000	100	4900	3100	1800	

1) ER-SR TTC declared at Talcher Interconnector and Gazuwaka HVDC B/B seam

2) ^ S1 comprises of AP and Karnataka; S2 comprises of Tamil Nadu, Kerala and Pondicherry

Limiting Constraints

Corridor	Constraint
NR-WR	(n-1) contingency of 400kV Bina(PG)-Bina(MP)
WR-NR	(n-1) contingency of 400kV Bina-Gwalior one circuit leading to over loading of the other circuit of 400 kV Bina-Gwalior and 400kV Soja-Zerda S/C
NR-ER	(n-1) contingency of 400 kV Maithon-Jamshedpur
ER-NR	(n-1) contingency of 400 kV Farakka-Malda
WR-ER	(n-1) contingency of 400 kV Farakka-Malda and Maithon-Kahalgaon
ER-WR	High loading of 400 kV Raipur-Bhadrawati T/C, Bhilai-Bhadrawati S/C, Bhilai-Koradi and Bhilai-Seoni (n-1) contingency of 400kV Maithon-Jamshedpur
WR-SR	High loading of 400 kV Raipur-Bhadrawati T/C and Bhilai-Bhadrawati S/C (n-1) contingency of 400 kV Vijaywada-Nellore*
SR-WR	(n-1) contingency of Chandrapur-Parli
ER-SR	(n-1) contingency of 400 kV Vijaywada-Nellore* Low Voltage in Chennai Area*
SR-ER	(n-1) contingency of 400 kV Farakka-Malda and Maithon-Kahalgaon (n-1) contingency of 400 kV Kadappa-Kolar and Neyvelli- Sriperumbudur
ER-NER	(n-1) contingency of 400 kV Farakka-Malda High Loading of 220 kV BTPS-Agia High Loading of 220 kV Balipara-Samaguri High Loading of 400/220 kV 315 MVA ICT at Misa
NER-ER	(n-1) contingency of 400 kV Binaguri-Bongaigaon High Loading of 220 kV BTPS-Agia High Loading of 220 kV Balipara-Samaguri High Loading of 400/220 kV 315 MVA ICT at Misa
S1-S2	(n-1) contingency of 400 kV Hosur-Salem

*Primary constraints

Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Comments
ER								
NR	5th January 2012 to 31st January 2012	00-17 23-24	4150	500	3650	977	2673	Revised due to low generation at Tala, Chukha, Teesta and NER
		17-23	4450		3950		2973	
NER	5th January 2012 to 31st January 2012	00-17 23-24	300	50	250	204	46	
		17-23	350		300		208	
WR								
SR	1st January 2012 to 31st January 2012	00-05 10-19	920	0	920	342	578	
		05-10 19-24	1380		1380		1038	

Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Comments
ER								
NR	1st January 2012 to 31st January 2012	00-24	2300	500	1800	286	1514	
NER	1st January 2012 to 31st January 2012	00-24	570	100	470	0	470	
WR								
SR	1st January 2012 to 31st January 2012	00-17 23-24	1550	0	1550	197	1353	
		17-23	1650		1650		1453	

Limiting Constraints

NR	Import	(n-1) contingency of 400 kV Farakka-Kahalgaon
	Export	(n-1) contingency of 400 kV Kahalgaon-Maithon
NER	Import	High Loading of 220 kV BTPS-Agia High Loading of 220 kV Balipara-Samaguri High Loading of 400/220 kV 315 MVA ICT at Misa (n-1) contingency of 400 kV Farakka-Malda*
	Export	High Loading of 220 kV BTPS-Agia High Loading of 220 kV Balipara-Samaguri High Loading of 400/220 kV 315 MVA ICT at Misa (n-1) contingency of 400 kV Binaguri-Bongaigaon*
SR	Import	High loading of 400 kV Raipur-Bhadravati T/C and Bhilai-Bhadrawati S/C Low Voltage in Chennai Area (n-1) contingency of 400 kV Vijaywada-Nellore
	Export	(n-1) contingency of Chandrapur-Parli (n-1) contingency of 400 kV Farakka-Kahalgaon and Maithon Kahalgaon (n-1) contingency of 400 kV Kadappa-Kolar and neyvelli- Sriperumbudur

ASSUMPTIONS IN BASECASE

S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
I	NORTHERN REGION				
1	Punjab	5182	3499	2668	2287
2	Haryana	4728	3718	2963	2963
3	Rajasthan	6057	5461	3605	3577
4	Delhi	3749	3121	1174	1174
5	Uttar Pradesh	8069	8116	3565	3585
6	Jammu & Kashmir	1688	1442	325	145
7	Uttarakhand	1151	1015	538	308
8	Himachal Pradesh	1013	895	222	64
9	Chandigarh	253	155	0	0
10	ISGS			15214	10686
	Total NR	31890	27420	30273	24789
II	EASTERN REGION				
1	West Bengal	5700	4750	4617	3942
2	Jharkhand	850	700	390	390
3	Orissa	3150	2250	2707	2092
4	Bihar	1700	1400	130	130
5	Damodar Valley Corporation	2000	1800	1551	1551
6	Sikkim	60	60	0	0
7	Bhutan	110	110	1400	1400
8	ISGS			5370	4950
	Total ER	13570	11070	16165	14455
III	WESTERN REGION				
1	Chattisgarh	2890	2343	3509	2836
2	Madhya Pradesh	6991	4680	4212	2677
3	Maharashtra	15000	12000	13232	10112
4	Gujarat	9915	7575	8984	6595
5	Goa	400	283	0	0
6	Daman and Diu	226	221	0	0
7	Dadra and Nagar Haveli	505	460	0	0
8	ISGS			9964	9754
	Total WR	35927	27562	39901	31974
IV	SOUTHERN REGION				
1	Andhra Pradesh	9500	8054	5731	4205
2	Tamil Nadu	9400	8190	5125	4335
3	Karnataka	5955	5045	4082	3198
4	Kerala	2645	1890	1892	1081
5	Pondy	260	260		
6	Goa	75	75		
7	ISGS			7843	7357
	Total SR	27835	23514	24673	20176
V	NORTH-EASTERN REGION				
1	Manipur	120	70	0	0
2	Meghalaya	258	180	120	70
3	Mizoram	70	40	0	0
4	Nagaland	70	60	15	15
5	Assam	950	700	240	220
6	Tripura	180	100	105	100
7	Arunachal Pradesh	70	55	0	0
8	ISGS			1292	682
	Total NER	1718	1205	1772	1087
	Total All India	110940	90771	112784	92481