

**National Load Despatch Centre
Total Transfer Capability for November 2012**

Issue Date: 18/09/2012

Issue Time: 1200 hrs

Revision No. 1

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Comments
NR-WR	1st November 2012 to 30th November 2012	00-24	1900	200	1700	286	1414	
WR-NR	1st November 2012 to 30th November 2012	00-24	2400	200	2200	260	1940	
NR-ER	1st November 2012 to 30th November 2012	00-17	800	200	600	0	600	
		23-24	900		700		700	
ER-NR	1st November 2012 to 30th November 2012	00-17	3500	300	3200	1031	2169	
		23-24					2125	
WR-ER#	1st November 2012 to 30th November 2012	00-24	1100	300	800	0	800	Sterlite considered in WR in bid area W3 for which separate export TTC is indicated
ER-WR#	1st November 2012 to 30th November 2012	00-24	900	250	650	650	0	
WR-SR	1st November 2012 to 30th November 2012	00-24	800	0	800	761	39	
SR-WR	1st November 2012 to 30th November 2012	00-24	1000	0	1000	0	1000	
ER-SR	1st November 2012 to 30th November 2012	00-05 10-19	530	0	530	170	360	
		05-10 19-24	800		800		630	
SR-ER	1st November 2012 to 30th November 2012	00-17	800	0	800	197	603	
		23-24	900		900		703	
ER-NER	1st November 2012 to 30th November 2012	00-17	500	35	465	156	309	
		23-24	500		465	159	306	
NER-ER	1st November 2012 to 30th November 2012	00-17	700	100	600	0	600	
		23-24	330		230		230	
S1-S2	1st November 2012 to 30th November 2012	00-10	5800	100	5700	3800	1900	
		10-24	5500		5400		1600	
Import TTC for DD&DNH	1st November 2012 to 30th November 2012	00-24	980	0	980	LTA and MTOA as per ex-pp schedule		
W3 zone export TTC	1st November 2012 to 30th November 2012	00-24	7000	200	6800	5700	1100	

1) ER-SR TTC declared at Talcher Interconnector and Gazuwaka HVDC B/B seam

2) ^ S1 comprises of AP and Karnataka: S2 comprises of Tamil Nadu, Kerala and Pondicherry

3) W3 comprises of the following regional entities and would be operational wef 0000 hrs of 18th September 2012

a) Chattisgarh, b) Jindal Power Limited (JPL), c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak

f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat

Limiting Constraints

Corridor	Constraint
NR-WR	(n-1) contingency of 400kV Bina(PG)-Bina(MP)
WR-NR	Low voltage at Gwalior on outage of 400 kV Bina-Gwalior
NR-ER	(n-1) contingency of 400 kV Pusauli-Biharsharif
ER-NR	(n-1-l) contingency of 400 kV Farakka-Malda
WR-ER	(n-1) contingency of 400 kV Maithon-Kahalgaon* Highloading of 220kV Korba(E)-Raigarh
ER-WR	High loading of 400 kV Raipur-Bhadrawati T/C, Bhilai-Bhadrawati S/C, Bhilai-Koradi and Bhilai-Seoni (n-1) contingency of 400kV Rourkela-Jamshedpur
WR-SR	High loading of 400 kV Raipur-Bhadravati T/C and Bhilai-Bhadrawati S/C (n-1) contingency of 400 kV Vijaywada-Nellore*
SR-WR	Bhadrawati HVDC B/B link capacity
ER-SR	(n-1) contingency of 400 kV Vijaywada-Nellore* Low Voltage in Chennai Area* (n-1) contingency of 400 kV Rourkela-Talcher*
SR-ER	(n-1) contingency of 400 kV Maithon-Kahalgaon* (n-1) contingency of 400 kV Kadappa-Kolar and Neyvelli- Sriperumbudur
ER-NER	(n-1) contingency of 400 kV Farakka-Malda * High Loading of 220 kV BTPS-Agia High Loading of 220 kV Balipara-Samaguri (n-1) contingency of 400/220 kV 315 MVA ICT at Misa
NER-ER	(n-1) contingency of 400 kV Purnea-Muzaffarpur High Loading of 220 kV BTPS-Agia High Loading of 220 kV Balipara-Samaguri (n-1) contingency of 400/220 kV 315 MVA ICT at Misa
S1-S2	(n-1) contingency of 400 kV Hosur-Salem
W3 zone	
export TTC	High loading of 400 kV Raipur-Bhadrawati T/C, Bhilai-Bhadrawati S/C, Bhilai-Koradi and Bhilai-Seoni *Primary constraints

Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Comments
ER								
NR	1st November 2012 to 30th November 2012	00-17	5900	500	5400	1291	4109	
		23-24			5400	1335	4065	
NER	1st November 2012 to 30th November 2012	00-17	500	35	465	156	309	
		23-24	500		465	159	306	
WR								
SR	1st November 2012 to 30th November 2012	00-05	1330	0	1330	931	399	
		10-19	1600		1600		669	

Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Comments
ER								
NR	1st November 2012 to 30th November 2012	00-24	2300	500	1800	286	1514	
NER	1st November 2012 to 30th November 2012	00-17	700	100	600	0	600	
		23-24	330		230		230	
WR								
SR	1st November 2012 to 30th November 2012	00-17	1800	0	1800	148	1652	
		23-24	1900		1900		1752	

Limiting Constraints

NR	Import	(n-1-1) contingency of 400 kV Farakka-Malda* Low voltage at Gwalior on outage of 400 kV Bina-Gwalior*
	Export	(n-1) contingency of 400 kV Kahalgaon-Maithon
NER	Import	High Loading of 220 kV BTPS-Agia High Loading of 220 kV Balipara-Samaguri High Loading of 400/220 kV 315 MVA ICT at Misa* (n-1) contingency of 400 kV Farakka-Malda*
	Export	High Loading of 220 kV BTPS-Agia High Loading of 220 kV Balipara-Samaguri High Loading of 400/220 kV 315 MVA ICT at Misa (n-1) contingency of 400 kV Purnea-Muzaffarpur*
SR	Import	High loading of 400 kV Raipur-Bhadravati T/C and Bhilai-Bhadrawati S/C (n-1) contingency of 400 kV Rourkela-Talcher Low Voltage in Chennai Area (n-1) contingency of 400 kV Vijaywada-Nellore
	Export	(n-1) contingency of Chandrapur-Parli (n-1) contingency of 400 kV Maithon Kahalgaon (n-1) contingency of 400 kV Kadappa-Kolar and Neyvelli- Sriperumbudur

ASSUMPTIONS IN BASECASE

S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
I	NORTHERN REGION				
1	Punjab	5213	4425	2078	2022
2	Haryana	5107	4336	3432	3432
3	Rajasthan	7437	6423	4076	3941
4	Delhi	3980	3379	1330	1330
5	Uttar Pradesh	10049	8632	5085	4959
6	Jammu & Kashmir	1798	1526	345	243
7	Uttarakhand	1338	1005	555	335
8	Himachal Pradesh	1030	874	582	284
9	Chandigarh	250	150	0	0
10	ISGS			15413	11010
	Total NR	36201	30751	32896	27555
II	EASTERN REGION				
1	West Bengal	6250	4930	4617	3942
2	Jharkhand	900	700	390	390
3	Orissa	3300	2400	2707	2092
4	Bihar	1650	1300	130	130
5	Damodar Valley Corporation	2200	1900	1551	1551
6	Sikkim	60	60	0	0
7	Bhutan	110	110	1400	1400
8	ISGS			6236	6236
	Total ER	14470	11400	17031	15741
III	WESTERN REGION				
1	Chattisgarh	2767	2138	2518	1985
2	Madhya Pradesh	7653	6229	3643	2802
3	Maharashtra	14659	11906	13413	9454
4	Gujarat	9908	7881	9933	7564
5	Goa	327	198		
6	Daman and Diu	218	157		
7	Dadra and Nagar Haveli	535	241		
8	ISGS			12120	11496
	Total WR	36066	28748	41627	33301
IV	SOUTHERN REGION				
1	Andhra Pradesh	10200	8960	7729	5978
2	Tamil Nadu	9900	8566	4423	3439
3	Karnataka	7300	5612	4701	3300
4	Kerala	3300	2166	1343	896
5	Pondy	300	275	0	0
6	Goa	80	80	0	0
7	ISGS			9700	8800
	Total SR	31080	25659	27896	22413
V	NORTH-EASTERN REGION				
1	Manipur	105	100	0	0
2	Meghalaya	260	190	120	70
3	Mizoram	70	40	0	0
4	Nagaland	70	60	15	15
5	Assam	870	824	220	220
6	Tripura	170	100	105	100
7	Arunachal Pradesh	124	83	0	0
8	ISGS			1092	482
	Total NER	1669	1397	1552	887
	Total All India	119486	97955	121002	99897