

**National Load Despatch Centre**  
**Total Transfer Capability for September 2012**

Issue Date: 29/06/2012

Issue Time: 1500 hrs

Revision No. 2

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Comments
NR-WR	1st September 2012 to 30th September 2012	00-24	1900	200	1700	286	1414	
WR-NR	1st September 2012 to 30th September 2012	00-24	2200	200	2000	260	1740	
NR-ER	1st September 2012 to 30th September 2012	00-17	800	200	600	0	600	
		23-24	900		700		700	
ER-NR	1st September 2012 to 30th September 2012	00-24	5000	300	4700	1158	3542	
WR-ER	1st September 2012 to 30th September 2012	00-24	1000	300	700	0	700	
ER-WR	1st September 2012 to 30th September 2012	00-24	1000	300	700	650	50	
WR-SR	1st September 2012 to 30th September 2012	00-24	800	0	800	800	0	LTA of 231 MW from Jajjar to AP & Kerala. MTOA of 761 MW towards SR (not path specific)
SR-WR	1st September 2012 to 30th September 2012	00-24	1000	0	1000	0	1000	
ER-SR#	1st September 2012 to 30th September 2012	00-05, 10-13, 17-19	530	0	530	352	178	Revised as Talcher-Kolar bipole would be operated at 2500 MW for 05-10 hrs and 19-24 hrs; 2000 MW for 00-05 hrs, 10-13 hrs, 17-19 hrs; 1800 MW for 13-17 hrs. 160 MW allocation from ER ISGS to SR. MTOA of 761 MW towards SR (not path specific)
		05-10, 19-24	1030		1030		678	
		13-17	330		330		0	
SR-ER	1st September 2012 to 30th September 2012	00-17	800	0	800	197	603	
		23-24	900		900		703	
ER-NER	1st September 2012 to 30th September 2012	00-17	560	35	525	161	364	
		23-24	490		455		289	
NER-ER	1st September 2012 to 30th September 2012	00-17	550	100	450	0	450	
		23-24	550		450		450	
S1-S2	1st September 2012 to 30th September 2012	00-10	5800	100	5700	3800	1900	
		10-24'	5500		5400		1600	
JPL Complex	1st September 2012 to 30th September 2012	00-24	1030	0	1030	0	1030	
Import of Punjab	1st September 2012 to 30th September 2012	00-24	5400	300	5100	3243	1857	
Import TTC for DD&DNH	1st September 2012 to 30th September 2012	00-24	980	0	980	LTA and MTOA as per ex-pp schedule		

1) ER-SR TTC declared at Talcher Interconnector and Gazuwaka HVDC B/B seam

2) ^ S1 comprises of AP and Karnataka; S2 comprises of Tamil Nadu, Kerala and Pondicherry

## Limiting Constraints

Corridor	Constraint
<b>NR-WR</b>	(n-1) contingency of 400kV Bina(PG)-Bina(MP)
<b>WR-NR</b>	(n-1) contingency of 400kV Bina-Gwalior
<b>NR-ER</b>	(n-1) contingency of 400 kV Pusauli-Biharsharif
<b>ER-NR</b>	(n-1) contingency of 400 kV Purnea-Muzaffarpur
<b>WR-ER</b>	(n-1) contingency of 400 kV Maithon-Kahalgaon Highloading of 220kV Korba(E)-Raigarh
<b>ER-WR</b>	High loading of 400 kV Raipur-Bhadrawati T/C, Bhilai-Bhadrawati S/C, Bhilai-Koradi and Bhilai-Seoni (n-1) contingency of 400kV Rourkela-Jamshedpur
<b>WR-SR</b>	High loading of 400 kV Raipur-Bhadrawati T/C and Bhilai-Bhadrawati S/C (n-1) contingency of 400 kV Vijaywada-Nellore*
<b>SR-WR</b>	(n-1) contingency of Chandrapur-Parli
<b>ER-SR</b>	(n-1) contingency of 400 kV Vijaywada-Nellore* Low Voltage in Chennai Area*
<b>SR-ER</b>	(n-1) contingency of 400 kV Maithon-Kahalgaon* (n-1) contingency of 400 kV Kadappa-Kolar and Neyvelli- Sriperumbudur
<b>ER-NER</b>	(n-1) contingency of 400 kV Binaguri-Bongaigaon High Loading of 220 kV BTPS-Agia High Loading of 220 kV Balipara-Samaguri High Loading of 400/220 kV 315 MVA ICT at Misa, Balipara*
<b>NER-ER</b>	(n-1) contingency of 400 kV Purnea-Muzaffarpur High Loading of 220 kV BTPS-Agia High Loading of 220 kV Balipara-Samaguri High Loading of 400/220 kV 315 MVA ICT at Misa*
<b>S1-S2</b>	(n-1) contingency of 400 kV Hosur-Salem

\*Primary constraints

**Simultaneous Import Capability**

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Comments
ER								
NR	1st September 2012 to 30th September 2012	00-24	6200	500	5700	1418	4282	
NER	1st September 2012 to 30th September 2012	00-17	560	35	525	161	364	
		23-24	490		455	166	289	
WR								
SR#	1st September 2012 to 30th September 2012	00-05, 10-13, 17-19	1330	0	1330	1152	178	would be operated at 2500 MW for 05-10 hrs and 19-24 hrs; 2000 MW for 00-05 hrs, 10-13 hrs, 17-19 hrs; 1800 MW for 13-17 hrs. 149 MW allocation from ER ISGS to SR. MTOA of 761 MW towards SR (not path specific)
		05-10, 19-24	1830		1830		678	
		13-17	1130		1130	1130	0	

**Simultaneous Export Capability**

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Comments
ER								
NR	1st September 2012 to 30th September 2012	00-24	2300	500	1800	286	1514	
NER	1st September 2012 to 30th September 2012	00-17	550	100	450	0	450	
		23-24	530		430		430	
WR								
SR	1st September 2012 to 30th September 2012	00-17	1800	0	1800	197	1603	
		23-24	1900		1900		1703	

## Limiting Constraints

<b>NR</b>	<b>Import</b>	(n-1) contingency of 400 kV Purnea Muzaffarpur* (n-1) contingency of 400kV Bina-Gwalior
	<b>Export</b>	(n-1) contingency of 400 kV Kahalgaon-Maithon
<b>NER</b>	<b>Import</b>	High Loading of 220 kV BTPS-Agia High Loading of 220 kV Balipara-Samaguri High Loading of 400/220 kV 315 MVA ICT at Misa* (n-1) contingency of 400 kV Binaguri-Bongaigaon
	<b>Export</b>	High Loading of 220 kV BTPS-Agia High Loading of 220 kV Balipara-Samaguri High Loading of 400/220 kV 315 MVA ICT at Misa (n-1) contingency of 400 kV Purnea-Muzaffarpur*
<b>SR</b>	<b>Import</b>	High loading of 400 kV Raipur-Bhadravati T/C and Bhilai-Bhadrawati S/C Low Voltage in Chennai Area (n-1) contingency of 400 kV Vijaywada-Nellore
	<b>Export</b>	(n-1) contingency of Chandrapur-Parli (n-1) contingency of 400 kV Maithon Kahalgaon (n-1) contingency of 400 kV Kadappa-Kolar and neyvelli- Sriperumbudur

## ASSUMPTIONS IN BASECASE

S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
<b>I</b>	<b>NORTHERN REGION</b>				
1	Punjab	7551	7100	3016	2877
2	Haryana	5901	5400	3293	3293
3	Rajasthan	6100	5900	3552	3480
4	Delhi	4565	4200	1396	1396
5	Uttar Pradesh	10050	10300	5166	4832
6	Jammu & Kashmir	1900	1802	560	609
7	Uttarakhand	1600	1230	899	906
8	Himachal Pradesh	1030	970	745	745
9	Chandigarh	282	231	0	0
10	ISGS			18226	16779
	<b>Total NR</b>	<b>38979</b>	<b>37133</b>	<b>36853</b>	<b>34918</b>
<b>II</b>	<b>EASTERN REGION</b>				
1	West Bengal	6250	4930	4617	3942
2	Jharkhand	900	700	390	390
3	Orissa	3300	2400	2707	2092
4	Bihar	1650	1300	130	130
5	Damodar Valley Corporation	2200	1900	1551	1551
6	Sikkim	60	60	0	0
7	Bhutan	110	110	1400	1400
8	ISGS			6236	6236
	<b>Total ER</b>	<b>14470</b>	<b>11400</b>	<b>17031</b>	<b>15741</b>
<b>III</b>	<b>WESTERN REGION</b>				
1	Chattisgarh	2608	1983	2147	1716
2	Madhya Pradesh	5223	4166	3238	2739
3	Maharashtra	15700	12000	12016	8352
4	Gujarat	9618	6440	11085	6815
5	Goa	300	197		
6	Daman and Diu	225	177		
7	Dadra and Nagar Haveli	439	477		
8	ISGS			11971	10595
	<b>Total WR</b>	<b>34112</b>	<b>25439</b>	<b>40457</b>	<b>30217</b>
<b>IV</b>	<b>SOUTHERN REGION</b>				
1	Andhra Pradesh	10715	9050	7729	5978
2	Tamil Nadu	10100	8700	4423	3439
3	Karnataka	7200	5700	4701	3300
4	Kerala	2950	2300	1343	896
5	Pondy	325	250	0	0
6	Goa	80	80	0	0
7	ISGS			9700	8800
	<b>Total SR</b>	<b>31370</b>	<b>26080</b>	<b>27896</b>	<b>22413</b>
<b>V</b>	<b>NORTH-EASTERN REGION</b>				
1	Manipur	115	92	0	0
2	Meghalaya	258	180	120	70
3	Mizoram	70	40	0	0
4	Nagaland	70	60	15	15
5	Assam	950	824	240	220
6	Tripura	180	100	105	100
7	Arunachal Pradesh	124	83	0	0
8	ISGS			1292	682
	<b>Total NER</b>	<b>1767</b>	<b>1379</b>	<b>1772</b>	<b>1087</b>
	<b>Total All India</b>	<b>120698</b>	<b>101431</b>	<b>124009</b>	<b>104376</b>