National Load Despatch Centre Total Transfer Capability for October 2012

Issue Date: 05/10/2012 Issue Time: 1630 hrs Revision No. 9

			Total		Available	Long Term	Margin	
Corridor	Date	Time Period (hrs)	Transfer Capability (TTC)	Reliability Margin	Transfer Capability (ATC)	Access (LTA)/ Medium Term Open Access (MTOA)	Available for Short Term Open Access (STOA)	Comments
NR-WR	1st October 2012 to 31st October 2012	00-24	1500	200	1300	286	1014	
WR-NR	5th October 2012	00-08, 20-24 08-20'	1700 1600	200	1500 1400	520	980 880	
WK-NK	6th October 2012 to 31st October 2012	00-24	1700	200	1500	520	980	
	1st October 2012 to	00-17,	800		600		600	
NR-ER	31st October 2012	23-24 17-23	900	200	700	0	700	
	5th October 2012 to	00-08, 19-24	4000	300	3700	1158	2542	
ER-NR	19th October 2012	08-19'	3500	300	3200	1136	2042	
	20th October 2012 to 31st October 2012	00-24	4000	300	3700	1158	2542	
	1st October 2012 to	l				1		
WR-ER	31st October 2012 to 31st October 2012	00-24	1400	300	1100	0	1100	
ER-WR	1st October 2012 to 31st October 2012	00-24	900	250	650	650	0	
	2nd October 2012 to 10th October 2012	00-24	1000		1000	992	8	
WR-SR	11th October 2012 to	00-24	900	0	900	900	0	
	31st October 2012 1st October 2012 to							
SR-WR	31st October 2012	00-24	1000	0	1000	0	1000	
	6th October 2012 to 10th October 2012	00-24	185*	0	185*	185	0*	Outage of U#1 of Talcher Stage 1 due to tube leakage
	11th October 2012 to	00-05, 10-19	500	0	500	262	238	
ER-SR#	17th October 2012	05-10, 19-24	500*	Ü	500*	202	238*	
	18th October 2012 to 31st October 2012	00-05, 10-19	500	0	500	262	238	
		05-10, 19-24	750*	0	750*	262	488*	
SR-ER	1st October 2012 to	00-17 23-24	800	0	800	197	603	
	31st October 2012	17-23	900		900		703	
	1st October 2012 to	00-17 23-24	550	35	515	161	354	
	5th October 2012	17-23	510	33	475	166	309	
ER-NER	6th October 2012	00-08 16-17 23- 24	550	35	515	161	354	Shutdown of 220 kV BTPS – Agia S/C
		08-16'	520		485	161	324	
	7th October 2012 to	17-23 00-17	510		475	166	309	
	31st October 2012	23-24 17-23	550 510	35	475	161 166	354	
	1st October 2012 to	00-17	550	46-	450		450	
	5th October 2012	23-24 17-23	340	100	240	0	240	
NER-ER	6th October 2012	00-08 16-17 23-		100	450	0	450	Shutdown of 220 kV BTPS – Agia S/C
NEK-EK	otti October 2012	24 08-16'	430	100	330	0	330	Shuldown of 220 kV B1F3 - Agia 5/C
		17-23 00-17	340		240		240	
	6th October 2012 to 31st October 2012	23-24	550	100	450	0	450	
		17-23	340		240		240	
S1-S2	1st October 2012 to 31st October 2012	00-24	5000	100	4900	3400	1500	
Import of Punjab	1st October 2012 to 31st October 2012	00-24	5400	300	5100	3243	1857	
Import TTC for DD&DNH	1st October 2012 to 31st October 2012	00-24	980	0	980	LTA and MTO scheo		
W3 zone export TTC#	1st October 2012 to 31st October 2012	00-24	7000	200	6800	6100	700	6100 MW corresponds to maximum effective LTA from W3. Export Margin from W3 would vary as per the maintenance schedule of generators in the zone.

¹⁾ ER-SR TTC declared at Talcher Interconnector and Gazuwaka HVDC B/B seam
2) ^S1 comprises of AP and Karnataka: S2 comprises of Tamil Nadu, Kerala and Pondicherry
3) W3 comprises of the following regional entities and would be operational wef 0000 hrs of 18th September 2012
a) Chattisgarh, b) Jindal Power Limited (JPL), c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak
f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat
* additional 250 MW can be transferred to SR if injection point is South Odisha

Limiting Constraints

Corridor	Constraint
NR-WR	(n-1) contingency of 400kV Bina(PG)-Bina(MP)
WR-NR	(n-1) contingency of 400kV Bina-Gwalior
NR-ER	(n-1) contingency of 400 kV Pusauli-Biharsharif
ER-NR	(n-1) contingency of 400 kV Kahalgaon-Biharsharif
WR-ER	(n-1) contingency of 400 kV Maithon-Kahalgaon* Highloading of 220kV Korba(E)-Raigarh
ER-WR	High loading of 400 kV Raipur-Bhadrawati T/C, Bhilai-Bhadrawati S/C, Bhilai-Koradi and Bhilai-Seoni (n-1) contingency of 400kV Rourkela-Jamshedpur
WR-SR	High loading of 400 kV Raipur-Bhadravati T/C and Bhilai-Bhadrawati S/C (n-1) contingency of 400 kV Vijaywada-Nellore*
SR-WR	(n-1) contingency of Chandrapur-Parli
ER-SR	(n-1) contingency of 400 kV Vijaywada-Nellore* (n-1) contingency of Rourkela-Talcher* Low Voltage in Chennai Area
SR-ER	(n-1) contingency of 400 kV Maithon-Kahalgaon* (n-1) contingency of 400 kV Kadappa-Kolar and Neyvelli- Sriperumbudur
ER-NER	(n-1) contingency of 400 kV Binaguri-Bongaigaon* High Loading of 220 kV BTPS-Agia High Loading of 220 kV Balipara-Samaguri (n-1) contingency of 400/220 kV 315 MVA ICT at Misa*
NER-ER	(n-1) contingency of 400 kV Purnea-Muzaffarpur* High loading of 132 kV LTPS – Mariani S/C*
S1-S2	(n-1) contingency of 400 kV Hosur-Salem

^{*}Primary constraints

Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Comments
ER								
		00-08						
		20-24	5700		5400	1158	4242	
	5th October 2012	08-19'	5100	300	4800		3642	
		19-20	5600		5300		4142	
NR#	6th October 2012 to	00-08 19-24	5700	300	5400	1158	4242	
	19th October 2012	08-19'	5200		4900		3742	
	20th October 2012 to 30th October 2012	00-24	5700	300	5400	1158	4242	
	1st October 2012 to 5th October 2012	00-17 23-24	550	35	515	161	354	
	October 2012	17-23	510		475	166	309	
NER	6th October 2012	00-08 16-17 23-24	550	35	515	161	354	Shutdown of
		08-16'	520		485	161	324	220 kV BTPS – Agia S/C
		17-23	510		475	166	309	
	7th October 2012 to 31st October 2012	00-17 23-24	550	35	515	161	354	
	518t October 2012	17-23	510		475	166	309	
WR								
	6th October 2012 to 10th October 2012	00-24	1185*	0	1185*	1177	8*	Outage of U#1 of Talcher Stage 1 due to tube leakage
	11th October 2012 to 17th October 2012	00-05, 10-19	1400	0	1400	1162	238	
SR#		05-10, 19-24	1400*		1400*	1102	238*	
	18th October 2012 to 30th October 2012	00-05, 10-19	1400	0	1400	1162	238	
		05-10, 19-24	1650*		1650*		488*	

^{*} additional 250 MW can be transferred to SR if injection point is South Odisha

Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Comments
ER								
NR	1st October 2012 to 30th October 2012	00-24	2300	500	1800	286	1514	
	1st October 2012 to 5th October 2012	00-17 23-24	550	100	450	0	450	
NER	6th October 2012	17-23 00-08 16-17 23-24 08-16'	550 430	100	240 450 330	0	240 450 330	Shutdown of 220 kV BTPS – Agia S/C
	6th October 2012 to 31st October 2012	17-23 00-17 23-24	340 550	100	240 450	0	240 450	
WR	31st October 2012	17-23	340		240		240	
SR	1st October 2012 to 30th October 2012	00-17 23-24 17-23	1800	0	1800	197	1603 1703	

Limiting Constraints

NR	Import	(n-1) contingency of 400 kV Purnea Muzaffarpur*
		(n-1) contingency of 400kV Bina-Gwalior
	Export	(n-1) contingency of 400 kV Kahalgaon-Maithon
NER	Import	High Loading of 220 kV BTPS-Agia
		High Loading of 220 kV Balipara-Samaguri
		(n-1) contingency of 400/220 kV 315 MVA ICT at Misa*
		(n-1) contingency of 400 kV Binaguri-Bongaigaon*
	Export	High loading of 132 kV LTPS – Mariani S/C*
		(n-1) contingency of 400 kV Purnea-Muzaffarpur*
SR	Import	High loading of 400 kV Raipur-Bhadravati T/C and Bhilai-Bhadrawati S/C
		(n-1) contingency of Rourkela-Talcher*
		Low Voltage in Chennai Area
		(n-1) contingency of 400 kV Vijaywada-Nellore*
	Export	(n-1) contingency of Chandrapur-Parli
		(n-1) contingency of 400 kV Maithon Kahalgaon
		(n-1) contingency of 400 kV Kadappa-Kolar and neyvelli- Sriperumbudur

ASSUMPTIONS IN BASECASE

		Loa	ad	Generation		
S.No.	Name of State/Area	Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)	
ı	NORTHERN REGION					
1	Punjab	7551	7100	3016	287	
2	Haryana	5901	5400	3293	329	
3	Rajasthan	6100	5900	3552	348	
4	Delhi	4565	4200	1396	139	
5	Uttar Pradesh	10050	10300	5166	483	
6	Jammu & Kashmir	1900	1802	560	60	
7	Uttarakhand	1600	1230	899	90	
8	Himachal Pradesh	1030	970	745	74	
9	Chandigarh	282	231	0		
10	ISGS			18226	1677	
	Total NR	38979	37133	36853	3491	
II	EASTERN REGION					
1	West Bengal	6250	4930	4617	394	
2	Jharkhand	900	700	390	39	
3	Orissa	3300	2400	2707	209	
4	Bihar	1650	1300	130	13	
5	Damodar Valley Corporation	2200	1900	1551	155	
6	Sikkim	60	60	0	150	
7	Bhutan	110	110	1400	140	
8	ISGS	110	110	6236	623	
	Total ER	14470	11400	17031	1574	
	TOTAL EX	14470	11700	17031	1374	
III	WESTERN REGION					
1	Chattisgarh	2608	1983	2147	171	
2	Madhya Pradesh	5223	4166	3238	273	
3	Maharashtra	15700	12000	12016	835	
4	Gujarat	9618	6440	11085	681	
5	Goa	300	197			
6	Daman and Diu	225	177			
7	Dadra and Nagar Haveli	439	477			
8	ISGS	400	7//	11971	1059	
	Total WR	34112	25439	40457	3021	
	Total Wit	34112	25455	40437	3023	
IV	SOUTHERN REGION					
1	Andhra Pradesh	10715	0050	7720	F07	
2	Tamil Nadu	10715	9050	7729 4423	597	
3	Karnataka	10100	8700 5700		343	
4	Kerala	7200	5700	4701	330	
5	Pondy	2950	2300	1343	89	
6	Goa	325	250	0		
	ISGS	80	80	0		
7	Total SR	31370	26000	9700	880	
	Total SK	31370	26080	27896	2241	
	NORTH-EASTERN REGION					
V		4.5				
V	Maninur		92	0		
1	Manipur	115	l		7	
1	Meghalaya	258	180	120		
1 2 3	Meghalaya Mizoram	258 70	40	0		
1 2 3 4	Meghalaya Mizoram Nagaland	258 70 70	40 60	0 15		
1 2 3 4 5	Meghalaya Mizoram Nagaland Assam	258 70	40	0 15 240	,	
1 2 3 4 5 6	Meghalaya Mizoram Nagaland Assam Tripura	258 70 70	40 60	0 15	22	
1 2 3 4 5 6 7	Meghalaya Mizoram Nagaland Assam Tripura Arunachal Pradesh	258 70 70 950	40 60 824	0 15 240	22	
1 2 3 4 5 6	Meghalaya Mizoram Nagaland Assam Tripura Arunachal Pradesh	258 70 70 950 180 124	40 60 824 100 83	0 15 240 105 0 1292	22 10	
1 2 3 4 5 6 7	Meghalaya Mizoram Nagaland Assam Tripura Arunachal Pradesh	258 70 70 950 180	40 60 824 100	0 15 240 105	22 10 68 108	