

National Load Despatch Centre
Import of Arunachal Pradesh Transfer Capability for August 2021

Issue Date: 26th July 2021

Issue Time: 2100 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Aug 2021 to 31st Aug 2021	00 - 18	1582	40	1542	271	1271	-	
	18- 22	1500	40	1460	271	1189	-	
	22 - 24	1582	40	1542	271	1271	-	
Limiting Constraints	N-1 of 220/132 kV,160 MVA ICT at BTPS and Limiting constraint observed at 220/132 kV ,100 MVA ICT at BTPS							