National Load Despatch Centre Total Transfer Capability for April 2015

Issue Date: 28/12/2014 Issue Time: 1800 hrs Revision No. 0

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR-WR *	1st April 2015 to 30th April 2015	00-24	2500	500	2000	1055	945		
WR-NR	1st April 2015 to 30th April 2015	00-17 23-24 17-23	4900 4900	500	4400 4400	4767	0		
		1, 20	., 00		1.00		Ů		
NR-ER*	1st April 2015 to 30th April 2015	00-06 06-18' 18-24	2000 2000 2000	200	1800 1800 1800	293 358 293	1507 1442 1507		
ER-NR	1st April 2015 to 30th April 2015	00-17 23-24 17-23	3000 3000	300	2700 2700	2431	269 269		
W3-ER ^{\$}	1st April 2015 to 30th April 2015	00-24	1800	300	1500	697	803		
ER-W3	1st April 2015 to 30th April 2015	00-24	1000	300	700	973	0		
WR-SR	1st April 2015 to 30th April 2015	00-24	2100	750	1350	1350	0		
SR-WR*	1st April 2015 to 30th April 2015	00-24				No limit i	s being Specified.		
ER-SR	1st April 2015 to 30th April 2015	00-06 18-24 06-18'	2650	0	2650	2585 2650	65 0		
SR-ER *	1st April 2015 to 30th April 2015	00-24							
		00.15							
ER-NER	1st April 2015 to 30th April 2015	00-17 23-24 17-23	670 670	40	630 630	210	420 420		
NER-ER	1st April 2015 to 30th April 2015	00-17 23-24	545	30	515	0	515		
	50th 11pm 2015	17-23	450	40	410		410		
S1-S2	1st April 2015 to 30th April 2015	00-24	3070	300	2770	2775	0		
Import of Punjab	1st April 2015 to 30th April 2015	00-24	5700	300	5400	3790	1610		
Import TTC for DD & DNH	1st April 2015 to 30th April 2015	00-24	1200	0	1200		OA as per ex-pp edule		
W3 zone Injection	1st April 2015 to 30th April 2015	00-17 23-24 17-23	9400 9900	200	9200 9700	6862	2338		

^{*}Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

National Load Despatch Centre Total Transfer Capability for April 2015

Issue Date: 28/12/2014 Issue Time: 1800 hrs Revision No. 0

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
----------	------	-------------------------	--	-----------------------	--	--	--	---	----------

^{\$} As per Simulations, predominant direction of flow is on West to North Corridor. Hence, in case injection point is in Western Region (W1,W2,W3), STOA/PX transactions from West to North on West-East-North corridor shall not be allowed as such transaction increases congestion in the West to North Corridor.

- 1) ER-SR TTC declared at Talcher Interconnector and Gazuwaka HVDC B/B seam
- 2) S1 comprises of AP and Karnataka: S2 comprises of Tamil Nadu, Kerala and Pondicherry
- 3) W3 comprises of the following regional entities:
- a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak
- f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCL, n)Vandana Vidyut

In case of TTC Revision due to any shutdown :

- 1) The TTC value will be revised to normal values after restoration of shutdown.
- 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

Limiting Constraints

Corridor	Constraint
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.
WR-NR	High Loading of 400kV Singrauli-Anpara & High loading of 765 kV Agra-Gwalior (1250 MW SPS setting on each circuit of 765 kV Gwalior-Agra) and Loop flows on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda (power flowing from WR to NR on 765kV Gwalior-Agra D/C and from NR to WR on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda).
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli
ER-NR	(n-1) contingnecy of Kahalgaon-Banka S/C
W3-ER	i. (n-1) Contingency of 400 kV MPL-Maithon S/C ii. (n-1) contingency of 400kV Sterlite-Rourkela S/C
ER-W3	(n-1) contingency of 400kV Raigarh-Jharsuguda-Rourkela
WR-SR & ER-SR	1. (n-1) contingency of one circuit of 400kV Parli(PG)-Sholapur(PG) 2. ER-SR TTC has been declared assuming more than 1100 MW generation at Talcher Stage-2. In case Talcher Stage-2 generation goes below 1100 MW, then the ER-SR TTC would be revised downward as constraints within ER would emerge.
ER-NER	(n-1) contingnecy of Kahalgaon-Banka S/C
NER-ER	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA ICT at Misa
S1-S2	(n-1) contingency of one circuit of 400 kV Kolar-Hosur D/C
Import of DD & DNH	(n-1) contingency of 400/220KV 315MVA ICT at VAPI
Import of Punjab	(n-1) contingency of ICT at Dhuri and (n-1) contingnecy of 220kV Moga(PG)-Moga(PSTCL)
W3 zone Injection	(n-1-1) contingency of 400 kV Raipur-Bhadrawati D/C section and High loading of 400kV Raipur-Wardha (850 MW SPS setting on each circuit of 400kV Raipur-Wardha)

^{*}Primary constraints

[#] The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/Fuel shortage/New units being commissionned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER									
NR	1st April 2015 to 30th April 2015	00-17 23-24 17-23	7900 7900	800	7100 7100	7198	0		
NER	1st April 2015 to 30th April 2015	00-17 23-24 17-23	670 670	40	630 630	210	420 420		
WR									
SR	1st April 2015 to 30th April 2015	00-06 18-24 06-18'	4750 4750	750	4000	3935 4000	65 0		

Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments		
	1st April 2015 to 30th April 2015	00-06	4500	700	3800	1348	2452				
NR*		06-17'			3800	1413	2387				
		23-24	4500		3800	1348	2452				
	1st April 2015 to 30th April 2015	00-17	545	30	515		515				
NER		23-24	343		313	0	313				
		17-23	450	40	410		410				
WR											
W											
SR *	1st April 2015 to 30th April 2015	00-24		No limit is being Specified.							

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Limiting Constraints

21111111111	constraints	
		(n-1) contingnecy of Kahalgaon-Banka S/C
	T	High loading of 765 kV Agra-Gwalior (1250 MW SPS setting on each circuit of 765 kV Gwalior-Agra) and high loop
NR	Import	flows on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda (power flowing from WR to NR on 765kV Gwalior-Agra
1414		D/C and from NR to WR on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda).
	Evmont	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.
	Export	(n-1) contingency of 400 kV Saranath-Pusauli
NER	Import	(n-1) contingnecy of Kahalgaon-Banka S/C
NEK	Export	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other ICT at Misa
		1. (n-1) contingency of one circuit of 400kV Parli(PG)-Sholapur(PG)
SR	T	2. ER-SR TTC has been declared assuming more than 1100 MW generation at Talcher Stage-2. In case Talcher Stage-
SK	Import	2 generation goes below 1100 MW, then the ER-SR TTC would be revised downward as constraints within ER would
		emerge.

^{*}Primary constraints

National Load Despatch Centre Total Transfer Capability for April 2015

Revision	Date of	Period of	Daggar for Davision	Corridor
No	Revision	Revision	Reason for Revision	Affected