

**National Load Despatch Centre
Total Transfer Capability for August 2014**

Issue Date: 19/08/2014

Issue Time: 1300 hrs

Revision No. 18

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments					
NR-WR *	1st August 2014 to 31st August 2014	00-24	2500	500	2000	651	1349							
WR-NR	1st August 2014	00-17 23-24	4900	500	4400	4380	20							
		17-23	4900		4400		20							
	2nd August 2014	00-1215	4900	500	4400	4380	20							
		1215-24	3950		3450		0							
	3rd August 2014 to 31st August 2014	00-17 23-24	4900	500	4400	4380	20							
		17-23	4900		4400		20							
NR-ER*	1st August 2014 to 7th August 2014	00-06	1000	200	800	293	507							
		06-17'			800	338	462							
		17-18'	1100		900	338	562							
		18-23			900	293	607							
		23-24	1000		800	293	507							
	8th August 2014 to 31st August 2014	00-06	1000	200	800	293	507							
		06-17'			800	358	442							
		17-18'	1100		900	358	542							
		18-23			900	293	607							
		23-24	1000		800	293	507							
		ER-NR	1st August 2014 to 31st August 2014		00-17	3400	300			3100	2431	669		
					23-24							669		
17-23	669													
W3-ER^s	1st August 2014 to 31st August 2014	00-24	1700	300	1400	697	703							
ER-W3	1st August 2014 to 31st August 2014	00-24	1000	300	700	874	0							
WR-SR	1st August 2014 to 8th August 2014	00-24	2100	750	1350	1350	0							
	9th August 2014 to 10th August 2014	00-09	2100	750	1350	1350	0							
		09-24'	1700		950	950	0							
	11th August 2014 to 17th August 2014	00-24	2100	750	1350	1350	0							
	18th August 2014	00-18:15	2100	750	1350	1350	0							
		18:15-24	1750	750	1000	1000	0							
	19th August 2014	00-24	2100	750	1350	1350	0							
	20th August 2014 to 23rd August 2014	00-08	2100	750	1350	1350	0		Revised due to shutdown of Bhadrawati HVDC Pole-1 on 20th, 21st and Pole-2 on 22nd, 23rd.					
08-24'		1600	850		850	0	-500							
24th August 2014 to 31st August 2014	00-24	2100	750	1350	1350	0								
SR-WR *	1st August 2014 to 31st August 2014	00-24	No limit is being Specified.											
ER-SR	1st August 2014 to 7th August 2014	00-06	2650	0	2650	2069	581							
		18-24				2114	536							
		06-18'				2114	536							
	8th August 2014	00-06	2650	0	2650	2089	561							
		18-24				2134	516							
	9th August 2014 to 10th August 2014	00-06	2650	0	2650	2585	65							
		06-09'				2577	73							
		09-18'				2650	0							
		18-24				2650	0							
	11th August 2014 to 17th August 2014	00-06	2650	0	2650	2512	138							
		18-24				2577	73							
			06-18'											

National Load Despatch Centre
Total Transfer Capability for August 2014

Issue Date: 19/08/2014

Issue Time: 1300 hrs

Revision No. 18

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER-SR	18th August 2014	00-06	2650	0	2650	2512	138		Revised due to shutdown of Bhadrawati HVDC Pole-1 on 20th, 21st and Pole-2 on 22nd, 23rd.
		18-18:15				2650	0		
		18:15-24				2577	73		
	19th August 2014	00-06	2650	0	2650	2512	138		
		18-24				2577	73		
		06-18'				2585	65		
	20th August 2014 to 23rd August 2014	00-06	2650	0	2650	2577	73		
		06-08'				2577	73		
		08-18'				2650	0		
		18-24				2650	0		
	24th August 2014 to 31st August 2014	00-06	2650	0	2650	2512	138		
		18-24				2577	73		
SR-ER *	1st August 2014 to 31st August 2014	00-24	No limit is being Specified.						
ER-NER	1st August 2014 to 6th August 2014	00-17	645	50	595	205	390		
		23-24						600	550
	7th August 2014	00-07	645	50	420	370	205	390	
		07-17'	420					370	165
		17-23	420					370	165
		23'-24	420					370	165
	8th August 2014	00-17	420	50	370	205	165		
		17-23	420					370	165
		23 -24	420					370	165
	9th August 2014	00-17	420	50	370	205	165		
		17-23'	600					550	345
		23-24	645					595	390
	10th August 2014 to 18th August 2014	00-17	645	50	595	205	390		
		23-24						600	550
	19th August 2014	00-08	645	50	595	205	390		
		08'-09	400	50	350	205	145		
		09'-15	645	50	595	205	390		
		15-16	400	50	350	205	145		
		16-17	645	50	595	205	390		
		17-23	600	50	550	205	345		
	20th August 2014 to 31st August 2014	00-17	645	50	595	205	390		
		23-24						600	550
	NER-ER	1st August 2014 to 6th August 2014	00-17	500	100	400	0	400	
			17-23						490
7th August 2014		00-07	500	100	270	170	0	400	
		07'-17	240					170	140
		17-23	240					170	170
		23-24	270					170	170
8th August 2014		00-17	270	100	140	0	140		
		17-23	240					170	170
		23-24	270					170	170
9th August 2014		00-17	270	100	170	0	170		
		17'-23	490					390	390
10th August 2014 to 18th August 2014		00-17	500	100	400	0	400		
	23-24	490						390	390

**National Load Despatch Centre
Total Transfer Capability for August 2014**

Issue Date: 19/08/2014

Issue Time: 1300 hrs

Revision No. 18

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NER-ER	19th August 2014	00-08	500	100	400	0	400		
		08-09	320	100	220	0	220		
		09-15	500	100	400	0	400		
		15-16	320	100	220	0	220		
		16-17	500	100	400	0	400		
	19th August 2014	17-23	490	100	390	0	390		
		23-24	500	100	400	0	400		
20th August 2014 to 31st August 2014	00-17	500	100	400	0	400			
	17-23	490		390		390			
S1-S2	1st August 2014	00-24	2415	295	2120	2525	0		
	2nd August 2014	00-13	2415	295	2120	2525	0		
		13-24	2700		2405		0		
	3rd August 2014	00-24	2700	295	2405	2525	0		
	4th August 2014	00-24	2700	295	2405	2614	0		
	5th August 2014	00-12	3030	295	2735	2527	208		
		12-24	2750		2455	2527	0		
	6th August 2014 to 8th August 2014	00-24	2750	295	2455	2527	0		
	9th August 2014	00-17	1965	295	1670	2761	0		
		17-24	2750	295	2455	2761	0		
		2030-24	2415	295	2120	2761	0		
	10th August 2014	00-530	2415	295	2120	2761	0		
		530-18	2415		2120				
		18-23	2415		2120				
		23-24	2750		2455				
	11th August 2014	00-24	2750	295	2455	2761	0		
	12th August 2014 to 14th August 2014	00-24	2750	295	2455	2761	0		
	15th August 2014	00-24	3000	295	2705	2848	0		
	16th August 2014	00-21	3000	295	2705	2848	0		
		21-24	3250	295	2955	2848	107		
	17th August 2014	00-06	3250	295	2955	2848	107		
		06-18	2500		2205	2848	0		
		18-24	3250		2955	2848	107		
18th August 2014	00-12	3250	295	2955	2848	107			
	12-24	3000	295	2705	2848	0			
19th August 2014 to 22nd August 2014	00-24	3000	295	2705	2848	0			
23rd August 2014 to 24th August 2014	00-24	2970	295	2675	2837	0			
25th August 2014 to 31st August 2014	00-24	2970	295	2675	3048	0			
Import of Punjab	1st August 2014 to 31st August 2014	00-24	5700	300	5400	3790	1610		
Import TTC for DD & DNH	1st August 2014 to 31st August 2014	00-24	1200	0	1200	LTA and MTOA as per ex-pp schedule			
W3 zone Injection	1st August 2014 to 7th August 2014	00-17 23-24	9000	200	8800	7250	1550		
		17-24	9500		9300		2050		
	8th August 2014 to 31st August 2014	00-17 23-17	9000	200	8800	6843	1957		
		17-23	9500		9300		2457		

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

**National Load Despatch Centre
Total Transfer Capability for August 2014**

Issue Date: 19/08/2014

Issue Time: 1300 hrs

Revision No. 18

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
----------	------	-------------------	---------------------------------	--------------------	-------------------------------------	----------------------------------------------------------	----------------------------------------------------	-------------------------------------	----------

\$ As per Simulations, predominant direction of flow is on West to North Corridor. Hence, in case injection point is in Western Region (W1,W2,W3), STOA/PX transactions from West to North on West-East-North corridor shall not be allowed as such transaction increases congestion in the West to North Corridor.

1) S1 comprises of AP and Karnataka; S2 comprises of Tamil Nadu, Kerala and Pondicherry

2) W3 comprises of the following regional entities :

- a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak
f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCCL, n)Vandana Vidyut

The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown :

- 1) The TTC value will be revised to normal values after restoration of shutdown.
2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

Limiting Constraints

Corridor	Constraint
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.
WR-NR	High loading of 765 kV Agra-Gwalior (1250 MW SPS setting on each circuit of 765 kV Gwalior-Agra) and Loop flows on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda (power flowing from WR to NR on 765kV
NR-ER	(n-1) contingency of 400 kV Allahabad-Pusauli
ER-NR	High loading of 765 kV Agra-Gwalior (1250 MW SPS setting on each circuit of 765 kV Gwalior-Agra) due to
W3-ER	(n-1) contingency of 400kV Sterlite-Rourkela S/C
ER-W3	(n-1) contingency of 400kV Raigarh-Jharsuguda-Rourkela
WR-SR & ER-SR	1. (n-1) contingency of 400kV Parli(PG)-Sholapur(PG) D/C 2. ER-SR TTC has been declared assuming more than 1100 MW generation at Talcher Stage-2. In case
ER-NER	(n-1) contingency of 400 kV Balipara – Bongaigaon D/C leading to thermal loading of 220kV BTPS-Agia S/C
NER-ER	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa
S1-S2	(n-1) contingency of 400 kV Kolar-Hosur D/C
Import of DD & DNH	(n-1) contingency of 400/220kV 315MVA ICT at VAPI
Import of Punjab	(n-1) contingency of ICT at Dhuri and (n-1) contingency of 220kV Moga(PG)-Moga(PSTCL)
W3 zone Injection	(n-1-1) contingency of 400 kV Raipur-Bhadrawati D/C section and High loading of 400kV Raipur-Wardha (800 MW SPS setting on each circuit of 400kV Raipur-Wardha)

*Primary constraints

Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
ER										
NR	1st August 2014	00-17	8300	800	7500	6811	689			
		23-24	8300		7500		689			
	2nd August 2014	00-17	8300	800	7500	6811	689			
		23-24	8300		6550		0			
	3rd August 2014 to 31st August 2014	00-17	8300	800	7500	6811	689			
		23-24	8300		7500		689			
NER	1st August 2014 to 6th August 2014	00-17	645	50	595	205	390			
		23-24	645		595		390			
	7th August 2014	00-07	420	50	370	205	165			
		07-17'	420		370		165			
		17-23	420		370		165			
		23'-24	420		370		165			
	8th August 2014	00-17	420	50	370	205	165			
		17-23	420		370		165			
		23 -24	420		370		165			
	9th August 2014	00-17	420	50	370	205	165			
		17-23'	600		550		345			
		23'-24	645		595		390			
	10th August 2014 to 18th August 2014	00-17	645	50	595	205	390			
		23-24	600		550		345			
	19th August 2014	00-08	400	50	350	205	145			
		08'-09	400	50	350		145			
		09'-15	400	50	350		145			
		15-16	400	50	350		145			
		16-17	645	50	595		390			
		17-23	600	50	550		345			
	20th August 2014 to 31st August 2014	00-17	645	50	595	205	390			
		23-24	600		550		345			
WR										
SR	1st August 2014 to 7th August 2014	00-06	4750	750	4000	3419	581			
		18-24	4750		4000		536			
	8th August 2014	00-06	4750	750	4000	3419	581			
		18-24	4750		4000		516			
	9th August 2014 to 10th August 2014	00-06	4750	750	4000	3862	138			
		06-09'	4750		4000		73			
		09-18'	4350		3600		3927			0
		18-24	4350		3600		3927			0
	11th August 2014 to 17th August 2014	00-06	4750	750	4000	3862	138			
		18-24	4750		4000		73			
	18th August 2014	00-06	4750	750	4000	3862	138			
		18-18:15	4400		3650		3650			0
		18:15-24	4400		4000		3927			73
	19th August 2014	00-06	4750	750	4000	3862	138			
		18-24	4750		4000		3927			73
	20th August 2014 to 23rd August 2014	00-06	4750	750	4000	3862	138			
		06-18'	4750		4000		3927			73
		00-06	4750		4000		3862			138
06-08'		4750	4000		3927		73			
24th August 2014 to 31st August 2014	08-18'	4250	750	3500	3927	0	-500	Revised due to shutdown of Bhadrawati HVDC Pole-1 on 20th, 21st and Pole-2 on 22nd, 23rd.		
	18-24	4250		3500		3927			0	
	00-06	4750		4000		3862			138	
	18-24	4750	750	4000	3927	73				

Simultaneous Export Capability

Corridor	Date	Time Period	Total Transfer	Renewable Margin	Available Transfer	Long Term Access (LTA) / TTA	Margin Available	Changes in TTC	Comments	
NR*	1st August 2014 to 7th August 2014	00-06	3500	700	2800	590	2210			
		06-17'			2800	635	2165			
		17-18'	3600		2900	635	2265			
		18-23			2900	590	2310			
		23-24	3500		2800	590	2210			
		8th August 2014 to 31st August 2014	00-06		3500	700	2800	944	1856	
	06-17'		2800	1009			1791			
	17-18'		3600	2900	1009		1891			
	18-23			2900	944		1956			
	23-24		3500	2800	944		1856			
	NER		1st August 2014 to 6th August 2014	00-17	500		100	400	0	400
		17-23		490	390	390				
7th August 2014		00-07	500	100	400	0	400			
		07-17	270		170		170			
		17-23	240		140		140			
		23-24	270		170		170			
8th August 2014		00-17	270	100	170	0	170			
		17-23	240		140		140			
		23-24	270		170		170			
9th August 2014		00-17	270	100	170	0	170			
		17-23	490		390		390			
10th August 2014 to 18th August 2014		23-24	500	100	400	0	400			
		00-17	500		400		390	390		
19th August 2014		00-08	500	100	400	0	400			
		08-09	320	100	220		220			
		09-15	500	100	400		400			
		15-16	320	100	220		220			
		16-17	500	100	400		400			
		17-23	490	100	390		390			
20th August 2014 to 31st August 2014		00-17	500	100	400	0	400			
		17-23			490		390	390		
WR										
SR *		1st August 2014 to 31st August 2014	00-24	No limit is being Specified.						

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Limiting Constraints

NR	Import	High loading of 765 kV Agra-Gwalior (1250 MW SPS setting on each circuit of 765 kV Gwalior-Agra) due to transit High loading of 765 kV Agra-Gwalior (1250 MW SPS setting on each circuit of 765 kV Gwalior-Agra) and high loop
	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak. (n-1) contingency of 400 kV Allahabad-Pusauli
NER	Import	(n-1) contingency of 400 kV Balipara – Bongaigaon D/C leading to thermal loading of 220kV BTPS-Agia S/C
	Export	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa
SR	Import	1. (n-1) contingency of 400kV Parli(PG)-Sholapur(PG) D/C
		2. ER-SR TTC has been declared assuming more than 1100 MW generation at Talcher Stage-2. In case Talcher Stage-

National Load Despatch Centre
Total Transfer Capability for August 2014

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor Affected
1	26-05-2014	Whole Month	Refer to explanatory notes regarding the change in TTC representation given in the last page.	ER-SR/ S1-S2
			Re-Routing of transactions on West-East-North Corridor discontinued on account of Inter-Regional Loop flows leading to physical congestion on WR-NR	W3-ER
2	13-06-2014	Whole Month	Revised due to change in Load Generation Balance and Commissioning of Sasan Unit-1.	WR-NR
3	26-07-2014	Whole Month	Revised due to commissioning of contingency arrangement of one 500 MW Vindhyachal (Unit-12) with 400kV Vindhyachal-Rihand line.	WR-NR
			Revised due to change in Load generation Balance and Transit flows on ER-WR-NR.	ER-NR
			Revised due to commissioning of 765kV Sholapur-Raichur Circuit-2 and 765kV Wardha-Aurangabad D/C.	WR-SR
			Revised considering (a) 800MW generation at Vallur (b) 2nd Unit at NCTPS.	S1-S2
			Revised due to commissioning of 400/220KV 2X315MVA ICT at Kala S/S along with 220kV Kala-Sayali and 220KV Kala-Khadoli lines	Import of DD & DNH
			Revised due to change in Load-Generation balance and major network change due to commissioning of 400/220 kV Azara (Kukurmara) substation.	ER-NER
			Revised due to augmentation/ modifications in Punjab control area network.	Import of Punjab
4	30-07-2014	Whole Month	Revised based on further simulation. The LTA/MTOA figures are based on allocations, Talcher-II planned outage and the meetings on TTC/ATC taken by CTU on 24th and 30th Jul 2014. Any margins on account of less LTA/MTOA would be offered on day ahead basis.	WR-SR/ ER-SR
			STOA Margin revised due change in LTA/ MTOA/ Allocation.	ER-SR/ S1-S2
5	02-08-2014	02-08-2014	Revised due to Emergency shutdown of Rihand-Dadri Pole-2	WR-NR
		02/08/14 - 03/08/14	Revised due to tripping of NCTPS Unit-1	S1-S2
6	03-08-2014	04/08/14 - 05/08/14	Revised due to extended outage of NCTPS Unit-1	S1-S2
7	04-08-2014	05/08/14 - 31/08/14	Revised considering 400kV Tiruvalam-Kalivendapattu D/C and 400kV Kalivendapattu-Pugalur circuit-1	S1-S2
8	06-08-2014	07/08/14 - 09/08/14	Revised due to shutdown of 400 kV Balipara - Bongaigaon ckt 1	ER - NER/ NER -ER
9	07-08-2014	08/08/14- 31/08/14	STOA Margin revised due to correction in LTA/MTOA figures.	NR-ER/ ER-SR/ W3 Zone Injeccion
10	08-08-2014	09/08/2014 -	Revised due to shutdown of 400 kV Kolar - Hosur D/C line on daily basis on account of stringing works of 765 kV Dharmapuri- Madhugiri	S1-S2
		10/08/2014	Revised due to shutdown of 400 kV Ramagundam-Bhadravati ckt-2	WR-SR

**National Load Despatch Centre
Total Transfer Capability for August 2014**

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor Affected
11	09-08-2014	09/08/14-10/08/14	Revised due to tripping of 400kV Kalivindapattu - Pugalur - 1 and cancellation of 400kV Kolar-Hosur D/C shutdown.	S1-S2
12	10-08-2014	11-08-2014	Revised due to expected revival of 400kV Kalivindapattu - Pugalur ckt-1	S1-S2
13	10-08-2014	10-08-2014 - 11/08/2014	Revised due to restoration of 400kV Kalivindapattu - Pugalur ckt-1	S1-S2
14	15-08-2014	17-08-2014	Revised due to shutdown of 400 kV Kolar - Hosur D/C line on account of stringing works of 765 kV Dharmapuri-Madhugiri	S1-S2
15	16-08-2014	16/08/14 - 18/08/14	Revised due to NCTPS-II Unit-1 Outage due to Boiler Tube leakage	S1-S2
16	18-08-2014	19-08-2014	Revised due to the shutdown of 400 kV Balipara - Bongaigaon-II.	ER-NER NER-ER
17	18-08-2014	18-08-2014	Revised due to the breakdown of 400 kV Sholapur(MSEB)-parli(MSEB) S/C	WR - SR
18	19-08-2014	20/08/2014 - 23/08/2014	Revised due to shutdown of Bhadrawati HVDC Pole-1 on 20th, 21st and Pole-2 on 22nd, 23rd.	WR - SR

ASSUMPTIONS IN BASECASE

Month : Aug '14

S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
I	NORTHERN REGION				
1	Punjab	8684	8580	2899	2882
2	Haryana	7640	7545	3372	3372
3	Rajasthan	7336	7246	5231	5267
4	Delhi	4819	4516	1296	1296
5	Uttar Pradesh	11500	11688	6015	5961
6	Jammu & Kashmir	2082	1961	576	568
7	Uttarakhand	1696	1577	887	834
8	Himachal Pradesh	1449	1431	849	830
9	Chandigarh	283	201	0	0
10	ISGS/IPPs			19407	18615
	Total NR	45489	44745	40532	39625
II	EASTERN REGION				
1	West Bengal	6713	5052	4765	3347
2	Jharkhand	1059	753	365	365
3	Orissa	3700	3261	3049	2512
4	Bihar	2167	1706	80	80
5	Damodar Valley Corporation	2325	2308	3524	3029
6	Sikkim	85	50	0	0
7	Bhutan	108	108	1425	1425
8	ISGS/IPPs	300	300	9298	9070
	Total ER	16457	13538	22506	19828
III	WESTERN REGION				
1	Chattisgarh	2767	2215	1732	1326
2	Madhya Pradesh	6327	4793	4795	3686
3	Maharashtra	16000	12658	10208	6620
4	Gujarat	12030	9845	9648	7181
5	Goa	432	310		
6	Daman and Diu	284	191		
7	Dadra and Nagar Haveli	681	632		
8	ISGS/IPPs	1255	1255	18016	17237
	Total WR	39776	31899	44399	36050

ASSUMPTIONS IN BASECASE

Month : Aug '14

S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
IV	SOUTHERN REGION				
1	Andhra Pradesh	10892	9690	8223	6905
2	Tamil Nadu	11102	9769	7303	5712
3	Karnataka	7629	6617	7055	5681
4	Kerala	2963	2328	1651	1094
5	Pondy	310	274	0	0
6	Goa	80	80	0	0
7	ISGS/IPPs			8979	8978
	Total SR	32976	28758	33211	28370
V	NORTH-EASTERN REGION				
1	Arunachal Pradesh	95	63		
2	Assam	1083	829	250	220
3	Manipur	110	77		
4	Meghalaya	260	182	210	120
5	Mizoram	75	52	12	4
6	Nagaland	100	77	24	18
7	Tripura	250	125	110	110
8	ISGS/IPPs			1310	966
	Total NER	1973	1405	1916	1438
	Total All India	136671	120345	142564	125311