National Load Despatch Centre Total Transfer Capability for August 2020

Issue Date: 28th June 2020

Issue Time: 1800 hrs

Revision No. 2 Long Term Margin Changes Total Available Time Access (LTA)/ Available for in TTC Transfer Reliability Transfer Corridor Date Period Medium Term Short Term w.r.t. Comments Capability Capability Margin (hrs) **Open Access Open Access** Last (TTC) (ATC) (MTOA) # (STOA) Revision 00-06 195 1805 1st August 2020 NR-WR* to 31st August 06-18 2500 500 2000 1223 777 2020 18-24 195 1805 10268 17200 16700 00-06 500 6432 16250** 15750** 9318** Revision in STOA margin due to 1st August 2020 17200 16700 10657 change in LTA quantum from WR-NR* to 31st August 06-18 500 6043 GIWEL_SECI-III_RE (Wind, Bhuj) to Punjab from 151.2 MW to 200 2020 9707** 16250** 15750** MW 17200 16700 10268 18-24 500 6432 16250** 15750** 9318** 1st August 2020 00-06 2000 1800 193 1607 to 31st August NR-ER* 06-18 2000 200 1800 303 1497 2020 18-24 2000 1800 1607 193 1st August 2020 Revision in STOA margin due to ER-NR* to 31st August 00-24 5250 300 4950 4066 884 allocation of 20.75 MW power from 2020 Kameng HEP to UP and Haryana 1st August 2020 W3-ER to 31st August 00-24 No limit is being specified. 2020 1st August 2020 ER-W3 to 31st August 00-24 No limit is being specified. 2020 1st August 2020 00-05 6950 6450 2415 500 4035 WR-SR[^] to 31st August 05-22 6950 6450 2415 2020 22-24 6950 6450 2415 1st August 2020 SR-WR * 400 to 31st August 00-24 4600 4200 550 3650 2020 00-06 2663 3037 1st August 2020 to 31st August 5950 250 5700 ER-SR[△] 06-18 2748 2952 2020 18-24 2663 3037 1st August 2020 No limit is being Specified. SR-ER * to 31st August 00-24 2020 00-02 1020 975 289 686 02-07 1020 975 289 686 1st August 2020 07-12 1080 1035 334 701 **ER-NER*** to 31st August 45 12-17 1060 1015 334 681 2020 17-23 1000 955 289 666 23-24 1020 975 289 686 2355 00-02 2400 21 2334 2355 2334 02-07 2400 21 Revision in STOA margin of due 1st August 2020 2405 allocation of 20.75 MW power from 07-12 2450 21 2384 NER-ER* to 31st August 45 2341 2296 2275 Kameng HEP to UP, Haryana, 12-17 21 2020 Chhattisgarh and Goa 17-23 2621 2576 21 2555 23-24 2400 2355 21 2334

National Load Despatch Centre Total Transfer Capability for August 2020

Issue Date: 28th June 2020 Issue Time: 1800 hrs Revision No. 2 Long Term Margin Changes Total Available Time Access (LTA)/ Available for in TTC Transfer Reliability Transfer Corridor Date Period Medium Term Short Term w.r.t. Comments Capability Capability Margin (hrs) **Open Access Open Access** Last (TTC) (ATC) (STOA) (MTOA) # Revision 1st August 2020 W3 zone to 31st August 00-24 No limit is being specified (In case of any constraints appearing in the system, W3 zone export would be revised accordingly) Injection 2020 Note: TTC/ATC of S1-(S2&S3) corridor, Import of S3(Kerala), Import of Punjab and Import of DD & DNH is uploaded on NLDC website under Intra-Regional Section in Monthly ATC. * Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve). **Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity. 1) S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala 2) W3 comprises of the following regional entities : a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCL, n)Vandana Vidyut o)RKM, p)GMR Raikheda, q)Ind Barath and any other regional entity generator in Chhattisgarh # The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissionned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC. In case of TTC Revision due to any shutdown : 1) The TTC value will be revised to normal values after restoration of shutdown. 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time. Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section ^Though 2X315 MVA, 400/220 kV ICTs at Maradam are N-1 non-compliant, the TTC of WR-SR and ER-SR corridor has not been restricted due to the same considering that this aspect will be managed by AP SLDC through appropriate measures like SPS implementation. ^In case of drawl of Karnataka beyond 3800 MW, the voltages in Bengaluru area are observed to be critically low. This issue may be taken care of by Karnataka SLDC by taking appropiate measures.

SR-WR TTC/ATC figures have been calculated considering 01 unit (800 MW) at Kudgi TPS in service. The figures are subject to change with change in generation at Kudgi TPS.

WR-NR/Import of NR TTC has been calculated considering generation at Pariccha TPS as 350 MW. TTC figures are subject to change with significant change in generation at Pariccha TPS.

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
		00-06	22450	-	21650	14334	7316		
	1st August 2020 to 31st August 2020		21500**		20700**	13384**			a) Revision in STOA margin due
		06-09	22450		21650	14723	6927		to change in LTA quantum from GIWEL_SECI-III_RE (Wind,
			21500**	800	20700**	13773**	6927		Bhuj) to Punjab from 151.2 MW
NR [*]			22450		21650	14723			to 200 MW
INIK		09-17	21500**		20700**	13773**			
			21300**		21650	14723			b) Revision in STOA margin
		17-18	21500**		20700**	13773**	6927		due to allocation of 20.75 MW power from Kameng HEP to UP
			22450		21650	14334		and	and Haryana
		18-24	21500**		20700**	13384**	7316		
		00-02	1020		975	289	686		
	1st August 2020	02-07	1020		975	289	686		
NER [*]	to 31st August	07-12	1080	45	1035	334	701		
INEK	2020	12-17	1060	45	1015	334	681		
	2020	17-23	1000		955	289	666		
		23-24	1020		975	289	686		
WR [*]									
	1 st. A very st 2020	00-06	12000		12150	6698	5452		
SD ^{*#}	1st August 2020 to 31st August	00-06	12900 12900	750	12150	6698	5452 5367		
SR ^{*#}	2020	18-24	12900	750	12150	6698	5452		

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

**Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.

* For approving STOA Bilateral transactions, margin available in Simultaneous Import of NR would be apportioned on WR-NR Corridor & ER-NR Corridor in the following ratio:

Margin in Simultaneous import of NR = A WR-NR ATC =B ER-NR ATC = C

Margin for WR-NR applicants = A * B/(B+C)Margin for ER-NR Applicants = A * C/(B+C)

Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section

#Though 2X315 MVA, 400/220 kV ICTs at Maradam are N-1 non-compliant, the TTC of SR Import has not been restricted due to the same considering that this aspect will be managed by AP SLDC through appropriate measures like SPS implementation.

In case of drawl of Karnataka beyond 3800 MW, the voltages in Bengaluru area are observed to be critically low. This issue may be taken care of by Karnataka by taking appropriate measures.

WR-NR/Import of NR TTC has been calculated considering generation at Pariccha TPS as 350 MW. TTC figures are subject to change with significant change in generation at Pariccha TPS.

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR*	1st August 2020 to 31st August 2020	00-06	4500 700	3800	388	3412			
		06-18		3800	1526	2274			
		18-24	4500		3800	388	3412		
	1st August 2020 to 31st August 2020	00-02	2400	45	2355	21	2334		Devision in STOA monsie
		02-07	2400		2355	21	2334	-	Revision in STOA margin due to allocation of 20.75 MW power from Kameng HEP to UP, Haryana, Chhattisgarh and Goa
NER*		07-12	2450		2405	21	2384		
NEK.		12-17	2341		2296	21	2275		
		17-23	2621		2576	21	2555		
		23-24	2400		2355	21	2334		Chinatusgani and Oba
WR*									
	TSI August 2020								
SR*^	to 31st August	00-24	3700	400	3300	1150	2150		considered for advanced

^SR Export TTC/ATC figures have been calculated considering 01 unit (800 MW) at Kudgi TPS in service. The figures are subject to change with change in generation at Kudgi TPS.

		Applicable Revisions
Corridor	Constraint	
WR-NR	N-1 contingency of 1000 MVA, 765/400 kV ICT at Orai will overload the other ICT	Rev- 0 to 2
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli	Rev- 0 to 2
ER-NR	 N-1 contingency of 400 kV Mejia-Maithon A line will overload the other ckt. N-1 contingency of 400 kV Kahalgaon-Banka line will overload the other ckt. N-1 contingency of 400kV MPL- Maithon line will overload the other ckt. 	Rev- 0 to 2
WR-SR	n-1 contingency of one ckt of 765 kV Wardha - Nizamabad D/C will overload of the other ckt	
wk-Sk and ER- SR	n-1 contingency of one ckt of 765 kV Angul - Srikakulam D/C will overload of the other ckt	Rev- 0 to 2
ы	Low Voltage at Gazuwaka (East) Bus.	
SR-WR	a) N-1 contingency of one ckt of 400 kV Kolhapur-PG - Kolhapur-MS D/C will overload of the other ckt b) N-1 contingency of 500 MVA ICT at 400 kV Kolhapur-MS will overload the other 2x315 MVA ICTs	Rev- 0 to 2
ER-NER	 a) N-1 contingency of 400 kV Bongaigaon - Azara line b) High Loading of 220 kV Samaguri-Sonabil S/C (200 MW) 	Rev- 0 to 2
NER-ER	 a) N-1 contingency of 400 kV Silchar- Azara line b) High Loading of 400 kV Silchar-Killing Line 	Rev- 0 to 2
W3 zone Injection		Rev- 0 to 2

Limming	constraints	(Simulaneous)	
			Applicable Revisions
NR	Import	 N-1 contingency of 400 kV Mejia-Maithon A line will overload the other ckt. N-1 contingency of 400 kV Kahalgaon-Banka line will overload the other ckt. N-1 contingency of 400kV MPL- Maithon line will overload the other ckt. 	Rev- 0 to 2
	Export	N-1 contingency of 1000 MVA, 765/400 kV ICT at Orai will overload the other ICT (n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak. (n-1) contingency of 400 kV Saranath-Pusauli	Rev- 0 to 2
NED	Import	 a) N-1 contingency of 400 kV Bongaigaon - Azara line b) High Loading of 220 kV Samaguri-Sonabil S/C (200 MW) 	Rev- 0 to 2
NER	Export	a) N-1 contingency of 400 kV Silchar- Azara lineb) High Loading of 400 kV Silchar-Killing Line	Rev- 0 to 2
SR	Import	n-1 contingency of one ckt of 765 kV Wardha - Nizamabad D/C will overload of the other ckt n-1 contingency of one ckt of 765 kV Angul - Srikakulam D/C will overload of the other ckt Low Voltage at Gazuwaka (East) Bus	Rev- 0 to 2
	Export	N-1 contingency of one ckt of 400 kV Kolhapur-PG - Kolhapur-MS D/C will overload of the other ckt N-1 contingency of 500 MVA ICT at 400 kV Kolhapur-MS will overload the other 2x315 MVA ICTs	Rev- 0 to 2

Revision No			Reason for Revision/Comment	Corridor Affected
1	28th May 2020	Whole Month	Revision in STOA margin due to operationalization of MTOA from Rajasthan Solar to Maharashtra and MP	NR-WR/Export of NR
			Revision in STOA margin due to change in LTA quantum from GIWEL_SECI-III_RE (Wind, Bhuj) to Punjab from 151.2 MW to 200 MW	WR-NR/Import of NR
2	28th June 2020	Whole Month	Revision in STOA margin due to allocation of 20.75 MW power from Kameng HEP to UP, Haryana, Chhattisgarh and Goa	NER-ER/Export of NER/ER- NR/Import of NR

National Load Despatch Centre Total Transfer Capability for August 2020

ASSUN	IPTIONS IN BASECASE					
				Month : August'2020		
S.No.	Name of State/Area		Load	Generation		
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)	
I	NORTHERN REGION					
1	Punjab	10228	9530	4580	4618	
2	Haryana	9146	9428	2953	2953	
3	Rajasthan	10205	11428	6168	6168	
4	Delhi	5674	6558	753	753	
5	Uttar Pradesh	18102	15529	9903	9908	
6	Uttarakhand	2144	1981	1060	1015	
7	Himachal Pradesh	1562	1558	859	854	
8	Jammu & Kashmir	3049	1686	1075	1017	
9	Chandigarh	375	303	0	0	
10	ISGS/IPPs	23	23	20932	19626	
	Total NR	60510	58023	48283	46912	
	EASTERN REGION					
1	Bihar	5380	4412	99	110	
2	Jharkhand	1637	1024	425	421	
3	Damodar Valley Corporation	3028	2466	4980	4180	
4	Orissa	4823	3995	3952	2615	
5	West Bengal	8541	7006	5659	4956	
6	Sikkim	114	43	0	0	
7	Bhutan	171	168	1474	1444	
8	ISGS/IPPs	-171	-168	11907	10404	
	Total ER	23523	18947	28495	24128	
	WESTERN REGION					
1	Maharashtra	16912	14197	12996	9886	
2	Gujarat	13683	8433	10325	6208	
3	Madhya Pradesh	8253	5455	4058	2863	
4	Chattisgarh	3890	3168	2239	2230	
5	Daman and Diu	297	153	0	0	
6	Dadra and Nagar Haveli	781	550	0	0	
7	Goa-WR	513	326	0	0	
8	ISGS/IPPs	4640	3609	33397	25451	
-	Total WR	48969	35891	63015	46638	

S.No.	Name of State/Area		Load	Generation		
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)	
IV	SOUTHERN REGION					
1	Andhra Pradesh	9316	6695	6310	5934	
2	Telangana	9937	9870	5913	4863	
3	Karnataka	8351	4343	6606	3257	
4	Tamil Nadu	14738	12867	8660	7460	
5	Kerala	3683	2236	1649	423	
6	Pondy	298	246	0	0	
7	Goa-SR	58	48	0	0	
8	ISGS/IPPs	0	0	14970	12179	
	Total SR	46381	36305	44109	34117	
V	NORTH-EASTERN REGION					
1	Arunachal Pradesh	111	70	18	16	
2	Assam	1707	1346	295	245	
3	Manipur	183	82	0	0	
4	Meghalaya	269	198	237	142	
5	Mizoram	99	66	68	42	
6	Nagaland	120	75	22	16	
7	Tripura	259	154	76	75	
8	ISGS/IPPs	159	81	2385	2242	
	Total NER	2907	2073	3101	2778	
	Total All India	182131	151157	187003	154572	