Issue Date: 10th Aug 2020 Issue Time: 1600 hrs Revision No. 7

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
	1st August 2020	00-06				195	1805			
NR-WR*	to 31st August	06-18	2500	500	2000	1223	777			
	2020	18-24				195	1805			
		00-06	17100 16150**	500	16600 15650**	10268 9318**	6332			
WR-NR*	1st August 2020 to 31st August 2020	06-18	17100 16150**	500	16600 15650**	10657	5943			
	2020	18-24	17100 16150**	500	16600 15650**	10268	6332			
	1st August 2020	00-06	2000		1800	193	1607			
NR-ER*	to 31st August	06-18	2000	200	1800	303	1497			
THE LIK	2020	18-24	2000	200	1800	193	1607			
ER-NR*	1st August 2020 to 31st August 2020	00-24	6250	300	5950	4066	1884			
W3-ER	1st August 2020 to 31st August 2020	00-24	No limit is being specified.							
ER-W3	1st August 2020 to 31st August 2020	00-24				No limit i	s being specified.			
	1st August 2020	00-05	6050		6450		2415			
	to 3rd August	05-22	6950 6950	500	6450 6450	4035	2415 2415			
	2020	22-24	6950	300	6450	1033	2415			
		00-05	6950		6450		2415			
	4th August	05-07	6950	500	6450	4025	2415			
	2020	07-22	6300	300	5800	4035	1765			
		22-24	6300		5800		1765			
	7.1 A	00-05	6950		6450		2415			
WR-SR	5th August	05-09	6950	500	6450	4035	6450			
	2020	09-22	6450		5950	-	1915			
		22-24 00-05	6450 6950		5950 6450		1915 2415			
	6th August	05-11	6950		6450		2415			
	2020	11-22	3800	500	3300	4035	0			
		22-24	3800		3300		0			
	7th August	00-05	6950		6450		2415			
	2020 to 31st	05-22	6950	500	6450	4035	2415			
	August 2020	22-24	6950		6450		2415			
SR-WR *	1st August 2020 to 31st August 2020	00-24	4600	400	4200	550	3650			

Issue Date: 10th Aug 2020 Issue Time: 1600 hrs Revision No. 7

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
	1st August 2020	00-06	5950		5700	2663	3037			
	to 3rd August	06-18	5950	250	5700	2748	2952			
	2020	18-24	5950		5700	2663	3037			
	4th August 2020	00-06	5950		5700	2663	3037			
		06-07	5950	250	5700	2748	2952		1	
		07-18	5800	250	5550	2748	2802			
		18-24	5800		5550	2663	2887			
		00-06	5950		5700	2663	3037			
	5th August	06-09	5950	250	5700	2748	2802			
	2020	09-18	5850	250	5600	2748	2952			
		18-24	5850		5600	2663	3037			
ED CD ^Δ		00-06	5950		5700	2663	3037			
ER-SR [^]	6th August	06-11	5950	250	5700	2748	2952			
	2020	11-18	5350	230	5100	2748	2352			
		18-24	5350		5100	2663	2437			
	7th August	00-06	5950		5700	2663	3037			
	2020 to 11th	06-18			250	5700	2748	2952		
	August 2020	18-24	5950		5700	2663	3037			
	12th August 2020	00-06	5950	250	5700	2663	3037		Revision in TTC/ATC due to	
		06-07	5950		5700	2748	2952		planned outage of 400 kV	
		07-18	5650		5400	2748	2652	-300	Meramundali-Bolangir line	
	12:1 4	18-24	5650		5400	2663	2737	-300		
	13th August	00-06	5950	250	5700	2663	3037			
	2020 to 31st August 2020	06-18 18-24	5950 5950	250	5700 5700	2748 2663	2952 3037		-	
SR-ER *	1st August 2020 to 31st August 2020	00-24					,			
		00-02	1410		1365	432	933	390		
		02-07	1410		1365	432	933	390		
		07-12	1410		1365	474	891	330		
	1st August 2020	12-17	1410		1365	474	891	350		
R-NER*	to 31st August	17-18	1410	45	1365	474	891	410		
	2020	18-22	1340		1295	432	863	340		
		22-23	1410		1365	432	933	410		
		23-24	1410		1365	432	933	390		
		00-02	2020		1975	42	1933	-380		
		02-07	2020		1975	42	1933	-380		
	1st August 2020	07-12	2020		1975	42	1933	-430		
NER-ER*	to 31st August	12-17	2020	45	1975	42	1933	-321		
TEIX-TEIX	2020	17-18	2020	73	1975	42	1933	-601		
	2020	18-22	2110		2065	42	2023	-511		
		22-23	2020		1975	42	1933	-601		
		23-24	2020		1975	42	1933	-380		
W3 zone Injection	1st August 2020 to 31st August 2020	00-24	No limit is be	ing specified (In case of any o	constraints appeari	ng in the system, W	/3 zone expo	rt would be revised accordingly)	

Note: TTC/ATC of S1-(S2&S3) corridor, Import of S3(Kerala), Import of Punjab and Import of DD & DNH is uploaded on NLDC website under Intra-Regional Section in Monthly ATC.

Issue Date: 10th Aug 2020 Issue Time: 1600 hrs Revision No. 7

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
----------	------	-------------------------	--	-----------------------	--	--	--	-------------------------------------	----------

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

- 1) S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala
- 2) W3 comprises of the following regional entities:
- a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak
- f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCL, n)Vandana Vidyut o)RKM, p)GMR Raikheda, q)Ind Barath and any other regional entity generator in Chhattisgarh

The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/Fuel shortage/New units being commissionned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis.

In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown:

- 1) The TTC value will be revised to normal values after restoration of shutdown.
- 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section

^Though 2X315 MVA, 400/220 kV ICTs at Maradam are N-1 non-compliant, the TTC of WR-SR and ER-SR corridor has not been restricted due to the same considering that this aspect will be managed by AP SLDC through appropriate measures like SPS implementation.

^In case of drawl of Karnataka beyond 3800 MW, the voltages in Bengaluru area are observed to be critically low. This issue may be taken care of by Karnataka SLDC by

SR-WR TTC/ATC figures have been calculated considering 01 unit (800 MW) at Kudgi TPS in service. The figures are subject to change with change in generation at Kudgi TPS.

WR-NR/Import of NR TTC has been calculated considering generation at Pariccha TPS as 350 MW. TTC figures are subject to change with significant change in generation at Pariccha TPS.

^{**}Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.

Simultane	ous Import Capa	bility							
Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
		00-06	23350		22550 21600**	14334 13384**	8216		
		06-09	23350		22550	14723	7827		
NR*	1st August 2020 to 31st August 2020	09-17	22400** 23350	800	21600**	13773** 14723	7827		
	2020	17-18	22400** 23350 22400**		21600** 22550 21600**	13773** 14723	7827		
		18-24	23350		22550	13773** 14334	8216		
		00-02	910		21600** 865	13384** 432	433		
		02-07	910	45	865	432	433		-
	1-4 4	07-12	910		865	474	391		
NER*	1st August 2020 to 31st August	12-17	910		865	474	391		
NEK	2020	17-18	910		865	474	391]
	2020	18-22	840		795	432	363		
		22-23	910		865	432	433		
		23-24	910		865	432	433		
\mathbf{WR}^*									-
	1st August 2020	00-06	12900		12150	6698	5452		
	to 3rd August	06-18	12900	750	12150	6783	5367		
	2020	18-24	12900		12150	6698	5452		
		00-06	12900		12150	6698	5452		-
	4th August 2020	06-07	12900 12100	750	12150	6783	5367		-
		07-18 18-24	12100		11350 11350	6783 6698	4567 4652		-
		00-06	12900		12150	6698	5452		
		06-09	12900		12900	6783	6117		-
	5th August 2020	09-18	12300	750	11550	6783	4767		-
		18-24	12300		11550	6698	4852		
		00-06	12900		12150	6698	5452	·	
SR*#	6th August 2020	06-11	12900	750	12900	6783	6117		
	om August 2020	11-18	9150	130	8400	6783	1617		
		18-24	9150		8400	6698	1702		
	7th August 2020	00-06	12900		12150	6698	5452		
	to 11th August	06-18	12900	750	12150	6783	5367		-
	2020	18-24	12900		12150	6698	5452		
	12th August	00-06 06-07	12900 12900		12150 12150	6698 6783	5452 5367		Revision in TTC/ATC due to
	2020	07-18	12900	750	11850	6783	5067	-300	planned outage of 400 kV
	2020	18-24	12600		11850	6698	5152	-300	Meramundali-Bolangir line
	13th August	00-06	12900		12150	6698	5452	500	
	2020 to 31st	06-18	12900	750	12150	6783	5367		1
	August 2020	18-24	12900	1	12150	6698	5452		1

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions

**Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW

* For approving STOA Bilateral transactions, margin available in Simultaneous Import of NR would be apportioned on WR-NR Corridor & ER-NR Corridor in the following ratio:

Margin in Simultaneous import of NR = A

WR-NR ATC =B

ER-NRATC = C

Margin for WR-NR applicants = A * B/(B+C)

Margin for ER-NR Applicants = A * C/(B+C)

Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section

#Though 2X315 MVA, 400/220 kV ICTs at Maradam are N-1 non-compliant, the TTC of SR Import has not been restricted due to the same considering that this aspect will be managed by AP SLDC through appropriate measures like SPS implementation.

In case of drawl of Karnataka beyond 3800 MW, the voltages in Bengaluru area are observed to be critically low. This issue may be taken care of by Karnataka by taking appropriate measures.

WR-NR/Import of NR TTC has been calculated considering generation at Pariccha TPS as 350 MW. TTC figures are subject to change with significant change in generation at Pariccha TPS.

Simultan	Simultaneous Export Capability											
Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments			
	1st August 2020	00-06	4500		3800	388	3412					
NR*	to 31st August 2020	06-18	4300	700	3800	1526	2274					
	2020	18-24	4500		3800	388	3412					
		00-02	2520	4.5	2475	42	2433					
		02-07	2520		2475	42	2433					
		07-12	2520		2475	42	2433					
NER*	1st August 2020 to 31st August	12-17	2520		2475	42	2433					
NEK"	2020	17-18	2520	45	2475	42	2433					
		18-22	2610		2565	42	2523					
		22-23	2520		2475	42	2433					
		23-24	2520		2475	42	2433					
WR*												
SR*^	1st August 2020 to 31st August 2020	00-24	3700	400	3300	1150	2150					

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section

^SR Export TTC/ATC figures have been calculated considering 01 unit (800 MW) at Kudgi TPS in service. The figures are subject to change with change in generation at Kudgi TPS.

		Applicable Revisions	
Corridor	Constraint		
WR-NR	N-1 contingency of 1000 MVA, 765/400 kV ICT at Orai will overload the other ICT	Rev- 0 to 7	
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli	Rev- 0 to 7	
ER-NR	 N-1 contingency of 400 kV Mejia-Maithon A line will overload the other ckt. N-1 contingency of 400 kV Kahalgaon-Banka line will overload the other ckt. N-1 contingency of 400kV MPL- Maithon line will overload the other ckt. 	Rev- 0 to 7	
	n-1 contingency of one ckt of 765 kV Wardha - Nizamabad D/C will overload of the other ckt		
	n-1 contingency of one ckt of 765 kV Angul - Srikakulam D/C will overload of the other ckt	Rev- 0 to 3, 7	
WR-SR	Low Voltage at Gazuwaka (East) Bus.		
	Overloading of 765/400 kV ICT at Nizamabad under outage of one ckt 765 kV Nizamabad - Maheshwaram line	Rev - 4	
	Overloading of 765/400 kV ICT at Nizamabad under outage of other ICT	Rev - 5	
	Overloading of 765/400 kV ICT at Nizamabad under outage of other bus	Rev-6	
	a) N-1 contingency of one ckt of 400 kV Kolhapur-PG - Kolhapur-MS D/C will overload of the other ckt b) N-1 contingency of 500 MVA ICT at 400 kV Kolhapur-MS will overload the other 2x315 MVA ICTs	Rev- 0 to 7	
	a) N-1 contingency of 400 kV Bongaigaon - Azara line b) High Loading of 220 kV Samaguri-Sonabil S/C (200 MW)	Rev- 0 to 2	
	N-1 contingency of 400 kV Bongaigaon - Azara line will lead to overloading of 220 kV Salakati-BTPS Double circuit (200 MW)	Rev- 3 to 7	
	a) N-1 contingency of 400 kV Silchar- Azara line b) High Loading of 400 kV Silchar-Killing Line	Rev- 0 to 7	
W3 zone Injection		Rev- 0 to 7	

Limiting Constraints (Simultaneous)

. 0		(Omitinations)	Applicable Revisions
NR	Import	N-1 contingency of 400 kV Mejia-Maithon A line will overload the other ckt. N-1 contingency of 400 kV Kahalgaon-Banka line will overload the other ckt. N-1 contingency of 400kV MPL- Maithon line will overload the other ckt.	Rev- 0 to 7
1111		N-1 contingency of 1000 MVA, 765/400 kV ICT at Orai will overload the other ICT	Rev- 0 to 7
	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak. (n-1) contingency of 400 kV Saranath-Pusauli	Kev- 0 to /
	In out	 a) N-1 contingency of 400 kV Bongaigaon - Azara line b) High Loading of 220 kV Samaguri-Sonabil S/C (200 MW) 	Rev- 0 to 2
NER	Import	N-1 contingency of 400 kV Bongaigaon - Azara line will lead to overloading of 220 kV Salakati-BTPS Double circuit (200 MW)	Rev-3 to 7
	Export	a) N-1 contingency of 400 kV Silchar- Azara lineb) High Loading of 400 kV Silchar-Killing Line	Rev- 0 to 7
		n-1 contingency of one ckt of 765 kV Wardha - Nizamabad D/C will overload of the other ckt	
		n-1 contingency of one ckt of 765 kV Angul - Srikakulam D/C will overload of the other ckt	Rev- 0 to 3, 7
		Low Voltage at Gazuwaka (East) Bus	
SR	Import	Overloading of 765/400 kV ICT at Nizamabad under outage of one ckt 765 kV Nizamabad - Maheshwaram line	Rev - 4
		Overloading of 765/400 kV ICT at Nizamabad under outage of other ICT	Rev -5
		Overloading of 765/400 kV ICT at Nizamabad under outage of other bus	Rev -6
	Ermont	N-1 contingency of one ckt of 400 kV Kolhapur-PG - Kolhapur-MS D/C will overload of the other ckt	Rev- 0 to 7
	Export	N-1 contingency of 500 MVA ICT at 400 kV Kolhapur-MS will overload the other 2x315 MVA ICTs	Kev- 0 to /

Revision No	Date of Revision	Period of Revision	Reason for Revision/Comment	Corridor Affected
1	28th May 2020	Whole Month	Revision in STOA margin due to operationalization of MTOA from Rajasthan Solar to Maharashtra and MP	NR-WR/Export of NR
			Revision in STOA margin due to change in LTA quantum from GIWEL_SECI-III_RE (Wind, Bhuj) to Punjab from 151.2 MW to 200 MW	WR-NR/Import of NR
2	2 28th June 2020		Revision in STOA margin due to allocation of 20.75 MW power from Kameng HEP to UP, Haryana, Chhattisgarh and Goa	NER-ER/Export of NER/ER- NR/Import of NR
			Revised TTC considering change in power order on HVDC APD-AGRA	WR-NR/ER- NR/Import of NR
3	30th July 2020	Whole Month	(i) Revised TTC due to (a) change in LGBR and (b) addition of 2x150 MW Kameng generation (ii) Change in STOA margins due to change in allocation from Kameng & Mangdekchu	NER-ER/Export of NER/ER- NR/Import of NR
4	2nd Aug 2020	4th Aug 2020	Revision in TTC/ATC due to planned outage of 765/400 kV Nizamabad ICT-I	WR-SR/ER- SR/Import of SR
5	3rd Aug 2020	5th Aug 2020	Revision in TTC/ATC due to planned outage of 765/400 kV Maheshwaram ICT-2	WR-SR/ER- SR/Import of SR
6	4rd Aug 2020	6th Aug 2020	Revision in TTC/ATC due to planned outage of 765 kV Bus - II at Nizamabad	WR-SR/ER- SR/Import of SR
7	10th Aug 2020	12th Aug 2020	Revision in TTC/ATC due to planned outage of 400 kV Meramundali-Bolangir line	ER-SR/Import of SR

ASSUM	MPTIONS IN BASECASE					
				Month : August'2020		
S.No.	Name of State/Area		Load	Generation		
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)	
I	NORTHERN REGION					
1	Punjab	10228	9530	4580	4618	
2	Haryana	9146	9428	2953	2953	
3	Rajasthan	10205	11428	6168	6168	
4	Delhi	5674	6558	753	753	
5	Uttar Pradesh	18102	15529	9903	9908	
6	Uttarakhand	2144	1981	1060	1015	
7	Himachal Pradesh	1562	1558	859	854	
8	Jammu & Kashmir	3049	1686	1075	1017	
9	Chandigarh	375	303	0	0	
10	ISGS/IPPs	23	23	20932	19626	
	Total NR	60510	58023	48283	46912	
П	EASTERN REGION					
1	Bihar	5380	4412	99	110	
2	Jharkhand	1637	1024	425	421	
3	Damodar Valley Corporation	3028	2466	4980	4180	
4	Orissa	4823	3995	3952	2615	
5	West Bengal	8541	7006	5659	4956	
6	Sikkim	114	43	0	0	
7	Bhutan	171	168	1474	1444	
8	ISGS/IPPs	-171	-168	11907	10404	
	Total ER	23523	18947	28495	24128	
III	WESTERN REGION					
1	Maharashtra	16912	14197	12996	9886	
2	Gujarat	13683	8433	10325	6208	
3	Madhya Pradesh	8253	5455	4058	2863	
4	Chattisgarh	3890	3168	2239	2230	
5	Daman and Diu	297	153	0	0	
6		781	550	0	0	
7	Dadra and Nagar Haveli Goa-WR	513	326	0	0	
8	ISGS/IPPs			33397	25451	
0	Total WR	4640	3609			
	I Olai WK	48969	35891	63015	46638	

S.No.	Name of State/Area		Load	Gene	ration
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
IV	SOUTHERN REGION				
1	Andhra Pradesh	9316	6695	6310	5934
2	Telangana	9937	9870	5913	4863
3	Karnataka	8351	4343	6606	3257
4	Tamil Nadu	14738	12867	8660	7460
5	Kerala	3683	2236	1649	423
6	Pondy	298	246	0	0
7	Goa-SR	58	48	0	0
8	ISGS/IPPs	0	0	14970	12179
	Total SR	46381	36305	44109	34117
V	NORTH-EASTERN REGION				
1	Arunachal Pradesh	111	70	18	16
2	Assam	1707	1346	295	245
3	Manipur	183	82	0	0
4	Meghalaya	269	198	237	142
5	Mizoram	99	66	68	42
6	Nagaland	120	75	22	16
7	Tripura	259	154	76	75
8	ISGS/IPPs	159	81	2385	2242
	Total NER	2907	2073	3101	2778
	Total All India	182131	151157	187003	154572