

**National Load Despatch Centre
Total Transfer Capability for December 2014**

Issue Date: 14/12/2014

Issue Time: 1315 hrs

Revision No. 16

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR-WR *	1st December 2014 to 31st December 2014	00-24	2500	500	2000	1055	945		
WR-NR	1st December 2014 to 2nd December 2014	00-07'	4900	500	4400	4380	20		
		07-24'	4100		3600		0		
	3rd December 2014	00-07'	4900	500	4400	4380	20		
		07-14'	4100		3600		0		
		14-24	3600		3600		0		
	4th December 2014	00-07'	4400	500	3900	4380	0		
		07-24'	3600		3100		0		
	5th December 2014 to 11th December 2014	00-07	4900	500	4400	4380	20		
		07-24	4100		3600		0		
	12th December 2014 to 18th December 2014	00-07	4900	500	4400	4380	20		
		07-24	4100		3600		0		
	19th December 2014 to 31st December 2014	00-17 23-24	4900	500	4400	4380	20		
		17-23	4900		4400		20		
	NR-ER*	1st December 2014 to 31st December 2014	00-06	2000	200	1800	293	1507	
06-18'			2000	1800		358	1442		
18-24			2000	1800		293	1507		
ER-NR	1st December 2014 to 31st December 2014	00-17 23-24	3500	300	3200	2431	769		
		17-23	3600		3300	869			
W3-ER[§]	1st December 2014 to 31st December 2014	00-24	1900	300	1600	697	903		
ER-W3	1st December 2014 to 31st December 2014	00-24	1000	300	700	973	0		
WR-SR	1st December 2014 to 9th December 2014	00-24	2100	750	1350	1350	0		
	10th December 2014	00-05 10-24'	2100	750	1350	1350	0		
		05-10'	1750		1000	1350	0		
	11th December 2014	05-22	2100	750	1350	1350	0		
		00-05 22-24	2500		1750	1350	400		
	12th December 2014 to 13th December 2014	05-08	2100	750	1350	1350	0		
		08-22'	1600		850	1350	0		
		22-24	2000		1250	1350	0		
		00-05	2500		1750	1350	400		
	14th December 2014 to 31st December 2014	05-22	2100	750	1350	1350	0		
		00-05 22-24	2500		1750	1350	400		
SR-WR *	1st December 2014 to 31st December 2014	00-24	No limit is being Specified.						

**National Load Despatch Centre
Total Transfer Capability for December 2014**

Issue Date: 14/12/2014

Issue Time: 1315 hrs

Revision No. 16

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
ER-SR	1st December 2014 to 4th December 2014	00-06	2300	0	2300	2435	0			
		18-24								
		06-18'								
	5th December 2014	00-06	2300	0	2300	2435	0			
		06-13'								
		13-18'								
		18-24								
	6th December 2014 to 7th December 2014	00-06	2650	0	2650	2435	215			
		18-24								
	8th December 2014 to 15th December 2014	00-06	2650	0	2650	2435	215			
		18-24								
	16th December 2014 to 31st December 2014	00-06	2650	0	2650	2435	215			
18-24										
SR-ER *	1st December 2014 to 31st December 2014	00-24	No limit is being Specified.							
ER-NER	1st December 2014	00-17	650	40	610	210	400			
		23-24								
		17-23								
	2nd December 2014 to 8th December 2014	00-17	685	40	645	210	435			
		23-24								
	9th December 2014	00-08	685	40	645	210	435			
		23-24								
		08-17'								
	10th December 2014 to 31st December 2014	00-17	685	40	645	210	435			
		23-24								
	NER-ER	1st December 2014 to 8th December 2014	00-17	480	30	450	0	450		
			23-24							
17-23										
9th December 2014		00-08	480	30	450	0	450			
		23-24								
		08-17'								
10th December 2014 to 31st December 2014		00-17	480	30	450	0	450			
		23-24								
		17-23	500	40	470		470			

National Load Despatch Centre
Total Transfer Capability for December 2014

Issue Date: 14/12/2014

Issue Time: 1315 hrs

Revision No. 16

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
S1-S2	1st December 2014 to 2nd December 2014	00-24	3300	295	3005	2879	126		
	3rd December 2014	00-10	3300	295	3005	2879	126		
		1000-1730	3210	295	2915	2879	36		
		1730-2400	3300	295	3005	2879	126		
	4th December 2014 to 9th December 2014	00-24	3300	295	3005	2879	126		
	11th December 2014	00-06	3300	295	3005	3029	0		
		06-24	3575	295	3280	3138	142		
	12th December 2014	00-24	3575	295	3280	3138	142		
	13th December 2014	00-09	3575	295	3280	3138	142		
		09-18'	2950		2655	3138	0		
		18-21	3575		3280	3138	142		
		21-24	2950		2655	3138	0		
	14th December 2014	00-17	2950	295	2655	3138	0		
		17-24	3575		3280	3138	142		
	15th December 2014 to 17th December 2014	00-24	3575	295	3280	3087	193	275	Revised due to Vallur Unit-1 outage extension
18th December 2014	00-10	3575	295	3280	3087	193	275		
	10-24'	3300		3005	2978	27			
19th December 2014 to 28th December 2014	00-24	3300	295	3005	2978	27			
29th December 2014 to 30th December 2014	00-24	3300	295	3005	2942	63			
31st December 2014	00-24	3300	295	3005	2865	140			
Import of Punjab	1st December 2014 to 31st December 2014	00-24	5700	300	5400	3790	1610		
Import TTC for DD & DNH	1st December 2014 to 31st December 2014	00-24	1200	0	1200	LTA and MTOA as per ex-pp schedule			
W3 zone Injection	1st December 2014 to 31st December 2014	00-17	9400	200	9200	6843	2357		
		23-24			9700		2857		

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

** Maharashtra's off peak demand is considered to be lower than the peak demand by approximately 5000 MW from 2200 hrs to 0500 hrs

\$ As per Simulations, predominant direction of flow is on West to North Corridor. Hence, in case injection point is in Western Region (W1,W2,W3), STOA/PX transactions from West to North on West-East-North corridor shall not be allowed as such transaction increases congestion in the West to North Corridor.

1) ER-SR TTC declared at Talcher Interconnector and Gazuwaka HVDC B/B seam

2) S1 comprises of AP and Karnataka; S2 comprises of Tamil Nadu, Kerala and Pondicherry

3) W3 comprises of the following regional entities :

a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak
f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, l)DB Power, m) KWPCCL, n)Vandana Vidyt

The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis.

In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown :

1) The TTC value will be revised to normal values after restoration of shutdown.

2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

**National Load Despatch Centre
Total Transfer Capability for December 2014**

Issue Date: 14/12/2014

Issue Time: 1315 hrs

Revision No. 16

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
----------	------	-------------------	---------------------------------	--------------------	-------------------------------------	--	--	-------------------------------------	----------

Limiting Constraints

Corridor	Constraint
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.
WR-NR	High Loading of 400kV Singrauli-Anpara & High loading of 765 kV Agra-Gwalior (1250 MW SPS setting on each circuit of 765 kV Gwalior-Agra) and Loop flows on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda (power flowing from WR to NR on 765kV Gwalior-Agra D/C and from NR to WR on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda).
NR-ER	(n-1) contingency of 400 kV Allahabad-Pusauli
ER-NR & ER-NER	Outage of one circuit of 400KV Kahalgaon-Banka leads to thermal loading of second circuit.
W3-ER	(n-1) contingency of 400kV Sterlite-Rourkela S/C
ER-W3	(n-1) contingency of 400kV Raigarh-Jharsuguda-Rourkela
WR-SR & ER-SR	1. (n-1) contingency of one circuit of 400kV Parli(PG)-Sholapur(PG) 2. ER-SR TTC has been declared assuming more than 1100 MW generation at Talcher Stage-2. In case Talcher Stage-2 generation goes below 1100 MW, then the ER-SR TTC would be revised downward as constraints within ER would emerge.
ER-NER	Palatana unit tripping leading to the thermal overloading of 220 kV BTPS - Salakati D/C
NER-ER	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa and High loading of 220kV Misa-Samaguri D/C
S1-S2	(n-1) contingency of one circuit of 400 kV Kolar-Hosur
Import of DD & DNH	(n-1) contingency of 400/220KV 315MVA ICT at VAPI
Import of Punjab	(n-1) contingency of ICT at Dhuri and (n-1) contingency of 220kV Moga(PG)-Moga(PSTCL)
W3 zone Injection	(n-1-1) contingency of 400 kV Raipur-Bhadrawati D/C section and High loading of 400kV Raipur-Wardha (850 MW SPS setting on each circuit of 400kV Raipur-Wardha)

*Primary constraints

Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER									
NR	1st December 2014 to 2nd December 2014	00-07	8400	800	7600	6811	789		
		07-17	7600		6800		0		
		17-23	7700		6900		89		
		23-24	7600		6800		0		
	3rd December 2014	00-07	8400	800	7600	6811	789		
		07-14	7600		6800		0		
		14-17	7100		7100		0		
		17-23	7200		6400		0		
	4th December 2014	23-24	7100	800	6300	6811	0		
		00-07	7900		7100		289		
		07-17	7100		6300		0		
		17-23	7200		6400		0		
	5th December 2014 to 11th December 2014	23-24	7100	800	6300	6811	0		
		00-07	8400		7600		789		
		07-17	7600		6800		0		
		17-23	7700		6900		89		
	12th December 2014 to 18th December 2014	00-07	8400	800	7600	6811	789		
		07-17	7600		6800		0		
		23-24	7600		6800		0		
		17-23	7700		6900		89		
19th December 2014 to 31st December 2014	00-17	8400	800	7600	6811	789			
	23-24	8400		7600		789			
		17-23	8500		7700		889		

NER	1st December 2014	00-17	650	40	610	210	400			
		23-24					630		420	
	2nd December 2014 to 8th December 2014	00-17	685	40	645	210	435			
		23-24					670		460	
	9th December 2014	00-08	685	40	645	210	435			
		23-24					420		210	
		08-17'	460				670		460	
	10th December 2014 to 31st December 2014	00-17	685	40	645	210	435			
		23-24					670		460	
	WR									
	SR	1st December 2014 to 4th December 2014	00-06	4400	750	3650	3785	0		
18-24								3850	0	
5th December 2014		06-18'		750	3650	3785	0			
		00-06	4400				3850	0		
		06-13'	4400				3850	3850	0	
		13-18'	4600				3850	3785	65	
6th December 2014 to 7th December 2014		18-24	4600							
		00-06	4750	750	4000	3785	215			
06-18'							3850	150		
8th December 2014 to 9th December 2014		00-06	4750	750	4000	3785	215			
		18-24						3850	150	
10th December 2014		06-18'								
		00-05	4750	750	4000	3785	215			
		18-24								
		05-06'	4400				3650	3785	0	
06'-10		4400				3650	3850	0		
11th December 2014		10-18'	4750			4000	3850	150		
		00-05	5150	750	4400	3785	615			
		06-18'	4750				4000	3850	150	
		18-22	4750				4000	3785	215	
		22-24	5150				4400	3785	615	
12th December 2014 to 13th December 2014		00-05	5150	750	4400	3785	615			
		05-06'	4750				4000	3785	215	
		06-08'	4750				4000	3850	150	
		08-18'	4250				3500	3850	0	
		18-22	4250				3500	3785	0	
		22-24	4650				3900	3785	115	
14th December 2014 to 31st December 2014	00-05	5150	750	4400	3785	615				
	05-06'	4750				4000	3785	215		
	06-18'	4750				4000	3850	150		
	18-22	4750				4000	3785	215		
	22-24	5150				4400	3785	615		

Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR*	1st December 2014 to 31st December 2014	00-06	4500	700	3800	999	2801		
		06-17'			3800	1064	2736		
		17-18'	4500		3800	1064	2736		
		18-24	4500		3800	999	2801		
NER	1st December 2014 to 8th December 2014	00-17 23-24	480	30	450	0	450		
		17-23	500	40	470		470		
	9th December 2014	00-08 23-24	480	30	450	0	450		
		08-17'	275	30	245		245		
		17-23	500	40	470		470		
	10th December 2014 to 31st December 2014	00-17 23-24	480	30	450	0	450		
		17-23	500	40	470		470		
	WR								
SR *	1st December 2014 to 31st December 2014	00-24	No limit is being Specified.						

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Limiting Constraints

NR	Import	Outage of one circuit of 400KV Kahalgaon-Banka leads to thermal loading of second circuit. High loading of 765 kV Agra-Gwalior (1250 MW SPS setting on each circuit of 765 kV Gwalior-Agra) and high loop
	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak. (n-1) contingency of 400 kV Allahabad-Pusauli
NER	Import	Outage of one circuit of 400KV Kahalgaon-Banka leads to thermal loading of second circuit.
	Export	Outage of one 315 MVA, 400/220kV ICT at Misa leads to overloading of second ICT at MISA.
SR	Import	1. (n-1) contingency of one circuit of 400kV Parli(PG)-Sholapur(PG)
		2. ER-SR TTC has been declared assuming more than 1100 MW generation at Talcher Stage-2. In case Talcher Stage-

*Primary constraints

**National Load Despatch Centre
Total Transfer Capability for December 2014**

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor Affected
1	11/21/14	Whole Month	Revised due to 400kV Jeypore-Gazuwaka D/C line Tower collapse	ER-SR
			Revised due to 400kV KalivendapattuPugalur-2 and 400/230kV Tiruvalam Downstream commissioning & Revised LGBR by constituents.	S1-S2
2	11/27/14	Whole month	LTA revised due to allocation of power from North to West	NR-WR
			LTA revised due to allocation of LTA from ER to MP	ER-W3
		1-12-2014 to 4-12-2014	Revised due to shutdown of Mundra-Mohindergarh HVDC Pole-2	WR-NR
		Whole Month	Revised due to NCTPS Stage -2 Unit-1 outage extension & Synchronisation of 765kV Karnool-Tiruvalam DC line (at 400kV level).	S1-S2
Revised considering network restructuring in NER region	ER-NER			
3	12/01/14	1-12-2014 to 7-12-2014	Revised considering the revival of 400 kV Jeypore Gazuwaka ckt 2 after cyclone Hudhud	ER-SR
		Whole month	Revised considering the real time load generation balance conditions in ER region	ER-NER
			Revised considering network restructuring and real time load generation balance in NER region	NER-ER
4	12/02/14	12/03/14	Revised due to shutdown of 400kV Nellore - Alamatty	S1-S2
5	12/03/14	03-12-2014 to 04-12-2014	Revised due to restriction of Power order of HVDC Vindhychal B/B to 250 MW for maintenance reasons.	WR-NR
6	12/04/14	05-12-2014 to 11-12-2014	Revised due to shutdown of HVDC Rihand - Dadri pole 1	WR-NR
		12-12-2014 to 18-12-2014	Revised due to shutdown of HVDC Rihand - Dadri pole 2	
7	12/05/14	05-12-2014 to 15-12-2014	Revised considering the revival of 400 kV Jeypore Gazuwaka ckt 2 after cyclone Hudhud	ER-SR
8	12/06/14	whole month	Revised considering the revival of 400 kV Jeypore Gazuwaka ckt 1 after cyclone Hudhud	ER-SR
9	12/08/14	12/09/14	Revised due to shutdown of 220 kV Azara	ER-NER / NER-ER
10	12/09/14	12/10/14	Revised due to shutdown of 400 kV Parli - Sholapur ckt 2	WR-SR

**National Load Despatch Centre
Total Transfer Capability for December 2014**

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor Affected
11	12/10/14	11-12-2014 to 31-12-2014	Revised considering the present demand pattern of Maharashtra** during off -peak conditions	WR-SR
12	12/10/14	11-12-2014 to 14-12-2014	Revised due to outage of Vallur unit 1	S1-S2
13	12/11/14	12-12-2014 to 13-12-2014	Revised due to shutdown of HVDC Bhadrawati Pole 2	WR-SR
14	12/12/14	13/12/2014	Revised due to shutdown of 400kV Kolar - Hoody D/C	S1-S2
15	13/12/2014	14/12/2014	Revised due to extension of 400kV Kolar - Hoody D/C shutdown	S1-S2
16	14/12/2014	15-12-2014 to 18-12-2014	Revised due to Vallur Unit-1 outage extension	S1-S2