

**National Load Despatch Centre
Total Transfer Capability for December 2014**

Issue Date: 01/12/2014

Issue Time: 1200 hrs

Revision No. 3

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR-WR *	1st December 2014 to 31st December 2014	00-24	2500	500	2000	1055	945		
WR-NR	1st December 2014 to 4th December 2014	00-07'	4900	500	4400	4380	20		
		07-24'	4100		3600		0		
	5th December 2014 to 31st December 2014	00-17 23-24	4900	500	4400	4380	20		
		17-23	4900		4400		20		
NR-ER*	1st December 2014 to 31st December 2014	00-06	2000	200	1800	293	1507		
		06-18'	2000		1800	358	1442		
		18-24	2000		1800	293	1507		
ER-NR	1st December 2014 to 31st December 2014	00-17 23-24	3500	300	3200	2431	769		
		17-23	3600		3300		869		
W3-ER [§]	1st December 2014 to 31st December 2014	00-24	1900	300	1600	697	903		
ER-W3	1st December 2014 to 31st December 2014	00-24	1000	300	700	973	0		
WR-SR	1st December 2014 to 31st December 2014	00-24	2100	750	1350	1350	0		
SR-WR *	1st December 2014 to 31st December 2014	00-24	No limit is being Specified.						
ER-SR ^{§§}	1st December 2014 to 7th December 2014	00-06 18-24	2300	0	2300	2435	0	300	Revised considering the revival of 400 kV Jeypore Gazuwaka ckt 2 after cyclone Hudhud
		06-18'				2500	0		
	8th December 2014 to 31st December 2014	00-06 18-24 06-18'	2000	0	2000	2435	0	0	
SR-ER *	1st December 2014 to 31st December 2014	00-24	No limit is being Specified.						
ER-NER	1st December 2014	00-17 23-24 17-23	650	40	610	210	400		
		17-23	670		630		420		
	2nd December 2014 to 31st December 2014	00-17 23-24 17-23	685	40	645	210	435	35	Revised considering the real time load generation balance conditions in ER region
NER-ER	1st December 2014 to 31st December 2014	00-17 23-24	480	30	450	0	450	-60	Revised considering network restructuring and real time load generation balance in NER region
		17-23	500	40	470		470	-25	
S1-S2	1st December 2014 to 9th December 2014	00-24	3300	295	3005	2879	0		
	10th December 2014 to 14th December 2014	00-24	3300	295	3005	3029	0		
	15th December 2014 to 28th December 2014	00-24	3300	295	3005	2978	0		
	29th December 2014 to 30th December 2014	00-24	3300	295	3005	2942	0		
	31st December 2014	00-24	3300	295	3005	2865	0		
Import of Punjab	1st December 2014 to 31st December 2014	00-24	5700	300	5400	3790	1610		
Import TTC for DD & DNH	1st December 2014 to 31st December 2014	00-24	1200	0	1200	LTA and MTOA as per ex-pp schedule			
W3 zone Injection	1st December 2014 to 31st December 2014	00-17 23-24	9400	200	9200	6843	2357		
		17-23	9900		9700		2857		

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

§ As per Simulations, predominant direction of flow is on West to North Corridor. Hence, in case injection point is in Western Region (W1,W2,W3), STOA/PX transactions from West to North on West-East-North corridor shall not be allowed as such transaction increases congestion in the West to North Corridor.

1) ER-SR TTC declared at Talcher Interconnector and Gazuwaka HVDC B/B seam

2) S1 comprises of AP and Karnataka; S2 comprises of Tamil Nadu, Kerala and Pondicherry

3) W3 comprises of the following regional entities :

- a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCOS Amarkantak
f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCCL, n)Vandana Vidut

**National Load Despatch Centre
Total Transfer Capability for December 2014**

Issue Date: 01/12/2014

Issue Time: 1200 hrs

Revision No. 3

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
----------	------	-------------------	---------------------------------	--------------------	-------------------------------------	--	--	-------------------------------------	----------

The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown :

- 1) The TTC value will be revised to normal values after restoration of shutdown.
- 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

Limiting Constraints

Corridor	Constraint
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.
WR-NR	High Loading of 400kV Singrauli-Anpara & High loading of 765 kV Agra-Gwalior (1250 MW SPS setting on each circuit of 765 kV Gwalior-Agra) and Loop flows on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda (power flowing from WR to NR on 765kV Gwalior-Agra D/C and from NR to WR on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda).
NR-ER	(n-1) contingency of 400 kV Allahabad-Pusauli
ER-NR & ER-NER	Outage of one circuit of 400KV Kahalgaon-Banka leads to thermal loading of second circuit.
W3-ER	(n-1) contingency of 400kV Sterlite-Rourkela S/C
ER-W3	(n-1) contingency of 400kV Raigarh-Jharsuguda-Rourkela
WR-SR & ER-SR	1. (n-1) contingency of one circuit of 400kV Parli(PG)-Sholapur(PG) 2. ER-SR TTC has been declared assuming more than 1100 MW generation at Talcher Stage-2. In case Talcher Stage-2 generation goes below 1100 MW, then the ER-SR TTC would be revised downward as constraints within ER would emerge.
ER-NER	Palatana unit tripping leading to the thermal overloading of 220 kV BTPS - Salakati D/C
NER-ER	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa and High loading of 220kV Misa-Samaguri D/C
S1-S2	(n-1) contingency of one circuit of 400 kV Kolar-Hosur
Import of DD & DNH	(n-1) contingency of 400/220KV 315MVA ICT at VAPI
Import of Punjab	(n-1) contingency of ICT at Dhuri and (n-1) contingency of 220kV Moga(PG)-Moga(PSTCL)
W3 zone Injection	(n-1-1) contingency of 400 kV Raipur-Bhadrawati D/C section and High loading of 400kV Raipur-Wardha (850 MW SPS setting on each circuit of 400kV Raipur-Wardha)

*Primary constraints

\$\$ 400 kV Jeypore Gazuwaka ckt 2 is restored after severe damage due to Hudhud cyclone. In view of this, TTC has been increased. However considering that n-1 of 400 kV Jeypore-Gazuwaka will result in blocking of HVDC Gauwaka B/B .Therefore, only LTA and MTOA transfers are allowed through ER-SR corridor till 7th December.

Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER									
NR	1st December 2014 to 4th December 2014	00-17 23-24	8400	800	7600	6811	789		
		17-23	7700		6900		89		
	5th December 2014 to 31st December 2014	00-17 23-24	8400	800	7600	6811	789		
		17-23	8500		7700		889		
NER	1st December 2014	00-17 23-24	650	40	610	210	400		
		17-23	670		630		420		
	2nd December 2014 to 31st December 2014	00-17 23-24	685	40	645	210	435	35	Revised considering the real time load generation balance conditions in ER
		17-23	710		670		460	40	
WR									
SR	1st December 2014 to 31st December 2014	00-06 18-24	4100	750	3350	3785	0		
		06-18'	4100		3350	3850	0		

Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR*	1st December 2014 to 31st December 2014	00-06	4500	700	3800	999	2801		
		06-17'			3800	1064	2736		
		17-18'			3800	1064	2736		
		18-24			3800	999	2801		
NER	1st December 2014 to 31st December 2014	00-17 23-24	480	30	450	0	450	-60	Revised considering network restructuring and real time load generation balance in NER region
		17-23	500	40	470		470	-25	
WR									
SR *	1st December 2014 to	00-24	No limit is being Specified.						

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Limiting Constraints

NR	Import	Outage of one circuit of 400KV Kahalgaon-Banka leads to thermal loading of second circuit. High loading of 765 kV Agra-Gwalior (1250 MW SPS setting on each circuit of 765 kV Gwalior-Agra) and high loop flows on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda (power flowing from WR to NR on 765kV Gwalior-Agra D/C and from NR to WR on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda).
	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak. (n-1) contingency of 400 kV Allahabad-Pusauli
NER	Import	Outage of one circuit of 400KV Kahalgaon-Banka leads to thermal loading of second circuit.
	Export	Outage of one 315 MVA, 400/220kV ICT at Misa leads to overloading of second ICT at MISA.
SR	Import	1. (n-1) contingency of one circuit of 400kV Parli(PG)-Sholapur(PG) 2. ER-SR TTC has been declared assuming more than 1100 MW generation at Talcher Stage-2. In case Talcher Stage-

*Primary constraints

**National Load Despatch Centre
Total Transfer Capability for December 2014**

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor Affected
1	21-11-2014	Whole Month	Revised due to 400kV Jeypore-Gazuwaka D/C line Tower collapse	ER-SR
			Revised due to 400kV KalivendapattuPugalur-2 and 400/230kV Tiruvalam Downstream commissioning & Revised LGBR by constituents.	S1-S2
2	27-11-2014	Whole month	LTA revised due to allocation of power from North to West	NR-WR
			LTA revised due to allocation of LTA from ER to MP	ER-W3
		1-12-2014 to 4-12-2014	Revised due to shutdown of Mundra-Mohindergarh HVDC Pole-2	WR-NR
		Whole Month	Revised due to NCTPS Stage -2 Unit-1 outage extension & Synchronisation of 765kV Karnool-Tiruvalam DC line (at 400kV level).	S1-S2
Revised considering network restructuring in NER region	ER-NER			
3	01-12-2014	1-12-2014 to 7-12-2014	Revised considering the revival of 400 kV Jeypore Gazuwaka ckt 2 after cyclone Hudhud	ER-SR
		Whole month	Revised considering the real time load generation balance conditions in ER region	ER-NER
			Revised considering network restructuring and real time load generation balance in NER region	NER-ER