National Load Despatch Centre Total Transfer Capability for December 2017

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
	1st December	00-06				55	1945		
NR-WR*	2017 to 31st December 2017	06-18 18-24	2500	500	2000	65 55	1935 1945		
	1st December 2017 to 4th	00-08	10050	500	9550	9318	232		
	December 2017	08-24'	9050	500	8550	9318	0		
WR-NR*	5th December 2017 to 10th December 2017	00-24	10050	500	9550	9318	232		
	11th December 2017 to 13th	00-08	10050	500	9550	9318	232		Revised due to shutdwon of 765kv Phagi-Bhiwani-1(11th and 12th
	December 2017	08-24'	9550	500	9050	9318	0	-500	Dec) and Phagi-Bhiwani-2(13th Dec 17)
	14th December 2017 to 31st December 2017	00-24	10050	500	9550	9318	232		
	1st December	00-06	2000		1800	193	1607		
NR-ER*	2017 to 31st	06-18	2000	200	1800	303	1497]	
	December 2017	18-24	2000		1800	193	1607		
ER-NR*	1st December 2017 to 31st December 2017	00-24	4500	300	4200	3030	1170		
W3-ER	1st December 2017 to 31st December 2017	00-24				No limit i	s being specified.		
ER-W3	1st December 2017 to 31st December 2017	00-24				No limit i	s being specified.		
		00-05	5200		4700		990		
	1st December 2017 to 4th	05-22	5200	500	4700	3710	990		
	December 2017	22-24	5200	200	4700	3710	990		
	51 D 1	00-05	5200		4700		990		
	5th December 2017 to 11th	05-22	5200	500	4700	3710	990		
	December 2017	22-24	5200		4700		990		
WR-SR	10th Danish	00-05	5200		4700		990	-500	Revised due to single Moose conductor
	12th December 2017 to 13th December 2017	05-22	5200	500	4700	3710	990	-500	configuration of both the ckts of 400kV
		22-24	5200		4700		990	-500	Chandrapur-Ramagundam which are on ERS towers.
	14th Dagamhan	00-05	5700		5200		1490		
	14th December 2017 to 15th	05-22	5700	500	5200	3710	1490		
	December 2017								
SR-WR*	1st December 2017 to 31st December 2017	00-24	2.00	5700 5200 1490 No limit is being Specified.					

National Load Despatch Centre Total Transfer Capability for December 2017

Issue Date: 10th December 2017 Issue Time: 1230 hrs Revision No. 8

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
	1st December	00-06				3289	261			
ER-SR	2017 to 31st	06-18'	3800	250	3550	3374	176			
	December 2017	18-24				3289	261			
SR-ER *	1st December 2017 to 31st December 2017	00-24		No limit is being Specified.						
	1st December 2017	00-17 17-23 23-24	1270 1160 1270	45	1225 1115 1225	225	1000 890 1000			
ER-NER	2nd December 2017 to 31st December 2017	00-17 17-23 23-24	1170 1060 1170	45	1125 1015 1125	225	900 790 900			
NER-ER	1st December 2017	00-17 17-23 23-24	1400 1400 1400	45	1355 1355 1355	0	1355 1355 1355			
NEK-EK	2nd December 2017 to 31st December 2017	00-17 17-23 23-24	1500 1500 1500	45	1455 1455 1455	0	1455 1455 1455			
W3 zone Injection	1 701 / to 31st 1 00-74 Tho limit is being specified (in case of any constraints appearing in the system way zone export would be revised accordingly)									

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

- 1) S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala
- 2) W3 comprises of the following regional entities:
- a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak
- f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCL, n)Vandana Vidyut o)RKM, p)GMR Raikheda, q)Ind Barath and any other regional entity generator in Chhattisgarh

The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/Fuel shortage/New units being commissionned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown:

- 1) The TTC value will be revised to normal values after restoration of shutdown.
- 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

Simultaneous Import Capability

Corrido r	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER									
		00-05	14350		13550		1202		
	1st December	05-08	14350		13550		1202		
	2017 to 4th	08-18	13000	800	12200	12348	0		
	December 2017	18-23	11750		10950		0		
		23-24	13000		12200		0		
		00-05	14350		13550		1202		
	5th December	05-08	14350		13550		1202		
	2017 to 10th	08-18	14350	800	13550	12348	1202		
	December 2017	18-23	13050		12250		0		
NID		23-24	14350		13550		1202		
NR		00-05	14350		13550		1202		
	11th December	05-08	14350	800	13550	12348	1202		Revised due to shutdwon of
	2017 to 13th	08-18	13650		12850		502	-700	765kv Phagi-Bhiwani-1(11th and 12th Dec) and Phagi-
	December 2017	18-23	12400		11600		0	-650	Bhiwani-2(13th Dec 17)
		23-24	13650		12850		502	-700	
		00-05	14350	800	13550	12348	1202		
	14th December	05-08	14350		13550		1202		
	2017 to 31st	08-18	14350		13550		1202		
	December 2017	18-23	13050		12250		0		
		23-24	14350		13550		1202		
		00-17	1270		1225		1000		
	1st December 2017	17-23	1160	45	1115	225	890		
NER		23-24	1270		1225		1000		
NEK	1st December	00-17	1170		1125		900		
	2017 to 31st	17-23	1060	45	1015	225	790		
	December 2017	23-24	1170		1125		900		
WR									
,,,,,									
		00-05	9000		8250	6998	1252		
	1st December	05-06	9000		8250	6998	1252		
SR	2017 to 04th	06-18	9000	750	8250	7083	1167		
	December 2017	18-22	9000		8250	6998	1252		
		22-24	9000		8250	6998	1252		

		00-05	9000		8250	6998	1252		
	5th December	05-06	9000		8250	6998	1252		
SR	2017 to 11th	06-18	9000	750	8250	7083	1167		
	December 2017	18-22	9000		8250	6998	1252		
		22-24	9000		8250	6998	1252		
	101 5	00-05	9000		8250	6998	1252	-500	
	12th December 2017	05-06	9000	750	8250	6998	1252	-500	Revised due to single Moose conductor configuration of both
SR	to	06-18	9000		8250	7083	1167	-500	the ckts of 400kV Chandrapur
	13th December 2017	18-22	9000		8250	6998	1252	-500	Ramagundam which are on ERS towers.
		22-24	9000		8250	6998	1252	-500	
		00-05	9500		8750	6998	1752		
	SR 14th December 2017 to 31st	05-06	9500		8750	6998	1752		
SR		06-18	9500	750	8750	7083	1667		
	December 2017	18-22	9500		8750	6998	1752		
		22-24	9500		8750	6998	1752		

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

* For approving STOA Bilateral transactions, margin available in Simultaneous Import of NR would be apportioned on WR-NR Corridor & ER-NR Corridor in the following ratio:

Margin in Simultaneous import of NR = A

WR-NR ATC =B

ER-NRATC = C

Margin for WR-NR applicants = A * B/(B+C)

Margin for ER-NR Applicants = A * C/(B+C)

Simultaneous Export Capability

Corrido r	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
	1st December	00-06	4500		3800	248	3552			
NR*	2017 to 31st	06-18	4300	700	3800	368	3432			
	December 2017	18-24	4500		3800	248	3552			
	1st December	00-17	1400	45	1355		1355			
NER	2017 to 31st	17-23	1400		1355	0	1355			
	December 2017	23-24	1400		1355		1355			
WR										
SR *	1st December 2017 to 31st December 2017	00-24		No limit is being Specified.						

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Limiting Constraints (Corridor wise)

`		Applicable Revisions
Corrido	Constraint	
r		
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak	All
WR-NR	1. (n-1) Contingnecy of 765kV Gwalior-Agra one ckt leads to 2750 MW loading on second circuit. 2. High Loading of 400kV Singrauli-Anpara S/C.	All
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli	All
ER-NR	(n-1) contingencies of N.Ranchi - Chandawa S/c & (n-1) contingencies of 400kV MPL- Maithon S/c	All
WR-SR	(n-1) contingency of 400 kV Dichipalli-Ramagundam or one ckt of 765 kV Aurangabad-Solapur D/C will lead to 874 MW loading on 400kV Vemagiri(PG)-Gazuwaka (With Opening of 400kV Vemagiri(PG)-Nunna S/C)	All
& ER- SR	 a. (n-1) contingency of 400 kV Vemagiri - Vijaywada S/C will lead to high loading (874 MW) on 400 kV Vemagiri - Gazuwaka S/C b. N-1 contingency of 765/400 kV 2x1500 MVA Maheswaram (PG) ICTs results in high loading of other ICT 	All except Rev-0
	Low Voltage at Gazuwaka (East) Bus.	All
ER-NER	a. (n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa b. High loading of 220 kV Balipara-Sonabil line(200 MW)	All
NER-ER	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of 220 kV Samaguri - Sonabil line	All
W3 zone Injection	 	All

Limiting Constraints (Simultaneous)

			Applicable Revisions
NR	Import	(n-1) contingencies of N.Ranchi - Chandawa S/c & (n-1) contingencies of 400kV MPL- Maithon S/c. 1. (n-1) Contingnecy of 765kV Gwalior-Agra one ckt leads to 2750 MW loading on second circuit. 2. High Loading of 400kV Singrauli-Anpara S/C.	All
	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak. (n-1) contingency of 400 kV Saranath-Pusauli	All
NER	Import	a. (n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa b. High loading of 220 kV Balipara-Sonabil line(200 MW)	All
NEK	Export	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of 220 kV Samaguri - Sonabil line	All
		(n-1) contingency of 400 kV Dichipalli-Ramagundam or one ckt of 765 kV Aurangabad-Solapur D/C will lead to 874 MW loading on 400kV Vemagiri(PG)-Gazuwaka (With Opening of 400kV Vemagiri(PG)-Nunna	All
SR	Import	a. (n-1) contingency of 400 kV Vemagiri - Vijaywada S/C will lead to high loading (874 MW) on 400 kV Vemagiri - Gazuwaka S/C b. N-1 contingency of 765/400 kV 2x1500 MVA Maheswaram (PG) ICTs results in high loading of other ICT	All except Rev 0
		Low Voltage at Gazuwaka (East) Bus.	All

National Load Despatch Centre Total Transfer Capability for December 2017

Revision	Date of	Period of	Reason for Revision	Corridor
No	Revision	Revision		Affected
1	20th September 2017	Whole Month	Revised considering commissioning and commercial operation of 765 kV Nizamabad - Maheswaram D/C, 765/400 kV 2x1500 MVA ICTs at Maheswaram, 400 kV Maheswaram(PG) - Maheswaram D/C, 400/220 kV 1x500 MVA ICTs at Maheswaram, 400 kV Maheswaram(PG) - Kurnool S/C and 400 kV Maheswaram - Ghanapur S/C (LILO of 400 kV Ghanapur - Kurnool S/C)	ER-SR / WR- SR / Import of SR
2	28th September	Whole Month	Revised TTC due to commissioning and commercial operation of HVDC Champa Kurukshetra pole II and revised STOA margins due to change in LTA/MTOA approved by CTU	WR-NR / Import of NR
	2017		Revised STOA margins due to change in LTA/MTOA approved by CTU	WR-SR/ER-SR / Import of SR
3	27th October 2017	Whole Month	Revised due to commisioning of 400 kV Nizamabad- Shankarapalli D/C and consideration of present load generation balance	ER-SR / WR- SR / Import of SR
4	28th November 2017	Whole Month	Revised STOA margins due to reconfiguration of Rihand TPS Stage-III from Northern Region to Western Region	WR-NR / Import of NR
5	30th November 2017	01st December 2017 to 04th December 2017	Revised due to shutdown of HVDC Mundra-Mohindergarh Pole-2 for replacement of Insulators and due to single Mosse conductor configuration of both the ckts of 400kV Chandrapur-Ramagundam which are on ERS towers.	WR-NR / Import of NR and WR-SR/ Import of SR
6	1st December 2017	2nd December 2017 to 31th December	Revised due to commissioning of second unit of BGTPP	ER-NER/NER- ER/Import of NER
7	4th December 2017	05th December 2017 to 11th December 2017	Revised due to single Moose conductor configuration of both the ckts of 400kV Chandrapur-Ramagundam which are on ERS towers.	WR-SR/ Import of SR
8	10 th December	11th December 2017 to 13th December 2017	Revised due to shutdwon of 765kv Phagi-Bhiwani-1(11th and 12th Dec) and Phagi-Bhiwani-2(13th Dec 17)	WR-NR / Import of NR
	2017	12th December 2017 to 13th December 2017	Revised due to single Moose conductor configuration of both the ckts of 400kV Chandrapur-Ramagundam which are on ERS towers.	WR-SR/ Import of SR

ASSUN	MPTIONS IN BASECASE				
				Month : Dec'17	
S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
I	NORTHERN REGION				
1	Punjab	5076	3313	2505	2469
2	Haryana	6779	3330	1533	1533
3	Rajasthan	10005	10899	5097	5121
4	Delhi	3244	1750	755	755
5	Uttar Pradesh	15422	13884	8026	7851
6	Uttarakhand	1899	1518	848	390
7	Himachal Pradesh	1421	1282	195	85
8	Jammu & Kashmir	2496	2504	551	356
9	Chandigarh	175	91	0	0
10	ISGS/IPPs	26	26	17096	8611
	Total NR	46543	38599	36606	27171
II	EASTERN REGION				
1	Bihar	4062	2536	202	181
2	Jharkhand	1290	891	197	190
3	Damodar Valley Corporation	3068	2634	4868	3974
4	Orissa	4265	3347	3232	2292
5	West Bengal	7139	5869	5379	4539
6	Sikkim	88	50	0	0
7	Bhutan	212	216	1434	1434
8	ISGS/IPPs	267	263	11767	8535
	Total ER	20389	15807	27079	21146
Ш	WESTERN REGION				
1	Maharashtra	17837	13518	12629	10871
2	Gujarat	12982	10844	9406	8143
3	Madhya Pradesh	11007	8265	5273	4547
4	Chattisgarh	3620	2188	2520	1990
5	Daman and Diu	312	269	0	0
6	Dadra and Nagar Haveli	635	686	0	0
7	Goa-WR	570	316	0	0
8	ISGS/IPPs	3903	3510	34513	29450
	Total WR	50865	39597	64342	55002

Name of State/Area	Load		Generation	
	Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
SOUTHERN REGION				
Andhra Pradesh	7515	6742	5781	3958
Telangana	7346	5433	4521	2775
Karnataka	10351	8454	5936	4350
Tamil Nadu	13800	11600	6869	5544
Kerala	3743	2200	1400	141
Pondy	387	387	0	0
Goa-SR	87	87	0	0
ISGS/IPPs	0	0	13456	12330
Total SR	43229	34903	37963	29098
NORTH-EASTERN REGION				
Arunachal Pradesh	122	63	0	0
Assam	1057	825	230	140
Manipur	147	87	0	0
Meghalaya	307	203	145	82
Mizoram	89	65	8	8
Nagaland	97	81	8	6
Tripura	197	185	83	82
ISGS/IPPs	160	60	1677	1260
Total NER	2176	1569	2151	1578
Total All India	163444	130721	160633	135488
	Andhra Pradesh Telangana Karnataka Tamil Nadu Kerala Pondy Goa-SR ISGS/IPPS Total SR NORTH-EASTERN REGION Arunachal Pradesh Assam Manipur Meghalaya Mizoram Nagaland Tripura ISGS/IPPs	SOUTHERN REGION Andhra Pradesh 7515 Telangana 7346 Karnataka 10351 Tamil Nadu 13800 Kerala 3743 Pondy 387 Goa-SR 87 ISGS/IPPs 0 Total SR 43229 NORTH-EASTERN REGION 43229 NORTH-EASTERN REGION 122 Assam 1057 Manipur 147 Meghalaya 307 Mizoram 89 Nagaland 97 Tripura 197 ISGS/IPPs 160 Total NER 2176	SOUTHERN REGION Andhra Pradesh 7515 6742 Telangana 7346 5433 Karnataka 10351 8454 Tamil Nadu 13800 11600 Kerala 3743 2200 Pondy 387 387 Goa-SR 87 87 ISGS/IPPs 0 0 Total SR 43229 34903 NORTH-EASTERN REGION 34903 Arunachal Pradesh 122 63 Assam 1057 825 Manipur 147 87 Meghalaya 307 203 Mizoram 89 65 Nagaland 97 81 Tripura 197 185 ISGS/IPPs 160 60 Total NER 2176 1569	SOUTHERN REGION Andhra Pradesh 7515 6742 5781 Telangana 7346 5433 4521 Karnataka 10351 8454 5936 Tamil Nadu 13800 11600 6869 Kerala 3743 2200 1400 Pondy 387 387 0 Goa-SR 87 87 0 ISGS/IPPs 0 0 13456 Total SR 43229 34903 37963 NORTH-EASTERN REGION 34903 37963 Manipur 147 87 0 Meghalaya 307 203 145 Mizoram 89 65 8 Nagaland 97