# National Load Despatch Centre Total Transfer Capability for December 2018

Issue Time: 1100 hrs Issue Date: 10th December 2018 Revision No. 2

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
	1st December	00-06				195	1805		
NR-WR*	2018 to 31st	06-18	2500	500	2000	250	1750		
	December 2018	18-24				195	1805		
WD MD*	1st December	00.24	12250	500	11750	9255	2495		
WR-NR*	2018 to 31st December 2018	00-24	11300**	500	10800**	8305**	2495**		
	1st December	00-06	2000		1800	193	1607		
NR-ER*	2018 to 31st	06-18	2000	200	1800	303	1497		
	December 2018	18-24	2000		1800	193	1607		
ER-NR*	1st December 2018 to 31st December 2018	00-24	5250	300	4950	3867	1083		
W3-ER	1st December 2018 to 31st December 2018	00-24		No limit is being specified.					
ER-W3	1st December 2018 to 31st December 2018	00-24		No limit is being specified.					
		00.05	5200		4700		165		
WR-SR	1st December 2018 to 31st	00-05		500		1525			
WK-SK	December 2018	05-22 22-24	5200 5200	300	4700 4700	4535	165 165		
		22-24	3200		4700		103		
SR-WR*	1st December 2018 to 31st December 2018	00-24				No limit i	s being Specified.		

#### National Load Despatch Centre Total Transfer Capability for December 2018

Issue Date: 10th December 2018 Issue Time: 1100 hrs Revision No. 2

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
	1.5	00-06				2762	1788			
ER-SR	1st December 2018 to 31st	06-18	4800	250	4550	2847	1703			
ZK-5K	December 2018	18-24	4000	230	4330	2762	1788			
SR-ER*	1st December 2018 to 31st December 2018	00-24		No limit is being Specified.						
	1st December	00.17	1350		1305		1080	Ι		
	2018 to 10th	00-17	1060	45	1015	225	790			
	December 2018	17-23 23-24	1350	43	1305	223	1080			
	December 2018	00-07	1350	45	1305	225	1080		Revised TTC due to day time	
	11th December 2018	07-17	900		855		630	-450	shutdown of 400/220kV 315MVA	
ER-NER		17-23	670		625		400	-390	ICT-2 at Misa(PG) for annual	
		23-24	900		855	<del> </del>	630	-450	maintenance	
	12th December	00-17	1350		1305		1080	-430	maintenance	
	2018 to 31st	17-23	1060	45	1015	225	790			
	December 2018	23-24	1350	1305	223	1080				
	1st December	00-17	1880		1835		1835			
	2018 to 10th	17-23	2070	45	2025	0	2025			
	December 2018	23-24	1880	43	1835		1835			
	December 2016	00-07	1880		1835		1835		Revised TTC due to day time	
	11th December	07-17	1530		1485		1485	-350	shutdown of 400/220kV 315MVA	
NER-ER	2018	17-23	1730	45	1685	0	1685	-340	ICT-2 at Misa(PG) for annual	
	2018	23-24	1530		1485	•	1485	-350	maintenance	
	12th December	00-17	1880		1835		1835	-330		
	2018 to 31st	17-23	2070	45	2025	0	2025			
	December 2018	23-24	1880		1835	Ů	1835			
W3 zone Injection	1st December 2018 to 31st 00-24 No limit is being specified (In case of any constraints appearing in the system, W3 zone export would be revised accordingly)									

Note: TTC/ATC of S1-(S2&S3) corridor, Import of S3(Kerala), Import of Punjab and Import of DD & DNH is uploaded on NLDC website under Intra-Regional Section in Monthly ATC.

- 1) S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala
- 2) W3 comprises of the following regional entities:
- a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak
- $f)\ BALCO,\ g)\ Sterlite\ (\#1,3,4),\ h)\ NSPCL,\ i)\ Korba,\ j)\ Sipat,\ k)\ KSK\ Mahanadi,\ L)DB\ Power,\ m)\ KWPCL,\ n)Vandana\ Vidyut\ o)RKM,\ p)GMR\ Raikheda,\ q)Ind\ Barath\ and\ any\ other\ regional\ entity\ generator\ in\ Chhattisgarh$

# The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/Fuel shortage/New units being commissionned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown:

- 1) The TTC value will be revised to normal values after restoration of shutdown.
- 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

<sup>\*</sup> Fifty Percent (50 % ) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

<sup>\*\*</sup>Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.

#### **Simultaneous Import Capability**

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER									
		00-05	16350 15400**		15550 14600**		2403 2403**		
NR	1st December 2018 to 31st	05-18 17500 800	800	16700	13147	3553			
	December 2018	18-24	16550** 16350 15400**		15750** 15550 14600**	12197**	3553** 2403 2403**		
	1st December 2018 to 10th December 2018	00-17 17-23 23-24	1350 1060 1350	45	1305 1015 1305	225	1080 790 1080		
NER	11th December 2018	00-07 07-17 17-23	1350 900 670	45	1305 855 625	225	1080 630 400	-450 -390	Revised TTC due to day time shutdown of 400/220kV 315MVA ICT-2 at Misa(PG) for annual
	12th December 2018 to 31st December 2018	23-24 00-17 17-23 23-24	900 1350 1060 1350	45	855 1305 1015 1305	225	630 1080 790 1080	-450	maintenance
WR									
SR	1st December 2018 to 31st December 2018	06-18 18-22 22-24	10000 10000 10000	750	9250 9250 9250	7297 7382 7297	1953 1868 1953		

<sup>\*</sup> Fifty Percent (50 % ) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Margin in Simultaneous import of NR = A

WR-NR ATC =B ER-NR ATC = C

Margin for WR-NR applicants = A \* B/(B+C)Margin for ER-NR Applicants = A \* C/(B+C)

<sup>\*\*</sup>Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.

<sup>\*</sup> For approving STOA Bilateral transactions, margin available in Simultaneous Import of NR would be apportioned on WR-NR Corridor & ER-NR Corridor in the following ratio:

### **Simultaneous Export Capability**

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
	1st December	00-06	4500		3800	388	3412		
NR*	2018 to 31st	06-18	4300	700	3800	553	3247		
	December 2018	18-24	4500		3800	388	3412		
	1st December	00-17	1880		1835	0	1835		
	2018 to 10th	17-23	2070	45	2025		2025		
	December 2018	23-24	1880		1835		1835		
	11th December 2018	00-07	1880	45	1835	0	1835		Revised TTC due to day
NER		07-17	1530		1485		1485	-350	time shutdown of 400/220kV 315MVA ICT-
NEK		17-23	1730		1685		1685	-340	2 at Misa(PG) for annual
		23-24	1530		1485		1485	-350	maintenance
	12th December	00-17	1880		1835		1835		
	2018 to 31st	17-23	2070	45	2025	0	2025		
	December 2018	23-24	1880		1835		1835		
WR									
SR *	1st December 2018 to 31st December 2018	00-24	No limit is being Specified.						

<sup>\*</sup> Fifty Percent (50 % ) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

## **Limiting Constraints (Corridor wise)**

		<b>Applicable Revisions</b>
Corridor	Constraint	
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak	Rev-0 to 2
WR-NR	(n-1) Contingnecy of 765kV Aligarh-Jhatikara leads to 2500 MW loading on 765kV Aligarh-Greater Noida.	Rev-0 to 2
VV IX-11IX	Frequent tripping of HVDC Champa - Kurukshetra poles	Rev-0 to 2
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli	Rev-0 to 2
ER-NR	1. N-1 contingencies of 400 kv Mejia-Maithon A S/c 2. N-1 contingencies of 400 kv Kahalgaon-Banka S/c 3. N-1 contingencies of 400kV MPL- Maithon S/C	Rev-0 to 2
WR-SR	n-1 contingency of 2x1500 MVA, 765/400 kV ICTs at Vemagiri (PG) will lead to overloading of the second ICT	Rev-0 to 2
and ER-	n-1 contingency of 2x1500 MVA, 765/400 kV ICTs at Vemagiri (PG) will lead to overloading of the second ICT	Rev-1 to 2
SR	Low Voltage at Gazuwaka (East) Bus.	Rev-0 to 2
I HK-NHK	a. (n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa b. High loading of 220 kV Balipara-Sonabil line(200 MW)	Rev-0 to 2
NER-ER	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other ICT at Misa	Rev-0 to 2
W3 zone Injection		Rev-0 to 2

# **Limiting Constraints (Simultaneous)**

			Applicable Revisions
NR	Import	N-1 contingencies of 400 kv Mejia-Maithon A S/c     N-1 contingencies of 400 kv Kahalgaon-Banka S/c     N-1 contingencies of 400kV MPL- Maithon S/c     (n-1) Contingency of 765kV Aligarh-Jhatikara leads to 2500 MW loading on 765kV Aligarh-Greater Noida.  Frequent tripping of HVDC Champa - Kurukshetra poles	Rev-0 to 2
	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak. (n-1) contingency of 400 kV Saranath-Pusauli	Rev-0 to 2  Rev-0 to 2
NER	Import	a. (n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa b. High loading of 220 kV Balipara-Sonabil line(200 MW)	Rev-0 to 2
	Export	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other ICT at Misa	Rev-0 to 2
	Import	n-1 contingency of 2x1500 MVA, 765/400 kV ICTs at Vemagiri (PG) will lead to overloading of the second ICT	Rev-0 to 2
SR		n-1 contingency of 2x1500 MVA, 765/400 kV ICTs at Vemagiri (PG) will lead to overloading of the second ICT	Rev-1 to 2
		Low Voltage at Gazuwaka (East) Bus.	Rev-0 to 2

# National Load Despatch Centre Total Transfer Capability for December 2018

Revision No	Date of Revision	Period of Revision	Reason for Revision/Comment	Corridor Affected
1	26th Nov 2018	Whole month	(i) Revised TTC due to change in: (a) load generation balance and network conditions and (b) change in pattern of inter-regional flow towards NR (ii) Revised STOA margins due to operationalization of: (a) 50 MW LTA from Green Infra Energy Limited to Delhi, (b) 99.9 MW LTA from Green Infra Energy Limited to UP (c) 20 MW LTA from OKWPL to UP discom	WR-NR/ Import of NR
			Revised considering (a) recent commissioning of 765 kV Jharsuguda - Dharamjaygarh 3&4, 765 kV Gadarwara - Warora PS D/C, 765 kV Warora PS - Parli D/C, LILO of Kurnool - Thirvualam D/C at Cuddapah, 400 kV Cuddapah-Hindupur D/C, Salem PS - Madhugiri PS S/C, 765 kV Dharamjaigarh - Champa S/C, 765 kV Champa-Raigarh S/C and 765 kV Sipat- Bilaspur ckt-3 and some other 400 kV lines	WR-SR/ER- SR/Import of SR
2	10th Dec 2018	11th Dec 2018	Revised TTC due to day time shutdown of 400/220kV 315MVA ICT-2 at Misa(PG) for annual maintenance	ER-NER/NER- ER/Import/Exp ort of NER

ASSUM	IPTIONS IN BASECASE				
			N	/lonth : December'	18
S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
1	NORTHERN REGION				
1	Punjab	7121	4573	4602	4217
2	Haryana	7810	5484	2002	2002
3	Rajasthan	11766	12065	7031	6910
4	Delhi	4670	2505	1266	1266
5	Uttar Pradesh	14350	14457	7408	7224
6	Uttarakhand	2083	1622	946	685
7	Himachal Pradesh	1554	739	224	157
8	Jammu & Kashmir	2098	1610	374	306
9	Chandigarh	258	130	0	0
10	ISGS/IPPs	54	53	18132	10730
	Total NR	51764	43237	41985	33497
П	EASTERN REGION				
1	Bihar	3453	2410	247	177
2	Jharkhand	975	812	360	223
3	Damodar Valley Corporation	2946	2756	5213	4002
4	Orissa	3715	2991	2344	2044
5	West Bengal	7102	5253	5189	4516
6	Sikkim	76	82	0	0
7	Bhutan	202	208	643	534
8	ISGS/IPPs	692	643	12290	9301
	Total ER	19160	15155	26285	20796
Ш	WESTERN REGION				
1	Maharashtra	18572	12992	13651	8562
2	Gujarat	13543	11084	8764	8072
3	Madhya Pradesh	12461	8848	4689	4821
4	Chattisgarh	3918	2719	2751	2152
5	Daman and Diu	329	263	0	0
6	Dadra and Nagar Haveli	815	686	0	0
7	Goa-WR	527	325	0	0
8	ISGS/IPPs	4485	3475	38213	30169
	Total WR	54650	40392	68068	53776

S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
IV	SOUTHERN REGION				
1	Andhra Pradesh	8873	6394	6225	4712
2	Telangana	10073	8339	4311	3808
3	Karnataka	9928	6077	6500	4842
4	Tamil Nadu	13905	11359	6899	5799
5	Kerala	3745	2119	1524	153
6	Pondy	340	368	0	0
7	Goa-SR	77	83	0	0
8	ISGS/IPPs	0	0	16984	10353
	Total SR	46942	34739	42443	29668
V	NORTH-EASTERN REGION				
1	Arunachal Pradesh	141	88	0	0
2	Assam	1235	1119	185	142
3	Manipur	179	96	0	0
4	Meghalaya	357	230	169	91
5	Mizoram	98	66	8	8
6	Nagaland	121	77	16	0
7	Tripura	194	120	74	74
8	ISGS/IPPs	156	96	2042	1566
	Total NER	2481	1893	2494	1881
	Total All India	174998	135416	181276	139618