

**National Load Despatch Centre
Total Transfer Capability for December 2018**

Issue Date: 19th December 2018

Issue Time: 0930 hrs

Revision No. 5

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR-WR*	1st December 2018 to 31st December 2018	00-06	2500	500	2000	195	1805		
		06-18				250	1750		
		18-24				195	1805		
WR-NR*	1st December 2018 to 15th December 2018	00-24	12250	500	11750	9255	2495		
			11300**		10800**	8305**	2495**		
	16th December 2018 to 19th December 2018	00-06'	12250	500	11750	9255	2495		
			11300**		10800**	8305**	2495**		
		06-24'	11250	500	10750	9255	1495		
			10300**		9800**	8305**	1495**		
	20th December 2018 to 23th December 2018	00-06'	12250	500	11750	9255	2495		
		11300**	10800**		8305**	2495**			
	06-24'	11250	500	10750	9255	1495	-1000		
		10300**		9800**	8305**	1495**			
24th December 2018 to 31st December 2018	00-24		12250	500	11750	9255	2495		
			11300**		10800**	8305**	2495**		
NR-ER*	1st December 2018 to 31st December 2018	00-06	2000	200	1800	193	1607		
		06-18	2000		1800	303	1497		
		18-24	2000		1800	193	1607		
ER-NR*	1st December 2018 to 31st December 2018	00-24	5250	300	4950	3867	1083		
W3-ER	1st December 2018 to 31st December 2018	00-24	No limit is being specified.						
ER-W3	1st December 2018 to 31st December 2018	00-24	No limit is being specified.						
WR-SR	1st December 2018 to 31st December 2018	00-05	5200	500	4700	4535	165		
		05-22	5200		4700		165		
		22-24	5200		4700		165		
SR-WR *	1st December 2018 to 31st December 2018	00-24	No limit is being Specified.						

National Load Despatch Centre
Total Transfer Capability for December 2018

Issue Date: 19th December 2018

Issue Time: 0930 hrs

Revision No. 5

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
ER-SR	1st December 2018 to 31st December 2018	00-06	4800	250	4550	2762	1788			
		06-18				2847	1703			
		18-24				2762	1788			
SR-ER *	1st December 2018 to 31st December 2018	00-24	No limit is being Specified.							
ER-NER	1st December 2018 to 10th December 2018	00-17	1350	45	1305	225	1080			
		17-23	1060		1015		790			
		23-24	1350		1305		1080			
	11th December 2018	00-07	1350	45	1305	225	1080			
		07-17	900		855		630			
		17-23	670		625		400			
	12th December 2018 to 18th December 2018	00-17	1350	45	1305	225	1080			
		17-23	1060		1015		790			
		23-24	1350		1305		1080			
	19th December 2018	00-07	1350	45	1305	225	1080			
		07-17	1220		1175		950			
		17-23	900		855		630			
	20th December 2018	00-07'	1350	45	1305	225	1080		Revised due to shutdown of 400 kV Misa- Balipara ckt I for Replacement of Y-Ph LA at Balipara Substation	
		07-17'	900		855		630	-450		
		17-23	670		625		400	-390		
	21st December 2018 to 31st December 2018	00-17	1350	45	1305	225	1080			
		17-23	1060		1015		790			
		23-24	1350		1305		1080			
	NER-ER	1st December 2018 to 10th December 2018	00-17	1880	45	1835	0	1835		
			17-23	2070		2025		2025		
			23-24	1880		1835		1835		
11th December 2018		00-07	1880	45	1835	0	1835			
		07-17	1530		1485		1485			
		17-23	1730		1685		1685			
12th December 2018 to 18th December 2018		00-17	1880	45	1835	0	1835			
		17-23	2070		2025		2025			
		23-24	1880		1835		1835			
19th December 2018		00-07	1880	45	1835	0	1835			
		07-17	1700		1655		1655			
		17-23	1860		1815		1815			
20th December 2018		00-07'	1880	45	1835	0	1835		Revised due to shutdown of 400 kV Misa- Balipara ckt I for Replacement of Y-Ph LA at Balipara Substation	
		07-17'	1530		1485		1485	-350		
		17-23	1730		1685		1685	-340		
21st December 2018 to 31st December 2018		00-17	1880	45	1835	0	1835			
		17-23	2070		2025		2025			
		23-24	1880		1835		1835			
W3 zone Injection	1st December 2018 to 31st December 2018	00-24	No limit is being specified (In case of any constraints appearing in the system, W3 zone export would be revised accordingly)							

Note: TTC/ATC of S1-(S2&S3) corridor, Import of S3(Kerala), Import of Punjab and Import of DD & DNH is uploaded on NLDC website under Intra-Regional Section in Monthly ATC.

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

**Considering 400 kV Rihand stage-III - Vindhyaachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.

1) S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala

2) W3 comprises of the following regional entities :

a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCCL, n)Vandana Vidut o)RKM, p)GMR Raikheda, q)Ind Barath and any other regional entity generator in Chhattisgarh

**National Load Despatch Centre
Total Transfer Capability for December 2018**

Issue Date: 19th December 2018

Issue Time: 0930 hrs

Revision No. 5

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
-----------------	-------------	--------------------------	--	---------------------------	--	---	---	--	-----------------

The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown :

- 1) The TTC value will be revised to normal values after restoration of shutdown.
- 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
ER										
NR	1st December 2018 to 15th December 2018	00-05	16350	800	15550	13147	2403			
			15400**		14600**		2403**			
		05-18	17500		16700		3553			
			16550**		15750**		12197**	3553**		
	18-24	16350	15550		2403					
		15400**	14600**		2403**					
	16th December 2018 to 19th December 2018	00-05	16350		800	15550	13147	2403		
			15400**			14600**		2403**		
		05-06	17500	16700		3553				
			16550**	15750**		12197**		3553**		
	06-18	16050	15250	2103						
		15100**	14300**	2103**						
	18-24	15000	14200	1053						
		14050**	13250**	1053**						
	20th December 2018 to 23th December 2018	00-05	16350	800	15550	13147	2403			
			15400**		14600**		2403**			
		05-06	17500		16700		3553			
			16550**		15750**		12197**	3553**		
	06-18	16050	15250		2103					
		15100**	14300**		2103**					
	18-24	15000	14200		1053					
		14050**	13250**		1053**					
	24th December 2018 to 31st December 2018	00-05	16350	800	15550	13147	2403			
			15400**		14600**		2403**			
05-18		17500	16700		3553					
		16550**	15750**		12197**		3553**			
18-24	16350	15550	2403							
	15400**	14600**	2403**							

NER	1st December 2018 to 10th December 2018	00-17	1350	45	1305	225	1080		
		17-23	1060		1015		790		
		23-24	1350		1305		1080		
	11th December 2018	00-07	1350	45	1305	225	1080		
		07-17	900		855		630		
		17-23	670		625		400		
	12th December 2018 to 18th December 2018	23-24	900	45	855	225	630		
		00-17	1350		1305		1080		
		17-23	1060		1015		790		
	19th December 2018	23-24	1350	45	1305	225	1080		
		00-07	1350		1175		950		
		07-17	1220		855		630		
	20th December 2018	17-23	900	45	1175	225	950		Revised due to shutdown of 400 kV Misa- Balipara ckt I for Replacement of Y-Ph LA at Balipara Substation
		23-24	1220		1175		950		
		00-07'	1350		1305		1080		
		07-17'	900		855		630		
	21st December 2018 to 31st December 2018	17-23	670	45	625	225	400		
		23-24	900		855		630		
00-17		1350	1305		1080				
17-23		1060	1015		790				
WR									
SR	1st December 2018 to 31st December 2018	06-18	10000	750	9250	7297	1953		
		18-22	10000		9250	7382	1868		
		22-24	10000		9250	7297	1953		

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

**Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.

* For approving STOA Bilateral transactions, margin available in Simultaneous Import of NR would be apportioned on WR-NR Corridor & ER-NR Corridor in the following ratio:

Margin in Simultaneous import of NR = A

WR-NR ATC = B

ER-NR ATC = C

Margin for WR-NR applicants = $A * B / (B + C)$

Margin for ER-NR Applicants = $A * C / (B + C)$

Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR*	1st December 2018 to 31st December 2018	00-06	4500	700	3800	388	3412		
		06-18			3800	553	3247		
		18-24			3800	388	3412		
NER	1st December 2018 to 10th December 2018	00-17	1880	45	1835	0	1835		
		17-23	2070		2025		2025		
		23-24	1880		1835		1835		
	11th December 2018	00-07	1880	45	1835	0	1835		
		07-17	1530		1485		1485		
		17-23	1730		1685		1685		
		23-24	1530		1485		1485		
	12th December 2018 to 18th December 2018	00-17	1880	45	1835	0	1835		
		17-23	2070		2025		2025		
		23-24	1880		1835		1835		
	19th December 2018	00-07	1880	45	1835	0	1835		
		07-17	1700		1655		1655		
		17-23	1860		1815		1815		
		23-24	1700		1655		1655		
	20th December 2018	00-07'	1880	45	1835	0	1835		Revised due to shutdown of 400 kV Misa- Balipara ckt I for Replacement of Y-Ph LA at Balipara Substation
		07-17'	1530		1485		1485	-350	
		17-23	1730		1685		1685	-340	
		23-24	1530		1485		1485	-350	
	21st December 2018 to 31st December 2018	00-17	1880	45	1835	0	1835		
		17-23	2070		2025		2025		
		23-24	1880		1835		1835		
	WR								
	SR *	1st December 2018 to 31st December 2018	00-24	No limit is being Specified.					

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Limiting Constraints (Corridor wise)

Corridor	Constraint	Applicable Revisions
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak	Rev-0 to 5
WR-NR	(n-1) Contingency of 765kV Aligarh-Jhatikara leads to 2500 MW loading on 765kV Aligarh-Greater Noida.	Rev-0 to 2
	(n-1) Contingency of 765/400kV ICT-1 at Agra leads to 1500 MW loading on other 765kV ICT at Agra.	Rev-3 to 5
	Frequent tripping of HVDC Champa - Kurukshetra poles	Rev-0 to 5
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli	Rev-0 to 5
ER-NR	1. N-1 contingencies of 400 kv Mejia-Maithon A S/c 2. N-1 contingencies of 400 kv Kahalgaon-Banka S/c 3. N-1 contingencies of 400kV MPL- Maithon S/C	Rev-0 to 5
WR-SR and ER-SR	n-1 contingency of 2x1500 MVA, 765/400 kV ICTs at Vemagiri (PG) will lead to overloading of the second ICT	Rev-0 to 5
	n-1 contingency of 2x1500 MVA, 765/400 kV ICTs at Vemagiri (PG) will lead to overloading of the second ICT	Rev-1 to 5
	Low Voltage at Gazuwaka (East) Bus.	Rev-0 to 5
ER-NER	a. (n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa b. High loading of 220 kV Balipara-Sonabil line(200 MW)	Rev-0 to 5
NER-ER	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other ICT at Misa	Rev-0 to 5
W3 zone Injection	---	Rev-0 to 5

Limiting Constraints (Simultaneous)

		Applicable Revisions	
NR	Import	1. N-1 contingencies of 400 kv Mejia-Maithon A S/c 2. N-1 contingencies of 400 kv Kahalgaon-Banka S/c 3. N-1 contingencies of 400kV MPL- Maithon S/c	Rev-0 to 5
		(n-1) Contingency of 765kV Aligarh-Jhatikara leads to 2500 MW loading on 765kV Aligarh-Greater Noida.	Rev-0 to 2
		(n-1) Contingency of 765/400kV ICT-1 at Agra leads to 1500 MW loading on other 765kV ICT at Agra.	Rev-3 to 5
	Export	Frequent tripping of HVDC Champa - Kurukshetra poles	Rev-0 to 5
		(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak. (n-1) contingency of 400 kV Saranath-Pusauli	Rev-0 to 5
NER	Import	a. (n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa b. High loading of 220 kV Balipara-Sonabil line(200 MW)	Rev-0 to 5
	Export	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other ICT at Misa	Rev-0 to 5
SR	Import	n-1 contingency of 2x1500 MVA, 765/400 kV ICTs at Vemagiri (PG) will lead to overloading of the second ICT	Rev-0 to 5
		n-1 contingency of 2x1500 MVA, 765/400 kV ICTs at Vemagiri (PG) will lead to overloading of the second ICT	Rev-1 to 5
		Low Voltage at Gazuwaka (East) Bus.	Rev-0 to 5

**National Load Despatch Centre
Total Transfer Capability for December 2018**

Revision No	Date of Revision	Period of Revision	Reason for Revision/Comment	Corridor Affected
1	26th Nov 2018	Whole month	(i) Revised TTC due to change in: (a) load generation balance and network conditions and (b) change in pattern of inter-regional flow towards NR (ii) Revised STOA margins due to operationalization of : (a) 50 MW LTA from Green Infra Energy Limited to Delhi, (b) 99.9 MW LTA from Green Infra Energy Limited to UP (c) 20 MW LTA from OKWPL to UP discom	WR-NR/ Import of NR
			Revised considering (a) recent commissioning of 765 kV Jharsuguda - Dharamjaygarh 3&4, 765 kV Gadarwara - Warora PS D/C, 765 kV Warora PS - Parli D/C, LILO of Kurnool - Thirvualam D/C at Cuddapah, 400 kV Cuddapah-Hindupur D/C, Salem PS - Madhugiri PS S/C, 765 kV Dharamjaigarh - Champa S/C, 765 kV Champa-Raigarh S/C and 765 kV Sipat-Bilaspur ckt-3 and some other 400 kV lines	WR-SR/ER-SR/ Import of SR
2	10th Dec 2018	11th Dec 2018	Revised TTC due to day time shutdown of 400/220kV 315MVA ICT-2 at Misa(PG) for annual maintenance	ER-NER/NER-ER/ Import/Export of NER
3	14th Dec 2018	16th Dec 2018 to 19th Dec 2018	Revised due to shutdown of HVDC Mundra-Mohindergarh Pole-1	WR-NR/ Import of NR
4	18th Dec 2018	19th Dec 2018	Revised TTC due to day time shutdown of 400 kV Bongaigaon - Azara for dismantling the failed Line Reactor at Bongaigaon S/s	ER-NER/NER-ER/ Import/Export of NER
5	19th Dec 2018	20th Dec 2018 to 23th Dec 2018	Revised due to shutdown of HVDC Mundra-Mohindergarh Pole-2	WR-NR/ Import of NR
		20th Dec 2018	Revised due to shutdown of 400 kV Misa- Balipara ckt I for Replacement of Y-Ph LA at Balipara Substation	ER-NER/NER-ER/ Import/Export of NER

ASSUMPTIONS IN BASECASE					
				Month : December'18	
S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
I	NORTHERN REGION				
1	Punjab	7121	4573	4602	4217
2	Haryana	7810	5484	2002	2002
3	Rajasthan	11766	12065	7031	6910
4	Delhi	4670	2505	1266	1266
5	Uttar Pradesh	14350	14457	7408	7224
6	Uttarakhand	2083	1622	946	685
7	Himachal Pradesh	1554	739	224	157
8	Jammu & Kashmir	2098	1610	374	306
9	Chandigarh	258	130	0	0
10	ISGS/IPPs	54	53	18132	10730
	Total NR	51764	43237	41985	33497
II	EASTERN REGION				
1	Bihar	3453	2410	247	177
2	Jharkhand	975	812	360	223
3	Damodar Valley Corporation	2946	2756	5213	4002
4	Orissa	3715	2991	2344	2044
5	West Bengal	7102	5253	5189	4516
6	Sikkim	76	82	0	0
7	Bhutan	202	208	643	534
8	ISGS/IPPs	692	643	12290	9301
	Total ER	19160	15155	26285	20796
III	WESTERN REGION				
1	Maharashtra	18572	12992	13651	8562
2	Gujarat	13543	11084	8764	8072
3	Madhya Pradesh	12461	8848	4689	4821
4	Chattisgarh	3918	2719	2751	2152
5	Daman and Diu	329	263	0	0
6	Dadra and Nagar Haveli	815	686	0	0
7	Goa-WR	527	325	0	0
8	ISGS/IPPs	4485	3475	38213	30169
	Total WR	54650	40392	68068	53776

S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
IV	SOUTHERN REGION				
1	Andhra Pradesh	8873	6394	6225	4712
2	Telangana	10073	8339	4311	3808
3	Karnataka	9928	6077	6500	4842
4	Tamil Nadu	13905	11359	6899	5799
5	Kerala	3745	2119	1524	153
6	Pondy	340	368	0	0
7	Goa-SR	77	83	0	0
8	ISGS/IPPs	0	0	16984	10353
	Total SR	46942	34739	42443	29668
V	NORTH-EASTERN REGION				
1	Arunachal Pradesh	141	88	0	0
2	Assam	1235	1119	185	142
3	Manipur	179	96	0	0
4	Meghalaya	357	230	169	91
5	Mizoram	98	66	8	8
6	Nagaland	121	77	16	0
7	Tripura	194	120	74	74
8	ISGS/IPPs	156	96	2042	1566
	Total NER	2481	1893	2494	1881
	Total All India	174998	135416	181276	139618