

**National Load Despatch Centre
Total Transfer Capability for December 2021**

Issue Time: 1700 hrs

Revision No. 21

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR-WR*	1st December 2021 to 31st December 2021	00-06	2500	500	2000	628	1372		
		06-18				1856	144		
		18-24				628	1372		
WR-NR*	1st December 2021	00-06	19500 18550**	1000	18500 17550**	11433 10483**	7067		
		06-09	17800 16850**	1000	16800 15850**	11822 10872*	4978		
		09-18	17500 16550**	1000	16500 15550**	11822 10872*	4678		
		18-21	17500 16550**	1000	16500 15550**	11433 10483**	5067		
		21-24	19200 18250**	1000	18200 17250**	11433 10483**	6767		
WR-NR*	2nd December 2021	00-06	19500 18550**	1000	18500 17550**	11433 10483**	7067		
		06-09	17800 16850**	1000	16800 15850**	11822 10872*	4978		
		09-18	17500 16550**	1000	16500 15550**	11822 10872*	4678		
		18-21	17500 16550**	1000	16500 15550**	11433 10483**	5067		
		21-24	19200 18250**	1000	18200 17250**	11433 10483**	6767		
WR-NR*	3rd December 2021	00-06	19500 18550**	1000	18500 17550**	11433 10483**	7067		
		06-09	17800 16850**	1000	16800 15850**	11822 10872*	4978		
		09-18	17250 16300**	1000	16250 15300**	11822 10872*	4428		
		18-21	17250 16300**	1000	16250 15300**	11433 10483**	4817		
		21-24	18950 18000**	1000	17950 17000**	11433 10483**	6517		

**National Load Despatch Centre
Total Transfer Capability for December 2021**

Issue Time: 1700 hrs

Revision No. 21

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
WR-NR*	4th December 2021	00-06	19500 18550**	1000	18500 17550**	11433 10483**	7067		
		06-08	17800 16850**	1000	16800 15850**	11822 10872*	4978		
		08-18	17250 16300**	1000	16250 15300**	11822 10872*	4428		
		18-21	17250 16300**	1000	16250 15300**	11433 10483**	4817		
		21-24	18950 18000**	1000	17950 17000**	11433 10483**	6517		
WR-NR*	5th December 2021	00-06	19500 18550**	1000	18500 17550**	11433 10483**	7067		
		06-08	17800 16850**	1000	16800 15850**	11822 10872*	4978		
		08-18	17250 16300**	1000	16250 15300**	11822 10872*	4428		
		18-21	17250 16300**	1000	16250 15300**	11433 10483**	4817		
		21-24	18950 18000**	1000	17950 17000**	11433 10483**	6517		
WR-NR*	6th December 2021	00-06	19500 18550**	1000	18500 17550**	11433 10483**	7067		
		06-08	17800 16850**	1000	16800 15850**	11822 10872*	4978		
		08-18	16200 15250**	1000	15200 14250**	11822 10872*	3378		
		18-21	16200 15250**	1000	15200 14250**	11433 10483**	3767		
		21-24	17900 16950**	1000	16900 15950**	11433 10483**	5467		
WR-NR*	7th December 2021	00-06	19500 18550**	1000	18500 17550**	11433 10483**	7067		
		06-08	17800 16850**	1000	16800 15850**	11822 10872*	4978		
		08-18	16200 15250**	1000	15200 14250**	11822 10872*	3378		
		18-21	16200 15250**	1000	15200 14250**	11433 10483**	3767		
		21-24	17900 16950**	1000	16900 15950**	11433 10483**	5467		

**National Load Despatch Centre
Total Transfer Capability for December 2021**

Issue Time: 1700 hrs

Revision No. 21

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
WR-NR*	8th December 2021	00-06	19500 18550**	1000	18500 17550**	11433 10483**	7067		
		06-08	17800 16850**	1000	16800 15850**	11822 10872*	4978		
		08-18	17350 16400**	1000	16350 15400**	11822 10872*	4528		
		18-21	17350 16400**	1000	16350 15400**	11433 10483**	4917		
		21-24	19050 18100**	1000	18050 17100**	11433 10483**	6617		
WR-NR*	9th December 2021 to 12th December 2021	00-06	19500 18550**	1000	18500 17550**	11433 10483**	7067		
		06-18	17800 16850**	1000	16800 15850**	11822 10872*	4978		
		18-21	17800 16850**	1000	16800 15850**	11433 10483**	5367		
		21-24	19500 18550**	1000	18500 17550**	11433 10483**	7067		
WR-NR*	13th December 2021	00-06	19500 18550**	1000	18500 17550**	11433 10483**	7067		
		06-08	17800 16850**	1000	16800 15850**	11822 10872*	4978		
		08-18	17100 16150**	1000	16100 15150**	11822 10872*	4278		
		18-21	17100 16150**	1000	16100 15150**	11433 10483**	4667		
		21-24	18700 17850**	1000	17700 16850**	11433 10483**	6367		

**National Load Despatch Centre
Total Transfer Capability for December 2021**

Issue Time: 1700 hrs

Revision No. 21

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
WR-NR*	14th December 2021	00-06	19500 18550**	1000	18500 17550**	11433 10483**	7067		
		06-08	17800 16850**	1000	16800 15850**	11822 10872*	4978		
		08-18	17100 16150**	1000	16100 15150**	11822 10872*	4278		
		18-21	17100 16150**	1000	16100 15150**	11433 10483**	4667		
		21-24	18700 17850**	1000	17700 16850**	11433 10483**	6367		
WR-NR*	15th December 2021	00-06	19500 18550**	1000	18500 17550**	11433 10483**	7067		
		06-08	17800 16850**	1000	16800 15850**	11822 10872*	4978		
		08-18	17100 16150**	1000	16100 15150**	11822 10872*	4278		
		18-21	17100 16150**	1000	16100 15150**	11433 10483**	4667		
		21-24	18700 17850**	1000	17700 16850**	11433 10483**	6367		
WR-NR*	16th December 2021	00-06	19500 18550**	1000	18500 17550**	11433 10483**	7067		
		06-08	17800 16850**	1000	16800 15850**	11822 10872*	4978		
		08-18	17100 16150**	1000	16100 15150**	11822 10872*	4278		
		18-21	17100 16150**	1000	16100 15150**	11433 10483**	4667		
		21-24	18700 17850**	1000	17700 16850**	11433 10483**	6367		
WR-NR*	17th December 2021 to 31st December 2021	00-06	19500 18550**	1000	18500 17550**	11433 10483**	7067		
		06-18	17800 16850**	1000	16800 15850**	11822 10872*	4978		
		18-21	17800 16850**	1000	16800 15850**	11433 10483**	5367		
		21-24	19500 18550**	1000	18500 17550**	11433 10483**	7067		

**National Load Despatch Centre
Total Transfer Capability for December 2021**

Issue Time: 1700 hrs

Revision No. 21

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR-ER*	1st December 2021 to 31st December 2021	00-06	2000	200	1800	93	1707		
		06-18	2000		1800	1525	275		
		18-24	2000		1800	93	1707		
ER-NR*	1st December 2021	00-06	5900	400	5500	4333	1167		
		06-09	7600	400	7200	4333	2867		
		09-21	7450	400	7050	4333	2717		
		21-24	5750	400	5350	4333	1017		
ER-NR*	2nd December 2021	00-06	5900	400	5500	4333	1167		
		06-09	7600	400	7200	4333	2867		
		09-21	7450	400	7050	4333	2717		
		21-24	5750	400	5350	4333	1017		
ER-NR*	3rd December 2021	00-06	5900	400	5500	4333	1167		
		06-09	7600	400	7200	4333	2867		
		09-21	7450	400	7050	4333	2717		
		21-24	5750	400	5350	4333	1017		
ER-NR*	4th December 2021	00-06	5900	400	5500	4333	1167		
		06-08	7600	400	7200	4333	2867		
		08-21	7450	400	7050	4333	2717		
		21-24	5750	400	5350	4333	1017		
ER-NR*	5th December 2021	00-06	5900	400	5500	4333	1167		
		06-08	7600	400	7200	4333	2867		
		08-21	7450	400	7050	4333	2717		
		21-24	5750	400	5350	4333	1017		
ER-NR*	6th December 2021	00-06	5900	400	5500	4333	1167		
		06-08	7600	400	7200	4333	2867		
		08-21	7300	400	6900	4333	2567		
		21-24	5600	400	5200	4333	867		
ER-NR*	7th December 2021	00-06	5900	400	5500	4333	1167		
		06-08	7600	400	7200	4333	2867		
		08-21	7300	400	6900	4333	2567		
		21-24	5600	400	5200	4333	867		
ER-NR*	8th December 2021	00-06	5900	400	5500	4333	1167		
		06-08	7600	400	7200	4333	2867		
		08-21	7350	400	6950	4333	2617		
		21-24	5650	400	5250	4333	917		

**National Load Despatch Centre
Total Transfer Capability for December 2021**

Issue Time: 1700 hrs

Revision No. 21

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
ER-NR*	9th December 2021 to 12th December 2021	00-06	5900	400	5500	4333	1167			
		06-21	7600	400	7200	4333	2867			
		21-24	5900	400	5500	4333	1167			
ER-NR*	13th December 2021	00-06	5900	400	5500	4333	1167			
		06-08	7600	400	7200	4333	2867			
		08-21	7400	400	7000	4333	2667			
		21-24	5700	400	5300	4333	967			
ER-NR*	14th December 2021	00-06	5900	400	5500	4333	1167			
		06-08	7600	400	7200	4333	2867			
		08-21	7400	400	7000	4333	2667			
		21-24	5700	400	5300	4333	967			
ER-NR*	15th December 2021	00-06	5900	400	5500	4333	1167			
		06-08	7600	400	7200	4333	2867			
		08-21	7400	400	7000	4333	2667			
		21-24	5700	400	5300	4333	967			
ER-NR*	16th December 2021	00-06	5900	400	5500	4333	1167			
		06-08	7600	400	7200	4333	2867			
		08-21	7400	400	7000	4333	2667			
		21-24	5700	400	5300	4333	967			
ER-NR*	17th December 2021 to 31st December 2021	00-06	5900	400	5500	4333	1167			
		06-21	7600	400	7200	4333	2867			
		21-24	5900	400	5500	4333	1167			
W3-ER	1st December 2021 to 31st December 2021	00-24	No limit is being specified.							
ER-W3	1st December 2021 to 31st December 2021	00-24	No limit is being specified.							
WR-SR [^]	1st December 2021 to 4th December 2021	00-05	10350	650	9700	4018	5682			
		05-22	10350		9700		5682			
		22-24	10350		9700		5682			
		00-09:30	10350		9700		5682			
WR-SR [^]	5th December 2021	09:30-22	7600	650	6950	4018	2932			
		22-24	7600		6950		2932			
		00-05	10350		9700		5682			
WR-SR [^]	6th December 2021 to 7th December 2021	05-22	10350	650	9700	4018	5682			
		22-24	10350		9700		5682			
		00-05	10350		9700		5682			
		05-08	10350		9700		5682			
WR-SR [^]	8th December 2021	08-22	9800	650	9150	4018	5132			
		22-24	9800		9150		5132			
		00-05	9800		9150		5132			
		05-22	9800		9150		5132			
WR-SR [^]	9th December 2021 to 11th December 2021	22-24	9800	650	9150	4018	5132			
		00-06	9800		9150		5132			
		06-22	6000		5350		1332			
WR-SR [^]	12th December 2021	22-24	6000	650	5350	4018	1332			
		00-06	6000		5350		1332			

**National Load Despatch Centre
Total Transfer Capability for December 2021**

Issue Time: 1700 hrs

Revision No. 21

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments		
WR-SR [^]	13th December 2021	00-07	9800	650	9150	4018	5132				
		07-22	9450		8800		4782				
		22-24	9450		8800		4782				
WR-SR [^]	14th December 2021 to 15th December 2021	00-05	9450	650	8800	4018	4782				
		05-22	9450		8800		4782				
		22-24	9450		8800		4782				
WR-SR [^]	16th December 2021	00-13	9450	650	8800	4018	4782				
		13-18	7650		7000		2982				
		18-24	7650		7000		2982				
WR-SR [^]	17th December 2021 to 24th December 2021	00-05	9450	650	8800	4018	4782				
		05-22	9450		8800		4782				
		22-24	9450		8800		4782				
WR-SR [^]	25th December 2021 to 31st December 2021	00-05	10000	650	9350	4018	5332				
		05-22	10000		9350		5332				
		22-24	10000		9350		5332				
SR-WR *	1st December 2021 to 7th December 2021	00-24	6600	400	6200	983	5217				
SR-WR *	8th December 2021	00-08	6600	400	6200	983	5217				
		08-24	5800		5400		4417				
SR-WR *	9th December 2021 to 11th December 2021	00-24	5800	400	5400	983	4417				
SR-WR *	12th December 2021	00-06	5800	400	5400	983	4417				
		06-24	3700		3300		2317				
SR-WR *	13th December 2021 to 15th December 2021	00-24	5800	400	5400	983	4417				
SR-WR *	16th December 2021	00-13	5800	400	5400	983	4417				
		13-24	5300		4900		3917				
SR-WR *	17th December 2021 to 24th December 2021	00-24	5800	400	5400	983	4417				
SR-WR *	25th December 2021 to 31st December 2021	00-24	6600	400	6200	983	5217				
ER-SR [^]	1st December 2021 to 4th December 2021	00-06	5800	350	5450	2675	2775				
		06-18					2760	2690			
		18-24					2675	2775			
ER-SR [^]	5th December 2021	00-06	5800	350	5450	2675	2775				
		06-09:30					5450	2760		2690	
		09:30-18					5350	5000		2760	2240
		18-24					5350	5000		2675	2325

**National Load Despatch Centre
Total Transfer Capability for December 2021**

Issue Time: 1700 hrs

Revision No. 21

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER-SR ^Δ	6th December 2021 to 09th December 2021	00-06	5800	350	5450	2675	2775		
		06-18				2760	2690		
		18-24				2675	2775		
ER-SR ^Δ	10th December 2021	00-06	5800	350	5450	2675	2775		
		06-08	5800		5450	2760	2690		
		08-18	5350		5000	2760	2240		
		18-24	5350		5000	2675	2325		
ER-SR ^Δ	11th December 2021	00-06	5800	350	5450	2675	2775		
		06-08	5800		5450	2760	2690		
		08-18	5350		5000	2760	2240		
		18-24	5350		5000	2675	2325		
ER-SR ^Δ	12th December 2021	00-06	5800	350	5450	2675	2775		
		06-18				2760	2690		
		18-24				2675	2775		
ER-SR ^Δ	13th December 2021	00-06	5800	350	5450	2675	2775		
		06-07	5800		5450	2760	2690		
		07-18	5750		5400	2760	2640		
		18-24	5750		5400	2675	2725		
ER-SR ^Δ	14th December 2021 to 15th December 2021	00-06	5750	350	5400	2675	2725		
		06-18				2760	2640		
		18-24				2675	2725		
ER-SR ^Δ	16th December 2021	00-06	5750	350	5400	2675	2725		
		06-13	5750		5400	2760	2640		
		13-18	5450		5100	2760	2340		
		18-24	5450		5100	2675	2425		
ER-SR ^Δ	17th December 2021 to 31st December 2021	00-06	5750	350	5400	2675	2725		
		06-18				2760	2640		
		18-24				2675	2725		
SR-ER *	1st December 2021 to 31st December 2021	00-24	No limit is being Specified.						

**National Load Despatch Centre
Total Transfer Capability for December 2021**

Issue Time: 1700 hrs

Revision No. 21

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
ER-NER*	1st December 2021 to 16th December 2021	00-02	1695	60	1635	455	1180			
		02-07	1695		1635	455	1180			
		07-12	1695		1635	455	1180			
		12-17	1695		1635	455	1180			
		17-21	1275		1215	455	760			
		21-24	1695		1635	455	1180			
ER-NER*	17th December 2021 to 18th December 2021	00-02	1865	60	1805	455	1350	170	Four units of Kameng HEP (4x150 MW) are under force outage	
		02-07	1865		1805	455	1350			
		07-12	1865		1805	455	1350			
		12-17	1865		1805	455	1350			
		17-21	1615		1555	455	1100			340
		21-24	1865		1805	455	1350			170
ER-NER*	19th December 2021 to 31st December 2021	00-02	1695	60	1635	455	1180			
		02-07	1695		1635	455	1180			
		07-12	1695		1635	455	1180			
		12-17	1695		1635	455	1180			
		17-21	1275		1215	455	760			
		21-24	1695		1635	455	1180			
NER-ER*	1st December 2021 to 16th December 2021	00-02	2915	60	2855	81	2774			
		02-07	2915		2855	81	2774			
		07-12	2915		2855	81	2774			
		12-17	2915		2855	81	2774			
		17-21	2800		2740	81	2659			
		21-24	2915		2855	81	2774			
NER-ER*	17th December 2021 to 18th December 2021	00-02	2315	60	2255	81	2174	-600	Four units of Kameng HEP (4x150 MW) are under force outage	
		02-07	2315		2255	81	2174			
		07-12	2315		2255	81	2174			
		12-17	2315		2255	81	2174			
		17-21	2200		2140	81	2059			
		21-24	2315		2255	81	2174			
NER-ER*	19th December 2021 to 31st December 2021	00-02	2915	60	2855	81	2774			
		02-07	2915		2855	81	2774			
		07-12	2915		2855	81	2774			
		12-17	2915		2855	81	2774			
		17-21	2800		2740	81	2659			
		21-24	2915		2855	81	2774			

W3 zone Injection	1st December 2021 to 31st December 2021	00-24	No limit is being specified (In case of any constraints appearing in the system, W3 zone export would be revised accordingly)						
--------------------------	---	-------	---	--	--	--	--	--	--

Note: TTC/ATC of S1-(S2&S3) corridor, Import of S3(Kerala), Import of Punjab and Import of DD & DNH is uploaded on NLDC website under Intra-Regional Section in Monthly ATC.

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

**Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR

1) S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala

2) W3 comprises of the following regional entities :

a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak

f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPC, n)Vandana Vidut o)RKM, p)GMR Raikhe, q)Ind Barath and any other regional entity generator in Chhattisgarh

The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown :

1) The TTC value will be revised to normal values after restoration of shutdown.

2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section

^Though 2X315 MVA, 400/220 kV ICTs at Maradam are N-1 non-compliant, the TTC of WR-SR and ER-SR corridor has not been restricted due to the same considering that this aspect will be managed by AP SLDC through appropriate

^In case of drawl of Karnataka beyond 3800 MW, the voltages in Bengaluru area are observed to be critically low. This issue may be taken care of by Karnataka SLDC by taking appropriate measures.

SR-WR TTC/ATC figures have been calculated considering 01 unit (800 MW) at Kudgi TPS in service. The figures are subject to change with change in generation at Kudgi TPS.

WR-NR/Import of NR TTC has been calculated considering generation at Pariccha TPS as 350 MW. TTC figures are subject to change with significant change in generation at Pariccha TPS.

Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR	1st December 2021	00-06	25400	1400	24000	15766	8234		
			24450**		23050**	14816**			
		06-09	25400		24000	16155	7845		
			24450**		23050**	15205**			
		09-17	24950		23550	16155	7395		
			24000**		22600**	15205**			
		17-18	24950		23550	16155	7395		
			24000**		22600**	15205**			
		18-24	24950		23550	15766	7784		
			24000**		22600**	14816**			
NR	2nd December 2021	00-06	25400	1400	24000	15766	8234		
			24450**		23050**	14816**			
		06-09	25400		24000	16155	7845		
			24450**		23050**	15205**			
		09-17	24950		23550	16155	7395		
			24000**		22600**	15205**			
		17-18	24950		23550	16155	7395		
			24000**		22600**	15205**			
		18-24	24950		23550	15766	7784		
			24000**		22600**	14816**			
NR	3rd December 2021	00-06	25400	1400	24000	15766	8234		
			24450**		23050**	14816**			
		06-09	25400		24000	16155	7845		
			24450**		23050**	15205**			
		09-17	24700		23300	16155	7145		
			23750**		22350**	15205**			
		17-18	24700		23300	16155	7145		
			23750**		22350**	15205**			
		18-24	24700		23300	15766	7534		
			23750**		22350**	14816**			

NR	4th December 2021	00-06	25400	1400	24000	15766	8234	
			24450**		23050**	14816**		
		06-08	25400		24000	16155	7845	
			24450**		23050**	15205**		
		08-09	24700		23300	16155	7145	
			23750**		22350**	15205**		
		09-17	24700		23300	16155	7145	
23750**	22350**		15205**					
17-18	24700	23300	16155	7145				
	23750**	22350**	15205**					
18-24	24700	23300	15766	7534				
	23750**	22350**	14816**					
NR	5th December 2021	00-06	25400	1400	24000	15766	8234	
			24450**		23050**	14816**		
		06-08	25400		24000	16155	7845	
			24450**		23050**	15205**		
		08-09	24700		23300	16155	7145	
			23750**		22350**	15205**		
		09-17	24700		23300	16155	7145	
23750**	22350**		15205**					
17-18	24700	23300	16155	7145				
	23750**	22350**	15205**					
18-24	24700	23300	15766	7534				
	23750**	22350**	14816**					
NR	6th December 2021	00-06	25400	1400	24000	15766	8234	
			24450**		23050**	14816**		
		06-08	25400		24000	16155	7845	
			24450**		23050**	15205**		
		08-09	23500		22100	16155	5945	
			22550**		21150**	15205**		
		09-17	23500		22100	16155	5945	
22550**	21150**		15205**					
17-18	23500	22100	16155	5945				
	22550**	21150**	15205**					
18-24	23500	22100	15766	6334				
	22550**	21150**	14816**					

NR	7th December 2021	00-06	25400	1400	24000	15766	8234	
			24450**		23050**	14816**		
		06-08	25400		24000	16155	7845	
			24450**		23050**	15205**		
		08-09	23500		22100	16155	5945	
			22550**		21150**	15205**		
		09-17	23500		22100	16155	5945	
22550**	21150**		15205**					
17-18	23500	22100	16155	5945				
	22550**	21150**	15205**					
18-24	23500	22100	15766	6334				
	22550**	21150**	14816**					
NR	8th December 2021	00-06	25400	1400	24000	15766	8234	
			24450**		23050**	14816**		
		06-08	25400		24000	16155	7845	
			24450**		23050**	15205**		
		08-09	24700		23300	16155	7145	
			23750**		22350**	15205**		
		09-17	24700		23300	16155	7145	
23750**	22350**		15205**					
17-18	24700	23300	16155	7145				
	23750**	22350**	15205**					
18-24	24700	23300	15766	7534				
	23750**	22350**	14816**					
NR	9th December 2021 to 12th December 2021	00-06	25400	1400	24000	15766	8234	
			24450**		23050**	14816**		
		06-09	25400		24000	16155	7845	
			24450**		23050**	15205**		
		09-17	25400		24000	16155	7845	
			24450**		23050**	15205**		
		17-18	25400		24000	16155	7845	
24450**	23050**		15205**					
18-24	25400	24000	15766	8234				
	24450**	23050**	14816**					

NR	13th December 2021	00-06	25400 24450**	1400	24000 23050**	15766 14816**	8234	
		06-08	25400 24450**		24000 23050**	16155 15205**	7845	
		08-17	24500 23550**		23100 22150**	16155 15205**	6945	
		17-18	24500 23550**		23100 22150**	16155 15205**	6945	
		18-24	24500 23550**		23100 22150**	15766 14816**	7334	
NR	14th December 2021	00-06	25400 24450**	1400	24000 23050**	15766 14816**	8234	
		06-08	25400 24450**		24000 23050**	16155 15205**	7845	
		08-17	24500 23550**		23100 22150**	16155 15205**	6945	
		17-18	24500 23550**		23100 22150**	16155 15205**	6945	
		18-24	24500 23550**		23100 22150**	15766 14816**	7334	
NR	15th December 2021	00-06	25400 24450**	1400	24000 23050**	15766 14816**	8234	
		06-08	25400 24450**		24000 23050**	16155 15205**	7845	
		08-17	24500 23550**		23100 22150**	16155 15205**	6945	
		17-18	24500 23550**		23100 22150**	16155 15205**	6945	
		18-24	24500 23550**		23100 22150**	15766 14816**	7334	

SR [#]	1st December 2021 to 4th December 2021	00-06	16150	1000	15150	6693	8457	
		06-18	16150		15150	6778	8372	
		18-24	16150		15150	6693	8457	
SR [#]	5th December 2021	00-06	16150	1000	15150	6693	8457	
		06-09:30	16150		15150	6778	8372	
		09:30-18	12950		11950	6778	5172	
		18-24	12950		11950	6693	5257	
SR [#]	6th December 2021 to 7th December 2021	00-06	16150	1000	15150	6693	8457	
		06-18	16150		15150	6778	8372	
		18-24	16150		15150	6693	8457	
SR [#]	8th December 2021	00-06	16150	1000	15150	6693	8457	
		06-08	16150		15150	6778	8372	
		08-18	15600		14600	6778	7822	
		18-24	15600		14600	6693	7907	
SR [#]	9th December 2021	00-06	15600	1000	14600	6693	7907	
		06-18	15600		14600	6778	7822	
		18-24	15600		14600	6693	7907	
SR [#]	10th December 2021	00-06	15600	1000	14600	6693	7907	
		06-08	15600		14600	6778	7822	
		08-18	15150		14150	6778	7372	
		18-24	15150		14150	6693	7457	
SR [#]	11th December 2021	00-06	15600	1000	14600	6693	7907	
		06-08	15600		14600	6778	7822	
		08-18	15150		14150	6778	7372	
		18-24	15150		14150	6693	7457	

SR [#]	12th December 2021	00-06	15600	1000	14600	6693	7907		
		06-18	11800		10800	6778	4022		
		18-24	11800		10800	6693	4107		
SR [#]	13th December 2021	00-06	15600	1000	14600	6693	7907		
		06-07	15600		14600	6778	7822		
		07-18	15200		14200	6778	7422		
		18-24	15200		14200	6693	7507		
SR [#]	14th December 2021 to 15th December 2021	00-06	15200	1000	14200	6693	7507		
		06-18	15200		14200	6778	7422		
		18-24	15200		14200	6693	7507		
SR [#]	16th December 2021	00-06	15200	1000	14200	6693	7507		
		06-13	15200		14200	6778	7422		
		13-18	13100		12100	6778	5322		
		18-24	13100		12100	6693	5407		
SR [#]	17th December 2021 to 24th December 2021	00-06	15200	1000	14200	6693	7507		
		06-18	15200		14200	6778	7422		
		18-24	15200		14200	6693	7507		
SR [#]	25th December 2021 to 31st December 2021	00-06	15750	1000	14750	6693	8057		
		06-18	15750		14750	6778	7972		
		18-24	15750		14750	6693	8057		

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral &

**Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus

* For approving STOA Bilateral transactions, margin available in Simultaneous Import of NR would be apportioned on WR-NR Corridor & ER-NR Corridor in the

Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section

#Though 2X315 MVA, 400/220 kV ICTs at Maradam are N-1 non-compliant, the TTC of SR Import has not been restricted due to the same considering that this aspect will be managed by AP SLDC through appropriate measures like SPS implementation.

In case of drawl of Karnataka beyond 3800 MW, the voltages in Bengaluru area are observed to be critically low. This issue may be taken care of by Karnataka by

WR-NR/Import of NR TTC has been calculated considering generation at Pariccha TPS as 350 MW. TTC figures are subject to change with significant change in

Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR*	1st December 2021 to 31st December 2021	00-06	4500	700	3800	721	3079		
		06-18				3381	419		
		18-24				721	3079		
NER*	1st December 2021 to 16th December 2021	00-02	3415	60	3355	81	3274		
		02-07	3415			81	3274		
		07-12	3415			81	3274		
		12-17	3415			81	3274		
		17-21	3300			81	3159		
		21-24	3415			81	3274		
NER*	17th December 2021 to 18th December 2021	00-02	2815	60	2755	81	2674	-600	Four units of Kameng HEP (4x150 MW) are under force outage
		02-07	2815			81	2674		
		07-12	2815			81	2674		
		12-17	2815			81	2674		
		17-21	2700			81	2559		
		21-24	2815			81	2674		
NER*	19th December 2021 to 31st December 2021	00-02	3415	60	3355	81	3274		
		02-07	3415			81	3274		
		07-12	3415			81	3274		
		12-17	3415			81	3274		
		17-21	3300			81	3159		
		21-24	3415			81	3274		
WR*									
SR*^	1st December 2021 to 7th December 2021	00-24	5600	400	5200	1783	3417		
SR*^	8th December 2021	00-08	5600	400	5200	1783	3417		
		08-24	4800		4400		4400		

SR*^	9th December 2021 to 11th December 2021	00-24	4800	400	4400	1783	2617		
SR*^	12th December 2021	00-06	4800	400	4400	1783	2617		
		06-24	2700		2300		517		
SR*^	13th December 2021 to 15th December 2021	00-24	4800	400	4400	1783	2617		\
SR*^	16th December 2021	00-13	4800	400	4400	1783	2617		
		13-24	4300		3900		2117		
SR*^	17th December 2021 to 24th December 2021	00-24	4800	400	4400	1783	2617		\
SR*^	25th December 2021 to 31st December 2021	00-24	5600	400	5200	1783	3417		

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section

^SR Export TTC/ATC figures have been calculated considering 01 unit (800 MW) at Kudgi TPS in service. The figures are subject to change with change in generation at Kudgi TPS.

Limiting Constraints (Corridor wise)			Applicable Revisions
Corridor	Constraint		
	N-1 contingency of one ckt of 765 kV Vindhyachal-Varanasi will overload the other circuit		Rev- 0 to 21
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli		Rev- 0 to 21
ER-NR	Inter-regional flow pattern towards NR		Rev- 0 to 21
WR-SR and ER-SR	N-1 of one ICT of 765/400 kV, 1500 MVA ICT at Nizamabad will overload the other ICT		Rev- 0
	N-1 of one ckt of 765kV Angul-Srikakulam D/C will overload the other circuit		
	Low Voltage at Gazuwaka (East) Bus.		Rev- 0 to 21
	N-1 of one ICT of 765/400 kV, 1500 MVA ICT at Nizamabad will overload the other ICT		
	Low Voltage at Gazuwaka (East) Bus.		
SR-WR	a) N-1 contingency of one ckt of 400 kV Kolhapur-PG - Kolhapur-MS D/C will overload of the other ckt b) N-1 contingency of 500 MVA ICT at 400 kV Kolhapur-MS will overload the other 2x315 MVA ICTs		Rev- 0 to 21
ER-NER	a) N-1 contingency of 400 kV Bongaigaon - Azara line b) High Loading of 220 kV Salakati - BTPS D/C		Rev- 0 to 21
NER-ER	a) N-1 contingency of 220 kV Salakati - Alipurduar I or II b) High Loading of 220 kV Salakati - Alipurduar II or I		Rev- 0 to 21
W3 zone Injection	---		Rev- 0 to 21
Limiting Constraints (Simultaneous)			Applicable Revisions
NR	Import	Inter-regional flow pattern towards NR	Rev- 0 to 21
		N-1 contingency of one ckt of 765 kV Vindhyachal-Varanasi will overload the other circuit	Rev- 0 to 21
	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak. (n-1) contingency of 400 kV Saranath-Pusauli	Rev- 0 to 21
NER	Import	a) N-1 contingency of 400 kV Bongaigaon - Killing line (0000 hrs to 2400 hrs) b) High Loading of 220 kV Balipara-Sonabil (0000 hrs to 0700 hrs) c) High Loading of 220 kV Salakati - BTPS D/C (0700 hrs to 1200 hrs)	Rev- 0 to 21
	Export	a) N-1 contingency of 220 kV Salakati - Alipurduar I or II b) High Loading of 220 kV Salakati - Alipurduar II or I	Rev- 0 to 21
SR	Import	N-1 of one ICT of 765/400 kV, 1500 MVA ICT at Nizamabad will overload the other ICT	Rev- 0
		N-1 of one ckt of 765kV Angul-Srikakulam D/C will overload the other circuit	
		Low Voltage at Gazuwaka (East) Bus	
	Export	N-1 of one ICT of 765/400 kV, 1500 MVA ICT at Nizamabad will overload the other ICT	Rev- 0 to 21
		Low Voltage at Gazuwaka (East) Bus	
	Export	N-1 contingency of one ckt of 400 kV Kolhapur-PG - Kolhapur-MS D/C will overload of the other ckt N-1 contingency of 500 MVA ICT at 400 kV Kolhapur-MS will overload the other 2x315 MVA ICTs	Rev- 0 to 21

**National Load Despatch Centre
Total Transfer Capability for December 2021**

Revision No	Date of Revision	Period of Revision	Reason for Revision/Comment	Corridor Affected
1	25th September 2021	Whole Month	TTC/ATC revised due to commissioning of HVDC Raigarh-Pugalur Pole-3	WR-SR/ER-SR/SR Import
2	28th September 2021	Whole Month	Revised STOA margin due to a) operationalization of new LTA OF 73 MW from Tuticorin-BETAMWIND to UPPCL b) operationalization of new LTA OF 10 MW from Tuticorin-IWISL to Haryana	WR-NR/NR Import
			Revised STOA margin due to a) Discontinuation of 250 MW MTOA from ACEPL to Madhya Pradesh b) Operationalization of new LTA of 250 MW from RSWPL3_FTG2 to BSPHCL c) Operationalization of new LTA of 300 MW from AP43PL_BKN to Odisha	ER-NR/WR-NR/NR Export
			Revised STOA margin due to a) operationalization of new LTA of 106 MW from Fatehgarh-II Solar to Telangana b) operationalization of new LTA of 176 MW from Bhadia-II Solar to Telangana	WR-SR/SR Import
			Revised STOA margin due to a) Increase LTA by 6 MW from BETAM to UP (NR) b) Increase LTA by 15 MW from Spring Energy, Pugalur to UP (NR) c) Operationalization of 63 MW LTA from HIRIYUR_OSTROKANNADA to Bihar, ER	SR-WR/SR Export
			Revised STOA margin due to discontinuation of 50 MW MTOA Arunachal Pradesh to NPCL(UP)	NER-ER/NER Export
3	28th October 2021	Whole Month	Revised STOA margin due to a) Operationalization of LTA OF 39 MW from PGLR_SREPL to UPPCL b) Operationalization of LTA OF 11 MW from Tuticorin-BETAMWIND to UPPCL c) Discontinuation of 50 MW MTOA Arunachal Pradesh to NPCL(UP)	WR-NR/ER-NR/NR Import
			Revised STOA margin due to operationalization of new LTA of 33 MW from AP41PL_BHDL to ODISHA	NR-ER/NR Export
			Revised STOA margin due to a) Operationalization of LTA of 24 MW from Spring energy to UP (NR) b) Operationalization of LTA of 5 MW from BETAM to UP (NR) c) Operationalization of LTA of 5 MW from BETAM to Odisha (ER) d) Operationalization of LTA of 21 MW from Hiriyur_Ostrokannada to Bihar (ER)	SR-WR/SR/ER/SR Export
			Revised STOA margin due to a) Operationalization of LTA OF 300 MW from RSBPL_FTG2 to Maharashtra b) Operationalization of LTA OF 100 from ASunCEPL_BKN to Maharashtra c) Operationalization of LTA OF 250 from MRPL to CSEB d) Operationalization of LTA OF 250 MW from ACEPL_BHADLA to Maharashtra e) Operationalization of LTA from AP41PL_BHDL to ODISHA	NR-ER/NR-WR/NR Export
4	28th November 2021	Whole Month	Revised STOA margin due to operationalization of the LTA quantum of Tuticorin-BETAMWIND to UPPCL	WR-NR/ER-NR/NR Import
			Revised STOA margin due to a) Operationalization of LTA OF 50 MW from Fatehgarh PS(ACME Solar) to Pondicherry b) Operationalization of LTA OF 90 MW from Fatehgarh-II Solar to Telangana	WR-SR/SR Import
			Revised STOA margin due to a) Operationalization of LTA from Spring Energy, Pugalur to UP b) Operationalization of LTA from HIRIYUR_OSTROKANNADA to Bihar	SR-WR/SR Export
			TTC/ATC Changed due to 1) Change in Load-Generation of NER 2) One unit of Kameng HEP (4x150 MW) is under force outage Also, due to increase in peak demand of NER, TRM increased from 45 MW to 60 MW	ER-NER/NER Import/ NER-ER/NER Export
5	29th November 2021	Whole Month	TTC/ATC revised due to shutdown of 765 kV Gwalior - Phagi - 1	ER-NR/WR-NR/NR Import
6	30th November 2021	2nd December 2021	TTC/ATC revised due to shutdown of 765 kV Gwalior - Phagi - 2	ER-NR/WR-NR/NR Import
7	1st December 2021	3rd December 2021	TTC/ATC revised due to shutdown of 765 kV Bina - Gwalior - 1	ER-NR/WR-NR/NR Import
8	2nd December 2021	4th December 2021	TTC/ATC revised due to shutdown of 765 kV Bina - Gwalior - 2	ER-NR/WR-NR/NR Import
9	3rd December 2021	5th December 2021	TTC/ATC revised due to shutdown of 765 kV Bina - Gwalior - 1 Due to Shutdown of 765 kV Bus - 2 at Nizamabad	ER-NR/WR-NR/NR Import ER-SR/WR-SR/SR Import
10	4th December 2021	6th December 2021	TTC/ATC revised due to shutdown of 765 kV VARANASI(PG)-VINDHYACHALPOOL(PG) CKT-1	ER-NR/WR-NR/NR Import
11	5th December 2021	7th December 2021	TTC/ATC revised due to shutdown of 765 kV VARANASI(PG)-VINDHYACHALPOOL(PG) CKT-2	ER-NR/WR-NR/NR Import
12	6th December 2021	8th December 2021	TTC/ATC revised due to shutdown of 765KV-SATNA-VINDHYACHAL(PS)-2	ER-NR/WR-NR/NR Import
			TTC/ATC revised due to shutdown of 765KV-RAICHUR_PG-SHOLAPUR-1 & 2 (One at a time)	WR-SR/SR Import/SR-WR/SR Export
13	7th December 2021	9th December to 24th December 2021	TTC/ATC revised due to shutdown of 765KV-RAICHUR_PG-SHOLAPUR-1	WR-SR/SR Import/SR-WR/SR Export
14	8th December 2021	10th December 2021	TTC/ATC Revised due to shutdown of 765KV-SRIKAKULAM-VEMAGIRI_PG-1	ER-SR/SR Import
15	9th December 2021	11th December 2021	TTC/ATC Revised due to shutdown of 765KV-SRIKAKULAM-VEMAGIRI_PG-2	ER-SR/SR Import
16	10th December 2021	12th December 2021	TTC/ATC Revised due to Shutdown of 800kV Raigarh-Pugalur Line-1 and 2	WR-SR/SR Import/SR-WR/SR Export
17	11th December 2021	13th to 31st December 2021	TTC/ATC Revised due to shutdown of a 765KV-JABALPUR-ORAI-1	ER-NR/WR-NR/NR Import
			TTC/ATC Revised due to shutdown of 765KV-WARDHA-AURANGABAD-1 & 2	WR-SR/ER-SR/SR Import
18	12th December 2021	14th December 2021	TTC/ATC Revised due to shutdown of a 765KV-JABALPUR-ORAI-1	ER-NR/WR-NR/NR Import
19	13th December 2021	15th December 2021	TTC/ATC Revised due to shutdown of a 765KV-JABALPUR-ORAI-2	ER-NR/WR-NR/NR Import
20	14th December 2021	16th December 2021	TTC/ATC Revised due to shutdown of a 765KV-JABALPUR-ORAI-2	ER-NR/WR-NR/NR Import
			HVDC Bhadravathi Black start Mock drill exercise	WR-SR/ER-SR/SR Import/SR-WR/SR Export
21	15th December 2021	17th December 2021 to 18th December 2021	TTC/ATC Revised due to Four units of Kameng HEP (4x150 MW) are under force outage	ER-NER/NER Import/NER-ER/NER Export

ASSUMPTIONS IN BASECASE					
				Month : December 2021	
S.No.	Name of State/Area	Load		Generation	
5th December 2021		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
I	NORTHERN REGION				
1	Punjab	10744	10867	3971	3971
2	Haryana	9492	9088	2701	2701
3	Rajasthan	10485	9635	8259	8259
4	Delhi	5321	5152	796	795
5	Uttar Pradesh	20631	20099	10623	10689
6	Uttarakhand	2124	1886	928	939
7	Himachal Pradesh	1354	1114	783	769
8	Jammu & Kashmir	2363	1962	884	883
9	Chandigarh	313	249	0	0
10	ISGS/IPPs	48	48	21958	20013
	Total NR	62875	60100	50903	49019
II	EASTERN REGION				
1	Bihar	6537	5617	356	349
2	Jharkhand	1958	1503	511	501
3	Damodar Valley Corporation	2985	2723	5856	4190
4	Orissa	4513	4310	3998	3798
5	West Bengal	9704	8401	7033	6210
6	Sikkim	119	116	0	0
7	Bhutan	181	181	2325	2325
8	ISGS/IPPs	810	810	15771	11533
	Total ER	26808	23662	35850	28906
III	WESTERN REGION				
1	Maharashtra	17405	16509	11624	10789
2	Gujarat	13918	11320	8601	7246
3	Madhya Pradesh	9254	8534	3596	3845
4	Chattisgarh	4309	3965	2531	2835
5	Daman and Diu	276	236	0	0
6	Dadra and Nagar Haveli	744	870	0	0
7	Goa-WR	534	420	0	0
8	ISGS/IPPs	1784	3263	36712	32338
	Total WR	48224	45117	63064	57053
IV	SOUTHERN REGION				
1	Andhra Pradesh	8024	7220	6268	5204
2	Telangana	9100	8117	5196	5078
3	Karnataka	8396	6654	6023	4850
4	Tamil Nadu	15210	13068	7256	6376
5	Kerala	3778	2349	1614	961
6	Pondy	264	264	0	0
7	Goa-SR	82	82	0	0
8	ISGS/IPPs	37	37	14805	14794
	Total SR	44891	37791	41162	37263
V	NORTH-EASTERN REGION				
1	Arunachal Pradesh	140	95	118	118
2	Assam	1849	1588	615	574
3	Manipur	207	86	105	103
4	Meghalaya	315	255	302	229
5	Mizoram	150	55	60	60
6	Nagaland	173	155	96	93
7	Tripura	435	260	300	300
8	ISGS/IPPs	0	0	2371	2370
	Total NER	3269	2494	3967	3847
	Total All India	186067	169164	194946	176088