National Load Despatch Centre Total Transfer Capability for December 2021

Issue Date: 28th November, 2022 Issue Time: 1700 hrs Revision No. 4

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
		00-06				628	1372		Revised STOA margin due to
NR-WR*	1st December 2021 to 31st December 2021	06-18	2500	500	2000	2000 1856	144		a) Operationalization of LTA OF 300 MW from RSBPL_FTG2 to Maharastra b) Operationalization of LTA OF 100 from ASunceEPL_BKN to Maharastra c) Operationalization of LTA OF 250 from MRPL to CSEB d)
		18-24				628	1372		Operationalization of LTA OF 250 MW from ACSEPL_BHADLA to Maharastra
		00-06	19500		18500	11433			
			18550**	1000	17550**	10483**	7067		
WR-NR*	1st December 2021 to 31st	06-18	19500	1000	18500	11822	6678		Revised STOA margin due to
WK-NK	December 2021	00-18	18550**	1000	17550**	10872*	0078		operationalization of the LTA quantum of Tuticorin-BETAMWIND to UPPCL
			19500		18500	11433			
		18-24	18550**	1000	17550**	10483**	7067		
	1st December	00-06	2000		1800	93	1707		
NR-ER*	2021 to 31st	06-18	06-18 2000 200		1800	1525	275		Revised STOA margin due to operationalization of LTA from AP41PL_BHDL to ODISHA
	December 2021	18-24	2000		1800	93	1707		
ER-NR*	1st December 2021 to 31st December 2021	00-24	5900	400	5500	4333	1167		
W3-ER	1st December 2021 to 31st December 2021	00-24	No limit is being specified.						
ER-W3	1st December 2021 to 31st December 2021	00-24		No limit is being specified.					
	1st December	00-05	10350		9700		5682		Revised STOA margin due to
WR-SR	2021 to 31st	05-22	10350	650	9700	4018	5682		a) Operationalization of LTA OF 50 MW from Fatehgarh PS(ACME Solar) to Pondicherry
	December 2021	22-24	10350		9700		5682		b) Operationalization of LTA OF 90 MW from Fatehgarh-II Solar to Telangana
SR-WR*	1st December 2021 to 31st December 2021	00-24	4600	400	4200	983	3217		Revised STOA margin due to operationalization of LTA from Spring Energy,Pugalur to UP
	4	00-06	00-06			2675			
ER-SR [△]	1st December 2021 to 31st	06-18	5800	350	5450	2760	2690		
	December 2021	18-24	- 3000			2675	2775		
SR-ER*	1st December 2021 to 31st December 2021	00-24	No limit is being Specified.						
		00-02	810		765	455	310		
	1st December	02-07	810		765	455	310		
ER-NER*	2021 to 31st	07-12 12-18	805 820	20 45	760 775	455 455	305 320		
	December 2021	18-22	610		565	455	110		
		22-24 00-02	810		765 3235	455 81	310 3154		
	Let De	02-07	3280	3230 3270 45	3235	81	3154		
NER-ER*	1st December 2021 to 31st	07-12			3185	81	3104		
	December 2021	12-18 18-22	3270 3240		3225 3195	81 81	3144 3114		
		22-24	3280		3235	81	3154		

National Load Despatch Centre Total Transfer Capability for December 2021

Issue Date: 28th November, 2022 Issue Time: 1700 hrs Revision No. 4

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
W3 zone Injection	1st December 2021 to 31st December 2021		No limit is be	No limit is being specified (In case of any constraints appearing in the system, W3 zone export would be revised accordingly)					

Note: TTC/ATC of S1-(S2&S3) corridor, Import of S3(Kerala), Import of Punjab and Import of DD & DNH is uploaded on NLDC website under Intra-Regional Section in Monthly ATC.

Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

**Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity

- 1) S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala
- 2) W3 comprises of the following regional entities:
 a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak
- f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCL, n) Vandana Vidyut o) RKM, p) GMR Raikheda, q) Ind Barath and any other regional entity generator in Chhattisgarh
- # The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/Fuel shortage/New units being commissionned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

- In case of TTC Revision due to any shutdown:

 1) The TTC value will be revised to normal values after restoration of shutdown.
- 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section

^Though 2X315 MVA, 400/220 kV ICTs at Maradam are N-1 non-compliant, the TTC of WR-SR and ER-SR corridor has not been restricted due to the same considering that this aspect will be managed by AP SLDC through appropriate measures like SPS implementation.

^In case of drawl of Karnataka beyond 3800 MW, the voltages in Bengaluru area are observed to be critically low. This issue may be taken care of by Karnataka SLDC by taking appropiate measures.

SR-WR TTC/ATC figures have been calculated considering 01 unit (800 MW) at Kudgi TPS in service. The figures are subject to change with change in generation at Kudgi TPS.

WR-NR/Import of NR TTC has been calculated considering generation at Pariccha TPS as 350 MW. TTC figures are subject to change with significant change in generation at Pariccha TPS.

Simultaneous Import Capability Long Term Margin Changes Total Available Access (LTA)/ Time Available for in TTC Transfer Reliability Transfer Corridor Date Period **Medium Term Short Term** w.r.t. Comments Capability Margin Capability **Open Access** (hrs) **Open Access** Last (TTC) (ATC) (MTOA) (STOA) Revision 25400 24000 15766 00-06 8234 24450** 23050** 14816** 25400 24000 16155 06-09 7845 24450** 23050** 15205** 1st December 25400 24000 16155 Revised STOA margin due to NR 1400 2021 to 31st 09-17 7845 operationalization of the LTA quantum of December 2021 24450** 23050** 15205** Tuticorin-BETAMWIND to UPPCL 16155 25400 24000 17-18 7845 24450** 23050** 15205** 25400 24000 15766 18-24 8234

14816**

455

455

455

455

455

455

6693

6778

6693

310

310

305

320

110

310

8457

8372

8457

Revised STOA margin due to

Pondicherry

a) Operationalization of LTA OF 50 MW

b) Operationalization of LTA OF 90 MW

from Fatehgarh PS(ACME Solar) to

from Fatehgarh-II Solar to Telangana

23050**

765

765

760

775

565

765

15150

15150

15150

Margin in Simultaneous import of NR = A

WR-NR ATC =B

ER-NR ATC = C

Margin for WR-NR applicants = A * B/(B+C)

Margin for ER-NR Applicants = A * C/(B+C)

Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section

24450**

810

810

805

820

610

810

16150

16150

16150

45

1000

00-02

02-07

07-12

12-18

18-22

22-24

00-06

06-18

18-24

1st December

2021 to 31st

December 2021

1st December

2021 to 31st

December 2021

NER*

 WR^*

SR*#

#Though 2X315 MVA, 400/220 kV ICTs at Maradam are N-1 non-compliant, the TTC of SR Import has not been restricted due to the same considering that this aspect will be managed by AP SLDC through appropriate measures like SPS implementation.

In case of drawl of Karnataka beyond 3800 MW, the voltages in Bengaluru area are observed to be critically low. This issue may be taken care of by Karnataka by taking appropriate measures.

WR-NR/Import of NR TTC has been calculated considering generation at Pariccha TPS as 350 MW. TTC figures are subject to change with significant change in generation at Pariccha TPS.

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

^{**}Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.

^{*} For approving STOA Bilateral transactions, margin available in Simultaneous Import of NR would be apportioned on WR-NR Corridor & ER-NR Corridor in the following ratio:

Simultane	Simultaneous Export Capability									
Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
		00-06				721	3079		Revised STOA margin due to	
NR*	1st December 2021 to 31st December 2021	06-18	4500	4500 700	3800	3381	419		a) Operationalization of LTA OF 300 MW from RSBPL_FTG2 to Maharastra b) Operationalization of LTA OF 100 from ASunceEPL_BKN to Maharastra c) Operationalization of LTA OF 250 from MRPL to CSEB d) Operationalization of LTA OF 250 MW from ACSEPL BHADLA to Maharastra	
		18-24				721	3079		e) Operationalization of LTA OF 250 MW Holin ACSEPL_BRADLA to Manarastra e) Operationalization of LTA from AP41PL_BHDL to ODISHA	
	1st December 2021 to 31st December 2021	00-02	3280	45	3235	81	3154			
		02-07	3280		3235 81	81	3154			
NER*		07-12	3230		3185	81	3104			
NEK		12-18	3270		3225		3144			
		18-22	3240		3195		3114			
		22-24	3280		3235	81	3154			
WR*										
SR*^	1st December 2021 to 31st December 2021	00-24	3700	400	3300	1783	1517		Revised STOA margin due to a) Operationalization of LTA from Spring Energy,Pugalur to UP b) Operationalization of LTA from HIRIYUR_OSTROKANNADA to Bihar	

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section

^SR Export TTC/ATC figures have been calculated considering 01 unit (800 MW) at Kudgi TPS in service. The figures are subject to change with change in generation at Kudgi TPS.

Limiting	Limiting Constraints (Corridor wise)						
		Applicable Revisions					
Corridor	Constraint						
WR-NR	N-1 contingency of one ckt of 765 kV Vindhyachal-Varanasi will overload the other circuit	Rev- 0 to 4					
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli	Rev- 0 to 4					
ER-NR	Inter-regional flow pattern towards NR	Rev- 0 to 4					
	N-1 of one ICT of 765/400 kV, 1500 MVA ICT at Nizamabad will overload the other ICT						
WR-SR	N-1 of one ckt of 765kV Angul-Srikakulam D/C will overload the other circuit	Rev- 0					
and ER-	Low Voltage at Gazuwaka (East) Bus.						
SR	N-1 of one ICT of 765/400 kV, 1500 MVA ICT at Nizamabad will overload the other ICT						
	Low Voltage at Gazuwaka (East) Bus.						
CD-WD	a) N-1 contingency of one ckt of 400 kV Kolhapur-PG - Kolhapur-MS D/C will overload of the other ckt b) N-1 contingency of 500 MVA ICT at 400 kV Kolhapur-MS will overload the other 2x315 MVA ICTs	Rev- 0 to 4					
ER-NER	 a) N-1 contingency of 400 kV Bongaigaon - Azara line b) High Loading of 220 kV Salakati - BTPS D/C 	Rev- 0 to 4					
NER-ER	a) N-1 contingency of 220 kV Salakati - Alipurduar I or II	Rev- 0 to 4					
14EK-EK	b) High Loading of 220 kV Salakati - Alipurduar II or I	KCV- 0 t0 4					
W3 zone		Rev- 0 to 4					
Injection							

Limiting Constraints (Simultaneous)

			Applicable Revisions
	Import	Inter-regional flow pattern towards NR	Rev- 0 to 4
NR	Import	N-1 contingency of one ckt of 765 kV Vindhyachal-Varanasi will overload the other circuit	Rev- 0 to 4
141/	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.	Rev- 0 to 4
	Export	(n-1) contingency of 400 kV Saranath-Pusauli	Kev- 0 to 4
		a) N-1 contingency of 400 kV Bongaigaon - Killing line (0000 hrs to 2400 hrs)	
	Import	b) High Loading of 220 kV Balipara-Sonabil (0000 hrs to 0700 hrs)	Rev- 0 to 4
NER		c) High Loading of 220 kV Salakati - BTPS D/C (0700 hrs to 1200 hrs)	
	Export	a) N-1 contingency of 220 kV Salakati - Alipurduar I or II	D 04 4
		b) High Loading of 220 kV Salakati - Alipurduar II or I	Rev- 0 to 4
		N-1 of one ICT of 765/400 kV, 1500 MVA ICT at Nizamabad will overload the other ICT	
		N-1 of one ckt of 765kV Angul-Srikakulam D/C will overload the other circuit	Rev- 0
	Import	Low Voltage at Gazuwaka (East) Bus	
SR		N-1 of one ICT of 765/400 kV, 1500 MVA ICT at Nizamabad will overload the other ICT	Rev-1 to 4
		Low Voltage at Gazuwaka (East) Bus	Kev-1 to 4
	Export	N-1 contingency of one ckt of 400 kV Kolhapur-PG - Kolhapur-MS D/C will overload of the other ckt	Rev- 0 to 4
	Export	N-1 contingency of 500 MVA ICT at 400 kV Kolhapur-MS will overload the other 2x315 MVA ICTs	KCV- 0 t0 4

National Load Despatch Centre Total Transfer Capability for December 2021

Revision No	Date of Revision	Period of Revision	Reason for Revision/Comment	Corridor Affected
1	25th September 2021	Whole Month	TTC/ATC revised due to commissioning of HVDC Raigarh-Pugalur Pole-3	WR-SR/ER-SR/SR Import
			Revised STOA margin due to a)operationalization of new LTA OF 73 MW from Tuticorin-BETAMWIND to UPPCL b)operationalization of new LTA OF 10 MW from Tuticorin-IWISL to Haryana	WR-NR/NR Import
			Revised STOA margin due to a) Discontinuation of 250 MW MTOA from ACSEPL to Madhya Pradesh b) Operationalization of new LTA of 250 MW from RSWPL3_FTG2 to BSPHCL c) Operationalization of new LTA of 300 MW from AP43PL_BKN to Odisha	ER-NR/WR-NR/NR Export
2	28th September 2021	Revised STOA margin due to a) operationalization of new LTA of 106 Mb b) operationalization of new LTA of 176 M Revised STOA margin due to a) Increase LTA by 6 MW from BETAM to 0 b) Increase LTA by 15 MW from Spring Enc	Revised STOA margin due to a)operationalization of new LTA of 106 MW from Fatehgarh-II Solar to Telangana b) operationalization of new LTA of 176 MW from Bhadla-II Solar to Telangana	WR-SR/SR Import
			Revised STOA margin due to a) Increase LTA by 6 MW from BETAM to UP (NR) b) Increase LTA by 15 MW from Spring Energy, Pugalur to UP (NR) c) Operationalization of 63 MW LTA fromHIRIYUR_OSTROKANNADA to Bihar, ER Revised STOA margin due to discontinuation of 50 MW MTOA Arunachal	SR-WR/SR Export
			Pradesh to NPCL(UP)	NER-ER/NER Export
		1 Whole Month	Revised STOA margin due to a) Operationalization of LTA OF 39 MW from PGLR_SREPL to UPPCL b) Operationalization of LTA OF 11 MW from Tuticorin-BETAMWIND to UPPCL c) Discontinuation of 50 MW MTOA Arunachal Pradesh to NPCL(UP)	WR-NR/ER-NR/NR Import
3	28th October 2021		Revised STOA margin due to operationalization of new LTA of 33 MW from AP41PL_BHDL to ODISHA	NR-ER/NR Export
			Revised STOA margin due to a) Operationalization of LTA of 24 MW from Spring energy to UP (NR) b) Operationalization of LTA of 5 MW from BETAM to UP (NR) c) Operationalization of LTA of 5 MW from BETAM to Odisha (ER) d) Operationalization of LTA of 21 MW from Hiriyur_Ostrokannada to Bihar (ER)	SR-WR/SR-ER/SR Export
			Revised STOA margin due to a) Operationalization of LTA OF 300 MW from RSBPL_FTG2 to Maharastra b) Operationalization of LTA OF 100 from ASunceEPL_BKN to Maharastra c) Operationalization of LTA OF 250 from MRPL to CSEB d) Operationalization of LTA OF 250 MW from ACSEPL_BHADLA to Maharastra e) Operationalization of LTA from AP41PL_BHDL to ODISHA	NR-ER/NR-WR/NR Export
4	28th November	Whole Month	Revised STOA margin due to operationalization of the LTA quantum of Tuticorin-BETAMWIND to UPPCL	WR-NR/ER-NR/NR
4	2021	whole Month	Revised STOA margin due to a) Operationalization of LTA OF 50 MW from Fatehgarh PS(ACME Solar) to Pondicherry b) Operationalization of LTA OF 90 MW from Fatehgarh-II Solar to Telangana	Import WR-SR/SR Import
			Revised STOA margin due to a) Operationalization of LTA from Spring Energy,Pugalur to UP b) Operationalization of LTA from HIRIYUR_OSTROKANNADA to Bihar	SR-WR/SR Export

ASSUM	MPTIONS IN BASECASE					
				Month : December 202		
S.No.	Name of State/Area		Load	Generation		
	NORTHERN REGION	Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)	
1	NORTHERN REGION	40744	10007	0074	0074	
1	Punjab	10744	10867	3971	3971	
2	Haryana	9492	9088	2701	2701	
3	Rajasthan	10485	9635	8259	8259	
4	Delhi	5321	5152	796	795	
5	Uttar Pradesh	20631	20099	10623	10689	
6	Uttarakhand	2124	1886	928	939	
7	Himachal Pradesh	1354	1114	783	769	
8	Jammu & Kashmir	2363	1962	884	883	
9	Chandigarh	313	249	0	0	
10	ISGS/IPPs	48	48	21958	20013	
	Total NR	62875	60100	50903	49019	
	EASTERN REGION	0507	FC.1-	0.50	6.12	
1	Bihar	6537	5617	356	349	
2	Jharkhand	1958	1503	511	501	
3	Damodar Valley Corporation	2985	2723	5856	4190	
4	Orissa	4513	4310	3998	3798	
5	West Bengal	9704	8401	7033	6210	
6	Sikkim	119	116	0	0	
7	Bhutan	181	181	2325	2325	
8	ISGS/IPPs	810	810	15771	11533	
	Total ER	26808	23662	35850	28906	
III	WESTERN REGION					
1	Maharashtra	17405	16509	11624	10789	
2	Gujarat	13918	11320	8601	7246	
3	Madhya Pradesh	9254	8534	3596	3845	
4	Chattisgarh	4309	3965	2531	2835	
5	Daman and Diu	276	236	0	0	
6	Dadra and Nagar Haveli	744	870	0	0	
7	Goa-WR	534	420	0	0	
8	ISGS/IPPs	1784	3263	36712	32338	
	Total WR	48224	45117	63064	57053	
IV	SOUTHERN REGION					
1	Andhra Pradesh	8024	7220	6268	5204	
2	Telangana	9100	8117	5196	5078	
3	Karnataka	8396	6654	6023	4850	
4	Tamil Nadu	15210	13068	7256	6376	
5	Kerala	3778	2349	1614	961	
6	Pondy	264	264	0	0	
7	Goa-SR	82	82	0	0	
8	ISGS/IPPs	37	37	14805	14794	
	Total SR	44891	37791	41162	37263	
					1	
V	NORTH-EASTERN REGION				1	
1	Arunachal Pradesh	140	95	118	118	
2	Assam	1849	1588	615	574	
3	Manipur	207	86	105	103	
4	Meghalaya	315	255	302	229	
5	Mizoram	150	55	60	60	
6	Nagaland	173	155	96	93	
7	Tripura	435	260	300	300	
8	ISGS/IPPs	0	0	2371	2370	
	Total NER	3269	2494	3967	3847	
	Total All India	186067	169164	194946	176088	