Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR-WR *	1st February 2014 to 28th February 2014	00-24	2500	500	2000	286	1714		
	1st February 2014 to 11th February 2014	00-17 23-24	3900	500	3400	3181	219		
	Titil Columny 2014	17-23 00-17	3900		3400	3181	219		
	12th February 2014	23-24	4200	500	3700	3569	131		
WR-NR ¹		17-23	4200		3700		131		
	13th February 2014	00-08 12-24	4200	500	3700	3656	44		Revised due to Emergency shutdown
		08-12'	3200		2700		0	-1000	of 765kV Gwalior Bus-1.
	14th February 2014 to	00-17 23-24	4200	500	3700	3656	44		
	28th February 2014	17-23	4200		3700		44		
	1st February 2014 to	00-17	1000		800		600		
NR-ER *	28th February 2014	23-24		200		200			
		17-23 00-07	1100		900		700		
	1 - 4 F-1 2014	16-17	2600	300	2300	2118	182		
	1st February 2014	23-24 07-16'	1900		1600		0		
		17-23	1900		1600		0		
	2nd February 2014 to	00-17 23-24	2600		2300	2118	182		
	5th February 2014	17-23	1900		1600		0		
	6th February 2014	00-17 23-24	3600	300	3300	2118	1182		
ER-NR		17-23	3100		2800		682		
	7th February 2014	00-17 23-24	3600	300	3300	2118	1182		
		17-23	3100		2800	-	682		
	8th February 2014 to	00-07 23-24	3600	300	3300	2118	1182		
	9th Februray 2014	07-17'	3000		2700		582		
		17-23 00-17	3100		2800		682		
	10th February 2014 to 28th February 2014	23-24	3600	300	3300	2118	1182		
	Zotti February 2014	17-23	3100		2800		682		
	1st February 2014 to 08th February 2014	00-24	1800	300	1500	0	1500		
	09th Februray 2014	00-07 18-24	1800	300	1500	0	1500		
		07-18'	1300	300	1000	0	1000		
W3-ER	10th February 2014	00-24	1800	300	1500	0	1500		
	11th Februray 2014	18-24	1800	300	1500	0	1500		
		09-18'	1500	300	1200	0	1200		
	12th Februray 2014 to 28th Februray 2014	00-24	1800	300	1500	60	1440		
ER-W3	1st February 2014 to 28th February 2014	00-24	1000	300	700	700	0		
WR-SR	1st February 2014 to 28th February 2014	00-24	850	0	850	850	0		
SR-WR *	1st February 2014 to 28th February 2014	00-24	1000	0	1000	0	1000		

Issue Date: 12/02/2014 Issue Time: 1300 hrs Revision No. 12

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER-SR	1st February 2014 to 28th February 2014	00-05 10-19 05-10	700 700	0	700 700	700	0		
SR-ER*	1st February 2014 to 28th February 2014	19-24 00-17 23-24 17-23	1100	0	1100	197	903		
ER-NER ²	1st February 2014	00-07 16-17 23-24 07-16' 17-23	350 320 330	50	300 270 280	230	70 40 50		
	2nd February 2014 to 5th February 2014	00-17 23-24 17-23	350 350	50	300	230	70		
	6th February 2014	00-17 23-24 17-23	720 640	50	670 590	230	440 360		
ER-NER ²	7th February 2014	00-17 23-24 17-23	720 640	50	670 590	230	440 360		
	8th February 2014 to 9th Februray 2014	00-07 23-24 07-17'	720 500	50	670 450	230	440 220		
	10th February 2014 to 28th February 2014	17-23 00-17 23-24 17-23	640 720 640	50	590 670 590	230	360 440 360		
NER-ER	1st February 2014 to 28th February 2014	00-17 23-24 17-23	570 570	100	470 470	0	470 470		
		17-23	370		470		470		
S1-S2	1st February 2014 to 28th February 2014	00-24	5650	400	5250	4900	350		
Import of Punjab	1st February 2014 to 28th February 2014	00-24	5600	300	5300	3800	1500		
Import TTC for DD & DNH	1st February 2014 to 28th February 2014	00-24	980	0	980	LTA and MTO.			
W3 zone	1st February 2014	00-08 23-24 08-16' 16-17 17-18 18-23	8500 7600 8600 9100 9500	200	8300 7400 8400 8900 9300	7630	670 -230 770 1270 1670		
Injection	2nd February 2014 to 28th February 2014	00-08 23-24 08-16' 16-17 17-23	8500 8000 9000 9500	200	8300 7800 8800 9300	7630	670 170 1170 1670		

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

¹⁾ ER-SR TTC declared at Talcher Interconnector and Gazuwaka HVDC $\mbox{\sc B/B}$ seam

²⁾ S1 comprises of AP and Karnataka: S2 comprises of Tamil Nadu, Kerala and Pondicherry
3) W3 comprises of the following regional entities:
a) Chattisgarh, b) Jindal Power Limited (JPL), c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak

f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCL

[#] The figure is based on LTA/MTOA approved by CTU. In actual Operation, due to Units being on Maintenance/ Fuel shortage the LTA/MTOA utilized would be les. RLDC/ NLDC would factor this situation while issuing STOA approvals

Issue Date: 12/02/2014 Issue Time: 1300 hrs Revision No. 12

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
----------	------	-------------------------	--	-----------------------	--	--	--	---	----------

1. WR-NR Total Transfer capability will be reduced to 3100 MW in case of outage of any one of the following sections:

2. ER-NER Total Transfer capability will be reduced to 450 MW in case of outage of any one of the 400kV Purnea-Biharshariff circuit.

Limiting Constraints

Corridor	Constraint						
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.						
WR-NR	High loading of 765 kV Agra-Gwalior (1000 MW SPS setting on each circuit of 765 kV Gwalior-Agra)						
NR-ER	(n-1) contingency of 400 kV Allahabad-Pusauli						
ER-NR	(n-1) contingency of 400 kV Kahalgaon-Biharshariff						
W3-ER	(n-1) contingency of 400kV Sterilte-Rourkela S/C						
ER-W3	High loading of 400 kV Raipur-Bhadrawati T/C, Bhilai-Bhadrawati S/C, Bhilai-Koradi and Bhilai-Seoni*						
EK-W3	(n-1) contingency of 400kV Raigarh-Sterlite						
	1. Commissioning of 765kV Raichur-Sholapur S/C						
WR-SR &	2. Based on the operational experience after the synchronization of SR grid with NEW grid and due to inadvertent						
ER-SR	variation of 765kV Raichur-Sholapur line flow, observation of Low Frequency Oscillations (LFO)						
	Considering transfer capability assessment by CTU on NEW-SR corridor.						
SR-WR	Bhadrawati HVDC B/B link capacity						
SR-ER							
ER-NER	(n-1) contingency of 400 kV Kahalgaon-Biharshariff						
NER-ER	(n-1) contingency of 400 kV Farakka-Malda						
S1-S2	(n-1) contingency of 400 kV Kolar-Hosur D/C line, 400kV Hosur-Salem S/C						
51-52	and 400kV Somanahalli-Salem S/C line.						
Import of	()) of SIGT of Class						
Punjab	(n-1) contingency of ICT at Patiala/Moga						
W3 zone	(1)						
Injection	(n-1) contingency of 400 kV 400 kV Raipur-Wardha						

^{*}Primary constraints

^{• 765} kV Gwalior-Agra one circuit
• 765 kV Bina-Gwalior one circuit

Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER									
	1st February 2014	00-07 16-17 23-24	6500	800	5700	5299	401		
	,	07-16' 17-23	5800 5800		5000 5000		0		
	2nd February 2014 to 5th February 2014	00-17 23-24 17-23	6500 5800	800	5700 5000	5299	401		
	6th February 2014	00-17 23-24	7500	800	6700	5299	1401		
	7th February 2014	17-23 00-17 23-24	7000	800	6200	5299	901		
	8th Februray 2014 to	17-23 00-07 23-24	7000 7500		6200 6700		901 1401		
NR ¹	9th Februray 2014	07-17' 17-23	6900 7000	800	6100 6200	5299	801 901		
	10th February 2014 to 11h February 2014	00-17 23-24 17-23	7500 7000	800	6700 6200	5299	1401 901		
	12th February 2014	00-17 23-24 17-23	7800 7300	800	7000 6500	5687	1313 813		
	13th February 2014	00-08 12-17 23-24	7800	800	7000	5774	1226		Revised due to Emergency shutdown of 765kV
	14th February 2014 to	08-12' 17-23 00-17	5800 7300 7800		5000 6500 7000		0 726 1226	-2000	Gwalior Bus-1
	28th February 2014	23-24 17-23 00-07	7300	800	6500	5774	726		
	1st February 2014	16-17 23-24 07-16'	350 320	50	300 270	230	70		
	2nd February 2014 to 5th February 2014	17-23 00-17 23-24	330 350	50	300	230	50 70		
	6th February 2014	17-23 00-17 23-24	330 720	50	280 670	230	50 440		
NER ²	7th February 2014	17-23 00-17 23-24	640 720	50	590 670	230	360 440		
	8th Februray 2014 to	17-23 00-07	640 720		590 670		360 440		
	9th Februray 2014 to	23-24 07-17' 17-23	500 640	50	450 590	230	220 360		
	10th February 2014 to 28th February 2014	00-17 23-24 17-23	720 640	50	670 590	230	440 360		
WR									
SR	1st February 2014 to	00-05 10-19	1550	0	1550	1550	0		
)K	28th February 2014	05-10 19-24	1550	U	1550	1550	0		

- 1. WR-NR Total Transfer capability will be reduced to 3100 MW in case of outage of any one of the following sections:
 - 765 kV Gwalior-Agra one circuit
 - 765 kV Bina-Gwalior one circuit

2. ER-NER Total Transfer capability will be reduced to 450 MW in case of outage of any one of the 400kV Purnea-Biharshariff circuit.

Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR*	1st February 2014 to 28th February 2014	00-17 23-24	3500	700	2800	286	2514		
	2011 February 2014	17-23	3600		2900		2614		
NER	1st February 2014 to	00-17 23-24	570	100	470	0	470		
	28th February 2014	17-23	570		470	,	470		
WR									
WK									
SR*	1st February 2014 to	00-17 23-24	2100	0	2100	197	1903		
	28th February 2014	17-23	2100		2100	,	1903		

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Limiting Constraints

NR -	Import	(n-1) contingency of 400 kV Kahalgaon-Biharshariff High loading of 765 kV Agra-Gwalior (1000 MW SPS setting on each circuit of 765 kV Gwalior-Agra)
	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak. (n-1) contingency of 400 kV Allahabad-Pusauli
NER	Import	(n-1) contingency of 400 kV Kahalgaon-Biharshariff
NEK	Export	(n-1) contingency of 400 kV Farakka-Malda
SR	Import	 Commissioning of 765kV Raichur-Sholapur S/C Based on the operational experience after the synchronization of SR grid with NEW grid and due to inadvertent variation of 765kV Raichur-Sholapur line flow, observation of Low Frequency Oscillations (LFO) Considering transfer capability assessment by CTU on NEW-SR corridor.
	Export	

^{*}Primary constraints

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor Affected
1	06-11-2013	Whole Month	Revised considering the LTA/MTOA on NR-ER Path	NR-ER
			Revised due to change in Load Generation in WR/NR	WR-NR
2	27-11-2013	Whoe Month	Commissioning of 400 kV Purnea-Biharshariff D/C and Network reconfiguration at Malda & Purnea.	ER-NR/ER-NER
		WOILLI	Revised due to change in Inter-Regional flow pattern and Load generation change in ER/WR.	W3 Zone Injection
3	22-01-2014	Whoe Month	Revised due to commissioning of 765kV Raichur-Sholapur S/C	WR-SR/ER-SR
		01.02.14 - 06.02.14	Revised due to shutdown of 400kV Kahalgaon-Biharshariff D/C	ER-NR/ER-NER
4	29-01-2014	07.02.14 - 28.02.14	Revised due to shutdown of TEESTA Power Station	ER-NR
	Whole Month		Revside due to Non-Commissioning of Kudankulam U-1, Vallur U-3 & NLC Exp U-1	S1-S2
5	30-01-2014	01.02.14 - 06.02.14	Revised due to change in ER and Inter-regional flow pattern.	ER-NER/ER-NR
6	31-01-2014	01.02.14	Revised due to shutdown of 400kV Seoni-Bhilai	W3 Zone Injection
7	31-01-2014	01.02.14	Revised due to shutdown of Purnea-Malda ckt-1	ER-NER/ER-NR
8	05-02-2014	06.02.14 - 28.02.14	Revised due to restoration of 400 kV Kahalgaon-Biharshariff D/C	ER-NER/ER-NR
0	07.02.2014	08.02.14 - 09.02.14	Revised due to shutdown of 400 kV Purnea-Muzaffarpur D/C	ER-NR / ER-NER
9	9 07-02-2014		Revised due to shutdown of 400 kV Jharsuguda-Rourkela 2 and 400 kV SEL-Rourkela 2	W3-ER
10	10-02-2014	11.02.14	Revised due to shutdown of 400 kV Sterlite-Raigarh Ckt 1	W3-ER
11	11-02-2014	11.02.14	Revised due to change in Inter-regional flow pattern & COD of Sasan UMPP Unit-2	WR-NR
			Margin revised due to allocation of Power to Bangaldesh.	W3-ER
12	12-02-2014	13-02-2014	Revised due to Emergency shutdown of 765kV Gwalior Bus-1	WR-NR/ Import of NR