Issue Date: 15/02/2014 Issue Time: 1200 hrs Revision No. 13

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR-WR *	1st February 2014 to 28th February 2014	00-24	2500	500	2000	286	1714		
	1st February 2014 to 11th February 2014	00-17 23-24	3900	500	3400	3181	219		
	,	17-23 00-17	3900		3400	3181	219		
	12th February 2014	23-24 17-23	4200 4200	500	3700 3700	3569	131		
WR-NR ¹		00-08	4200		3700		44		
	13th February 2014	12-24 08-12'	3200	500	2700	3656	0		
	14th February 2014 to	00-17	4200	500	3700	2656	44		
	28th February 2014	23-24 17-23	4200	500	3700	3656	44		
		00-17							
NR-ER *	1st February 2014 to 28th February 2014	23-24	1000	200	800	200	600		
		17-23 00-07	1100		900		700		
	1st February 2014	16-17 23-24	2600	300	2300	2118	182		
		07-16' 17-23	1900 1900	-	1600 1600		0		
	2nd February 2014 to	00-17 23-24	2600	300	2300	2118	182		
	5th February 2014	17-23	1900	300	1600	2110	0		
	6th February 2014	00-17 23-24	3600	300	3300	2118	1182		
ER-NR		17-23	3100		2800		682		
	7th February 2014	00-17 23-24	3600	300	3300	2118	1182		
		17-23 00-07	3100		2800		682		
	8th February 2014 to	23-24	3600	300	3300	2118	1182		
	9th Februray 2014	07-17' 17-23	3000 3100		2700 2800		582 682		
	10th February 2014 to	00-17 23-24	3600		3300	2118	1182		
	28th February 2014	17-23	3100		2800	2110	682		
	1st February 2014 to	00-24	1800	300	1500	0	1500		
	08th February 2014	00-07	1800	300	1500	0	1500		
	09th Februray 2014	18-24 07-18'	1300	300	1000	0	1000		
	10th February 2014	00-24	1800	300	1500	0	1500		
	11th Februray 2014	00-09 18-24	1800	300	1500	0	1500		
W3-ER	,	09-18'	1500	300	1200	0	1200		
	12th Februray 2014 to 15th Februray 2014	00-24	1800	300	1500	60	1440		
	16th Februray 2014	00-08 19-24	1800	300	1500	60	1440		Revised due to shutdown of 400kV
	Tour reordinay 2014	08-19'	1600	500	1300	00	1240	-200	Sipat-Ranchi D/C
	17th Februray 2014 to 28th Februray 2014	00-24	1800	300	1500	60	1440		
ER-W3	1st February 2014 to 28th February 2014	00-24	1000	300	700	700	0		
WR-SR	1st February 2014 to 28th February 2014	00-24	850	0	850	850	0		
SR-WR *	1st February 2014 to 28th February 2014	00-24	1000	0	1000	0	1000		

Issue Date: 15/02/2014 Issue Time: 1200 hrs Revision No. 13

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER-SR	1st February 2014 to 28th February 2014	00-05 10-19 05-10	700	0	700	700	0		
	28th February 2014	19-24	700		700		0		
SR-ER *	1st February 2014 to 28th February 2014	00-17 23-24 17-23	1100 1100	0	1100 1100	197	903		
		17-23	1100		1100		903		
ER-NER ²	1st February 2014	00-07 16-17 23-24 07-16' 17-23	350 320 330	50	300 270 280	230	70 40 50		
	2nd February 2014 to 5th February 2014	00-17 23-24	350	50	300	230	70		
	6th February 2014	00-17 720	50	280 670	230	50 440			
ER-NER ²	7th February 2014	17-23 00-17 23-24	720	50	590 670	230	360 440		
	8th February 2014 to 9th Februray 2014	17-23 00-07 23-24	720	50	590 670	230	360 440		
		07-17' 17-23	500 640		450 590		220 360		
	10th February 2014 to 28th February 2014	00-17 23-24 17-23	720 640	50	670 590	230	440 360		
NER-ER	1st February 2014 to 28th February 2014	00-17 23-24	570	100	470	0	470		
	28th February 2014	17-23	570		470		470		
S1-S2	1st February 2014 to 28th February 2014	00-24	5650	400	5250	4900	350		
Import of Punjab	1st February 2014 to 28th February 2014	00-24	5600	300	5300	3800	1500		
Import TTC for DD & DNH	1st February 2014 to 28th February 2014	00-24	980	0	980	LTA and MTO			
		00-08 23-24	8500		8300		670		
W3 zone	1st February 2014	08-16' 16-17 17-18 18-23	7600 8600 9100 9500	200	7400 8400 8900 9300	7630	-230 770 1270 1670		
Injection	2nd February 2014 to 28th February 2014	00-08 23-24 08-16'	8500 8000	200	8300 7800	7630	670 170		
d File B	ý	16-17 17-23	9000 9500	TA A STORY	9300 9300	1:	1170 1670	1.0	vanced transactions (Bilateral &

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

¹⁾ ER-SR TTC declared at Talcher Interconnector and Gazuwaka HVDC B/B seam

²⁾ S1 comprises of AP and Karnataka: S2 comprises of Tamil Nadu, Kerala and Pondicherry

³⁾ W3 comprises of the following regional entities:

a) Chattisgarh, b) Jindal Power Limited (JPL), c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak

f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCL

[#] The figure is based on LTA/MTOA approved by CTU. In actual Operation, due to Units being on Maintenance/ Fuel shortage the LTA/MTOA utilized would be les. RLDC/ NLDC would factor this situation while issuing STOA approvals

Issue Date: 15/02/2014 Issue Time: 1200 hrs Revision No. 13

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
----------	------	-------------------------	--	-----------------------	--	--	--	---	----------

- 1. WR-NR Total Transfer capability will be reduced to 3100 MW in case of outage of any one of the following sections:
 - 765 kV Gwalior-Agra one circuit
 - 765 kV Bina-Gwalior one circuit

2. ER-NER Total Transfer capability will be reduced to 450 MW in case of outage of any one of the 400kV Purnea-Biharshariff circuit.

Limiting Constraints

Corridor	Constraint
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.
WR-NR	High loading of 765 kV Agra-Gwalior (1000 MW SPS setting on each circuit of 765 kV Gwalior-Agra)
NR-ER	(n-1) contingency of 400 kV Allahabad-Pusauli
ER-NR	(n-1) contingency of 400 kV Kahalgaon-Biharshariff
W3-ER	(n-1) contingency of 400kV Sterilte-Rourkela S/C
ER-W3	High loading of 400 kV Raipur-Bhadrawati T/C, Bhilai-Bhadrawati S/C, Bhilai-Koradi and Bhilai-Seoni* (n-1) contingency of 400kV Raigarh-Sterlite
WR-SR & ER-SR	Commissioning of 765kV Raichur-Sholapur S/C Based on the operational experience after the synchronization of SR grid with NEW grid and due to inadvertent variation of 765kV Raichur-Sholapur line flow, observation of Low Frequency Oscillations (LFO) Considering transfer capability assessment by CTU on NEW-SR corridor.
SR-WR	Bhadrawati HVDC B/B link capacity
SR-ER	
ER-NER	(n-1) contingency of 400 kV Kahalgaon-Biharshariff
NER-ER	(n-1) contingency of 400 kV Farakka-Malda
S1-S2	(n-1) contingency of 400 kV Kolar-Hosur D/C line, 400kV Hosur-Salem S/C and 400kV Somanahalli-Salem S/C line.
Import of Punjab	(n-1) contingency of ICT at Patiala/Moga
W3 zone Injection	(n-1) contingency of 400 kV 400 kV Raipur-Wardha

^{*}Primary constraints

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER									
	1st February 2014	00-07 16-17 23-24	6500	800	5700	5299	401		
		07-16' 17-23	5800 5800		5000 5000		0		
	2nd February 2014 to 5th February 2014	00-17 23-24 17-23	6500 5800	800	5700 5000	5299	401		
	6th February 2014	00-17 23-24 17-23	7500	800	6700	5299	1401		
	7th February 2014	00-17 23-24	7000 7500	800	6200 6700	5299	1401		
1	8th Februray 2014 to	17-23 00-07 23-24	7000 7500		6200 6700		901		
NR ¹	9th Februray 2014	07-17' 17-23	6900 7000	800	6100 6200	5299	801 901		
	10th February 2014 to 11h February 2014	00-17 23-24 17-23	7500 7000	800	6700 6200	5299	1401 901		
	12th February 2014	00-17 23-24 17-23	7800 7300	800	7000 6500	5687	1313 813		
	13th February 2014	00-08 12-17 23-24 08-12'	7800	800	7000	5774	1226		
	14th February 2014 to	17-23 00-17 23-24	5800 7300 7800	800	6500 7000	5774	726 1226		
	28th February 2014 1st February 2014	17-23 00-07 16-17	7300 350	50	6500 300	230	726 70		
		23-24 07-16' 17-23	320 330		270 280		40 50		
	2nd February 2014 to 5th February 2014	00-17 23-24 17-23	350 330	50	300	230	70 50		
NER ²	6th February 2014	00-17 23-24 17-23	720 640	50	670 590	230	440 360		
	7th February 2014	00-17 23-24 17-23	720 640	50	670 590	230	440 360		
	8th Februray 2014 to 9th Februray 2014	00-07 23-24 07-17'	720 500	50	670 450	230	440		
	10th February 2014 to 28th February 2014	17-23 00-17 23-24	640 720	50	590 670	230	360 440		
WD	20th 1 conduity 2014	17-23	640		590		360		
WR		00.07							
SR	1st February 2014 to 28th February 2014	00-05 10-19 05-10 19-24	1550 1550	0	1550 1550	1550	0		

- 1. WR-NR Total Transfer capability will be reduced to 3100 MW in case of outage of any one of the following sections:
 - 765 kV Gwalior-Agra one circuit
 - 765 kV Bina-Gwalior one circuit

2. ER-NER Total Transfer capability will be reduced to 450 MW in case of outage of any one of the 400kV Purnea-Biharshariff circuit.

Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR*	1st February 2014 to 28th February 2014	00-17 23-24	3500	700	2800	286	2514		
	20th February 2014	17-23	3600		2900		2614		
NER	1st February 2014 to 28th February 2014	00-17 23-24	570	100	470	0	470		
	28th reducity 2014	17-23	570		470		470		
WR									
WK									
SR*	1st February 2014 to 28th February 2014	00-17 23-24	2100	0	2100	197	1903		
	2011 reducity 2014	17-23	2100		2100		1903		

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Limiting Constraints

	Import	(n-1) contingency of 400 kV Kahalgaon-Biharshariff
NR		High loading of 765 kV Agra-Gwalior (1000 MW SPS setting on each circuit of 765 kV Gwalior-Agra)
1110	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.
	Export	(n-1) contingency of 400 kV Allahabad-Pusauli
NER	Import	(n-1) contingency of 400 kV Kahalgaon-Biharshariff
NEK	Export	(n-1) contingency of 400 kV Farakka-Malda
		1. Commissioning of 765kV Raichur-Sholapur S/C
	Import	2. Based on the operational experience after the synchronization of SR grid with NEW grid and due to inadvertent
SR	Import	variation of 765kV Raichur-Sholapur line flow, observation of Low Frequency Oscillations (LFO)
		3. Considering transfer capability asessment by CTU on NEW-SR corridor.
	Export	

^{*}Primary constraints

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor Affected
1	06-11-13	Whole Month	Revised considering the LTA/MTOA on NR-ER Path	NR-ER
			Revised due to change in Load Generation in WR/NR	WR-NR
2	27-11-13	Whoe Month	Commissioning of 400 kV Purnea-Biharshariff D/C and Network reconfiguration at Malda & Purnea.	ER-NR/ER-NER
		Wionth	Revised due to change in Inter-Regional flow pattern and Load generation change in ER/WR.	W3 Zone Injection
3	22-01-14	Whoe Month	Revised due to commissioning of 765kV Raichur-Sholapur S/C	WR-SR/ER-SR
		01.02.14 - 06.02.14	Revised due to shutdown of 400kV Kahalgaon-Biharshariff D/C	ER-NR/ER-NER
4	29-01-14	07.02.14 - 28.02.14	Revised due to shutdown of TEESTA Power Station	ER-NR
		Whole Month	Revside due to Non-Commissioning of Kudankulam U-1, Vallur U-3 & NLC Exp U-1	S1-S2
5	30-01-14	01.02.14 - 06.02.14	Revised due to change in ER and Inter-regional flow pattern.	ER-NER/ER-NR
6	31-01-14	01.02.14	Revised due to shutdown of 400kV Seoni-Bhilai	W3 Zone Injection
7	31-01-14	01.02.14	Revised due to shutdown of Purnea-Malda ckt-1	ER-NER/ER-NR
8	05-02-14	06.02.14 - 28.02.14	Revised due to restoration of 400 kV Kahalgaon-Biharshariff D/C	ER-NER/ER-NR
9	07-02-14	08.02.14 - 09.02.14	Revised due to shutdown of 400 kV Purnea-Muzaffarpur D/C	ER-NR / ER-NER
9	07-02-14	09.02.14	Revised due to shutdown of 400 kV Jharsuguda-Rourkela 2 and 400 kV SEL-Rourkela 2	W3-ER
10	10-02-14	11.02.14	Revised due to shutdown of 400 kV Sterlite-Raigarh Ckt 1	W3-ER
11	11-02-14	11.02.14	Revised due to change in Inter-regional flow pattern & COD of Sasan UMPP Unit-2	WR-NR
			Margin revised due to allocation of Power to Bangaldesh.	W3-ER
12	12-02-14	13-02-14	Revised due to Emergency shutdown of 765kV Gwalior Bus-1	WR-NR/ Import of NR
13	15-02-14	16-02-14	Revised due to shutdown of 400kV Sipat-Ranchi D/C	W3-ER