Issue Date: 19/02/2014 Issue Time: 1220 hrs Revision No. 15

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR-WR *	1st February 2014 to 28th February 2014	00-24	2500	500	2000	286	1714		
	1st February 2014 to 11th February 2014	00-17 23-24	3900	500	3400	3181	219		
	12th February 2014	17-23 00-17 23-24	3900 4200	500	3400 3700	3181 3569	219 131		
WR-NR ¹		17-23 00-08	4200 4200		3700 3700		131 44		
	13th February 2014	12-24 08-12' 00-17	3200	500	2700	3656	0		
	14th February 2014 to 28th February 2014	23-24	4200 4200	500	3700 3700	3656	44		
NR-ER *	1st February 2014 to 28th February 2014	00-17 23-24	1000	200	800	200	600		
	1st February 2014	17-23 00-07 16-17	1100 2600	300	2300	2118	700 182		
	1st reolully 2014	23-24 07-16' 17-23	1900 1900	300	1600 1600	2110	0		
	2nd February 2014 to 5th February 2014	00-17 23-24 17-23	2600 1900	300	2300 1600	2118	182		
ER-NR	6th February 2014	00-17 23-24 17-23	3600 3100	300	3300 2800	2118	1182 682		
ERTA	7th February 2014	00-17 23-24	3600	300	3300 2800	2118	1182		
	8th February 2014 to 9th February 2014	17-23 00-07 23-24	3100 3600	300	3300	2118	682 1182		
		07-17' 17-23 00-17	3000 3100		2700 2800		582 682		
	10th February 2014 to 28th February 2014	23-24 17-23	3600 3100	300	3300 2800	2118	1182 682		
	1st February 2014 to 08th February 2014	00-24	1800	300	1500	0	1500		
	09th Februray 2014	00-07 18-24	1800	300	1500	0	1500		
	10th February 2014	07-18'	1300 1800	300	1000 1500	0	1000 1500		
W3-ER	11th Februray 2014	00-09 18-24	1800	300	1500	0	1500		
	12th Februray 2014 to	09-18'	1500	300	1200	0	1200		
	15th Februray 2014	00-24	1800	300	1500	60	1440		
	16th Februray 2014 17th Februray 2014 to	19-24 08-19' 00-24	1600 1800	300	1300	60	1240 1440		
ER-W3	28th Februray 2014 1st February 2014 to 28th February 2014	00-24	1000	300	700	700	0		
	1st February 2014 to	00-24	850	0	850	850	0		
WR-SR	18th February 2014 19th February 2014 to 28th February 2014	00-24	1000	0	1000	1000	0		Margin revised due to MTOA.
SR-WR *	1st February 2014 to 28th February 2014	00-24	1000	0	1000	0	1000		

Issue Date: 19/02/2014 Issue Time: 1220 hrs Revision No. 15

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
	1st February 2014 to	00-05 10-19	700		700		0		
	18th February 2014	05-10	700	0	700	700	0		
ER-SR		19-24 00-05	750		750		93		
	19th February 2014 to 28th February 2014	10-19 05-10	750	0	750	657	93		Margin revised due to MTOA
	1st February 2014 to	19-24 00-17							
SR-ER *	28th February 2014	23-24 17-23	1100	0	1100	197	903		
		00-07							
ER-NER ²	1st Fohrmery 2014	16-17	350	50	300	230	70		
ER-NER	1st February 2014	23-24 07-16'	320	50	270	230	40		
		17-23 00-17	330		280		50		
	2nd February 2014 to 5th February 2014	23-24	350	50	300	230	70		
	· · · · · · · · · · · · · · · · · · ·	17-23 00-17	330		280		50		
	6th February 2014	23-24	720	50	670 590	230	440		
		17-23 00-17	640				360		
	7th February 2014	23-24 17-23	720 640	50	670 590	230	360		
		00-07	720	50	670	230	440		
ER-NER ²	8th February 2014 to 9th Februray 2014	23-24 07-17'	500		450		220		
EK-NEK	1 colulay 2014	17-23	640		590		360		
	10th February 2014 to 19th February 2014	00-17 23-24	720	50	670	230	440		
		17-23	640		590		360		
	20th February 2014 21st February to 28th February 2014	00-07 07-17'	720 650	50	670 600	220	370	-70	
		17-23	590		540	230	310	-50	Revised due to shutdown of 220kV
		23-24 00-17	650		600		370	-70 70	Balipara - Samaguri S/C
		23-24 17-23	650 590		540	230	370	370 -70 310 -50	
	1st February 2014 to	00-17	570		470		470	-30	
	19th February 2014	23-24 17-23	570	100	470	0	470		
		00-07	570		470		470		
NER-ER	20th February 2014	07-17 23-24	520	100	420	0	420	-50	
		17-23	450		350		350	-120	Revised due to shutdown of 220kV Balipara - Samaguri S/C
	21st February 2014 to 28th February 2014	00-17 23-24	520	100	420	0	420	-50	
	28th February 2014	17-23	450		350		350	-120	
S1-S2	1st February 2014 to 28th February 2014	00-24	5650	400	5250	4900	350		
Import of	1st February 2014 to	00-24	5600	300	5300	3800	1500		
Punjab Import TTC	28th February 2014	55 24	5000	500	3300				
for DD & DNH	1st February 2014 to 28th February 2014	00-24	980	0	980	LTA and MTO	1 11		
		00-08 23-24	8500		8300		670		
	1st February 2014	08-16'	7600	200	7400	7630	-230		
	,	16-17 17-18	8600 9100		8400 8900		770 1270		
		18-23	9500		9300		1670		
W3 zone Injection	2nd February 2014 to	00-08 23-24	8500		8300		670		
пресноп	18th February 2014	08-16' 16-17	8000 9000	200	7800 8800	7630	170 1170		
		17-23	9500		9300		1670		
	19th February 2014 to 28th February 2014	00-17 23-24	9000	200	8800	7630	1170		
	(50 %) Countar flow hon	17-23	9500		9300		1670		

Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Issue Date: 19/02/2014 Issue Time: 1220 hrs Revision No. 15

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Short Term Open Access	Changes in TTC w.r.t. Last Revision	Comments
----------	------	-------------------------	--	-----------------------	--	--	---------------------------	---	----------

- 1) ER-SR TTC declared at Talcher Interconnector and Gazuwaka HVDC B/B seam
- 2) S1 comprises of AP and Karnataka: S2 comprises of Tamil Nadu, Kerala and Pondicherry
- 3) W3 comprises of the following regional entities:
 a) Chattisgarh, b) Jindal Power Limited (JPL), c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak
- f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCL
- # The figure is based on LTA/MTOA approved by CTU. In actual Operation, due to Units being on Maintenance/ Fuel shortage the LTA/MTOA utilized would be les. RLDC/ NLDC would factor this situation while issuing STOA approvals
- 1. WR-NR Total Transfer capability will be reduced to 3100 MW in case of outage of any one of the following sections:
 - 765 kV Gwalior-Agra one circuit
 - 765 kV Bina-Gwalior one circuit

2. ER-NER Total Transfer capability will be reduced to 450 MW in case of outage of any one of the 400kV Purnea-Biharshariff circuit.

Limiting Constraints

Corridor	Constraint
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.
WR-NR	High loading of 765 kV Agra-Gwalior (1000 MW SPS setting on each circuit of 765 kV Gwalior-Agra)
NR-ER	(n-1) contingency of 400 kV Allahabad-Pusauli
ER-NR	(n-1) contingency of 400 kV Kahalgaon-Biharshariff
W3-ER	(n-1) contingency of 400kV Sterilte-Rourkela S/C
ER-W3	High loading of 400 kV Raipur-Bhadrawati T/C, Bhilai-Bhadrawati S/C, Bhilai-Koradi and Bhilai-Seoni* (n-1) contingency of 400kV Raigarh-Sterlite
WR-SR & ER-SR	Commissioning of 765kV Raichur-Sholapur S/C Based on the operational experience after the synchronization of SR grid with NEW grid and due to inadvertent variation of 765kV Raichur-Sholapur line flow, observation of Low Frequency Oscillations (LFO) Considering transfer capability assessment by CTU on NEW-SR corridor.
SR-WR	Bhadrawati HVDC B/B link capacity
SR-ER	
ER-NER	(n-1) contingency of 400 kV Kahalgaon-Biharshariff
NER-ER	(n-1) contingency of 400 kV Farakka-Malda
S1-S2	(n-1) contingency of 400 kV Kolar-Hosur D/C line, 400kV Hosur-Salem S/C and 400kV Somanahalli-Salem S/C line.
Import of Punjab	(n-1) contingency of ICT at Patiala/Moga
W3 zone Injection	(n-1) contingency of 400 kV 400 kV Raipur-Wardha-Parli section

^{*}Primary constraints

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER									
	1st February 2014	00-07 16-17 23-24	6500	800	5700	5299	401		
		07-16' 17-23	5800 5800		5000 5000		0		
	2nd February 2014 to 5th February 2014	00-17 23-24	6500	800	5700	5299	401		
	6th February 2014	17-23 00-17 23-24	5800 7500	800	5000 6700	5299	0 1401		
		17-23 00-17	7000 7500	200	6200 6700		901		
	7th February 2014	23-24 17-23	7000	800	6200	5299	901		
NR¹	8th Februray 2014 to 9th Februray 2014	00-07 23-24	7500	800	6700	5299	1401		
	9th February 2014	07-17' 17-23 00-17	6900 7000		6100 6200		801 901		
	10th February 2014 to 11h February 2014	23-24 17-23	7500 7000	800	6700 6200	5299	901		
	12th February 2014	00-17 23-24 17-23	7800 7300	800	7000	5687	1313		
	13th February 2014	00-08 12-17 23-24	7800	800	7000	5774	1226		
		08-12' 17-23	5800 7300		5000 6500		0 726		
	14th February 2014 to 28th February 2014	00-17 23-24 17-23	7800 7300	800	7000 6500	5774	1226 726		
	1st February 2014	00-07 16-17 23-24	350	50	300	230	70		
		07-16' 17-23	320 330		270 280	-	40 50		
	2nd February 2014 to 5th February 2014	00-17 23-24 17-23	350 330	50	300	230	70 50		
	6th February 2014	00-17 23-24	720	50	670	230	440		
	7th February 2014	17-23 00-17 23-24	720	50	590 670	230	360 440		
NER ²	_	17-23 00-07	640 720		590 670		360 440		
	8th Februray 2014 to 9th Februray 2014	23-24 07-17' 17-23	500 640	50	450 590	230	220 360		
	10th February 2014 to 19th February 2014	00-17 23-24	720	50	670	230	440		
	20th February 2014	17-23 00-07 07-17' 17-23	640 720 650 590	50	590 670 600 540	230	360 440 370 310	-70 -50	Revised due to shutdown
	21st February to 28th February 2014	23-24 00-17 23-24 17-23	650 650 590	50	600 600 540	230	370 370 310	-70 -70 -50	of 220kV Balipara - Samaguri S/C

Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
WR									
	1st February 2014 to 18th February 2014	00-05 10-19	1550	0	1550	1550	0		
SR		05-10 19-24	1550		1550		0		
SK.	19th February 2014 to 28th February 2014	00-05 10-19	1750	0	1750	1657	93	·	Margin revised due to MTOA.
		05-10 19-24	1750		1750	1037	93	·	

2. ER-NER Total Transfer capability will be reduced to 450 MW in case of outage of any one of the 400kV Purnea-Biharshariff circuit.

Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR*	1st February 2014 to 28th February 2014	00-17 23-24	3500	700	2800	286	2514		
	20th rebruary 2014	17-23	3600		2900		2614		
	1st February 2014 to 19th February 2014	00-17 23-24	570	100	470	0	470		
		17-23	570		470		470		
	20th February 2014	00-07	570		470		470		
NER		07-17 23-24	520	100	420	0	420	-50	Revised due to shutdown
		17-23	450		350		350	-120	of 220kV Balipara -
	21st February 2014 to	00-17 23-24	520	100	420		420	-50	Samaguri S/C
	28th February 2014	17-23	450		350		350	-120	
WR									
WK									
SR*	1st February 2014 to 28th February 2014	00-17 23-24	2100	0	2100	197	1903		
4 F10 F	28th February 2014	17-23	2100	CATTA DATE	2100		1903		

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Limiting Constraints

NR	Import	(n-1) contingency of 400 kV Kahalgaon-Biharshariff High loading of 765 kV Agra-Gwalior (1000 MW SPS setting on each circuit of 765 kV Gwalior-Agra)
I NK	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak. (n-1) contingency of 400 kV Allahabad-Pusauli
NER	Import	(n-1) contingency of 400 kV Kahalgaon-Biharshariff
NEK	Export	(n-1) contingency of 400 kV Farakka-Malda
SR	Import	 Commissioning of 765kV Raichur-Sholapur S/C Based on the operational experience after the synchronization of SR grid with NEW grid and due to inadvertent variation of 765kV Raichur-Sholapur line flow, observation of Low Frequency Oscillations (LFO) Considering transfer capability assessment by CTU on NEW-SR corridor.
	Export	

^{*}Primary constraints

Revision	Date of	Period of	Deegen for Devision	Corridor
No	Revision	Revision	Reason for Revision	Affected
1	06-11-2013	Whole Month	Revised considering the LTA/MTOA on NR-ER Path	NR-ER
			Revised due to change in Load Generation in WR/NR	WR-NR
2	27-11-2013	Whoe	Commissioning of 400 kV Purnea-Biharshariff D/C and Network reconfiguration at Malda & Purnea.	ER-NR/ER-NER
		Month	Revised due to change in Inter-Regional flow pattern and Load generation change in ER/WR.	W3 Zone Injection
3	22-01-2014	Whoe Month	Revised due to commissioning of 765kV Raichur-Sholapur S/C	WR-SR/ER-SR
		01.02.14 - 06.02.14	Revised due to shutdown of 400kV Kahalgaon-Biharshariff D/C	ER-NR/ER-NER
4	29-01-2014	07.02.14 - 28.02.14	Revised due to shutdown of TEESTA Power Station	ER-NR
		Whole Month	Revside due to Non-Commissioning of Kudankulam U-1, Vallur U-3 & NLC Exp U-1	S1-S2
5	30-01-2014	01.02.14 - 06.02.14	Revised due to change in ER and Inter-regional flow pattern.	ER-NER/ER-NR
6	31-01-2014	01.02.14	Revised due to shutdown of 400kV Seoni-Bhilai	W3 Zone Injection
7	31-01-2014	01.02.14	Revised due to shutdown of Purnea-Malda ckt-1	ER-NER/ER-NR
8	05-02-2014	06.02.14 - 28.02.14	Revised due to restoration of 400 kV Kahalgaon-Biharshariff D/C	ER-NER/ER-NR
9	07-02-2014	08.02.14 - 09.02.14	Revised due to shutdown of 400 kV Purnea-Muzaffarpur D/C	ER-NR / ER-NER
9	07-02-2014	09.02.14	Revised due to shutdown of 400 kV Jharsuguda-Rourkela 2 and 400 kV SEL-Rourkela 2	W3-ER
10	10-02-2014	11.02.14	Revised due to shutdown of 400 kV Sterlite-Raigarh Ckt 1	W3-ER
11	11-02-2014	11.02.14	Revised due to change in Inter-regional flow pattern & COD of Sasan UMPP Unit-2	WR-NR
			Margin revised due to allocation of Power to Bangaldesh.	W3-ER
12	12-02-2014	13-02-2014	Revised due to Emergency shutdown of 765kV Gwalior Bus-1	WR-NR/ Import of NR
13	15-02-2014	16-02-2014	Revised due to shutdown of 400kV Sipat-Ranchi D/C	W3-ER
14	18-02-2014	19.02.14 -	Revised considering operational experience and margins on HVDC	ER-SR/WR-SR
14	10-02-2014	28.02.14	Review of flow pattern due to network topology change and Load Generation Balance.	W3 Zone Injection
15	19-02-2014	20.02.14 - 28.02.14	Revised due to shutdown of 220kV Balipara - Samaguri S/C	ER-NER/NER-ER
		20.02.14	Margin revised due to MTOA	WR-SR/ER-SR