

**National Load Despatch Centre  
Total Transfer Capability for February 2021**

Issue Date: 26th February 2021

Issue Time: 16:00 hrs

Revision No. 31

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR-WR*	1st February 2021 to 28th February 2021	00-06	2500	500	2000	195	1805		
		06-18				1281	719		
		18-24				195	1805		
WR-NR*	1st February 2021 to 04th February 2021	00-06	17850	500	17350	10800	6550		
			16900**		16400**	9850**			
		06-18	17850		17350	11189		6161	
		16900**	16400**	10239**					
	18-24	17850	17350	10800	6550				
		16900**	16400**	9850**					
	05th February 2021	00-06	17850	500	17350	10858	6492		
			16900**		16400**	9908**			
		06-18	17850		17350	11247		6103	
		16900**	16400**	10297**					
	18-24	17850	17350	10858	6492				
	16900**	16400**	9908**						
06th February 2021 to 08th February 2021	00-06	16650	500	16150	10858	5292			
		15700**		15200**	9908**				
	06-18	16650		16150	11247		4903		
	15700**	15200**	10297**						
18-24	16650	16150	10858	5292					
	15700**	15200**	9908**						
09th February 2021	00-06	16650	500	16150	10858	5292			
		15700**		15200**	9908**				
	06-08	16650		16150	11247		4903		
		15700**		15200**	10297**				
08-18	15600	15100	11247	3853					
	14650**	14150**	10297**						
18-24	15600	15100	10858		4242				
	14650**	14150**	9908**						
10th February 2021 to 11th February 2021	00-06	17850	500	17350	10881	6469			
		16900**		16400**	9931**				
	06-08	17850		17350	11270		6080		
		16900**		16400**	10320**				
08-18	16800	16300	11270	5030					
	15850**	15350**	10320**						
18-24	16800	16300	10881		5419				
	15850**	15350**	9931**						
12th February 2021 to 15th February 2021	00-06	17850	500	17350	10881	6469			
		16900**		16400**	9931**				
	06-18	17850		17350	11270		6080		
	16900**	16400**	10320**						
18-24	17850	17350	10881	6469					
	16900**	16400**	9931**						

**National Load Despatch Centre  
Total Transfer Capability for February 2021**

Issue Date: 26th February 2021

Issue Time: 16:00 hrs

Revision No. 31

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
WR-NR*	16th February 2021 to 19th February 2021	00-06	17400 16450**	500	16900 15950**	10881 9931**	6019		
		06-18	17400 16450**	500	16900 15950**	11270 10320**	5630		
		18-24	17400 16450**	500	16900 15950**	10881 9931**	6019		
	20th February 2021	00-06	17850 16900**	500	17350 16400**	10881 9931**	6469		
		06-18	17850 16900**	500	17350 16400**	11270 10320**	6080		
		18-24	17850 16900**	500	17350 16400**	10881 9931**	6469		
	21st February 2021	00-06	17400 16450**	500	16900 15950**	10881 9931**	6019		
		06-18	17400 16450**	500	16900 15950**	11270 10320**	5630		
		18-24	17400 16450**	500	16900 15950**	10881 9931**	6019		
	22nd February 2021	00-06	17850 16900**	500	17350 16400**	10881 9931**	6469		
		06-18	17850 16900**	500	17350 16400**	11270 10320**	6080		
		18-24	17850 16900**	500	17350 16400**	10881 9931**	6469		
	23rd February 2021	00-06	17400 16450**	500	16900 15950**	10881 9931**	6019		
		06-18	17400 16450**	500	16900 15950**	11270 10320**	5630		
		18-24	17400 16450**	500	16900 15950**	10881 9931**	6019		
	24th February 2021	00-06	17850 16900**	500	17350 16400**	10881 9931**	6469		
		06-18	17850 16900**	500	17350 16400**	11270 10320**	6080		
		18-24	17850 16900**	500	17350 16400**	10881 9931**	6469		
	25th February 2021	00-06	17850 16900**	500	17350 16400**	10881 9931**	6469		
		06-18	17850 16900**	500	17350 16400**	11270 10320**	6080		
		18-24	17850 16900**	500	17350 16400**	10881 9931**	6469		

**National Load Despatch Centre  
Total Transfer Capability for February 2021**

Issue Date: 26th February 2021

Issue Time: 16:00 hrs

Revision No. 31

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
	26th February 2021 to 28th February 2021	00-06	17850 16900**	500	17350 16400**	10881 9931**	6469		
		06-18	17850 16900**	500	17350 16400**	11270 10320**	6080		
		18-24	17850 16900**	500	17350 16400**	10881 9931**	6469		
NR-ER*	1st February 2021 to 12th February 2021	00-06	2000	200	1800	193	1607		
		06-18	2000		1800	303	1497		
		18-24	2000		1800	193	1607		
NR-ER*	13th February 2021 to 28th February 2021	00-06	2000	200	1800	193	1607		
		06-18	2000		1800	603	1197		
		18-24	2000		1800	193	1607		
ER-NR*	1st February 2021 to 05th February 2021	00-24	5500	300	5200	4066	1134		
ER-NR*	06th February 2021 to 08th February 2021	00-24	5400	300	5100	4066	1034		
ER-NR*	9th February 2021	00-08	5400	300	5100	4066	1034		
		08-24	5050	300	4750	4066	684		
ER-NR*	10th February 2021 to 11th February 2021	00-08	5500	300	5200	4066	1134		
		08-24	5150	300	4850	4066	784		
ER-NR*	11th February 2021 to 12th February 2021	00-24	5500	300	5200	4066	1134		
ER-NR*	13th February 2021 to 15th February 2021	00-24	5500	300	5200	4181	1019		
ER-NR*	16th February 2021 to 19th February 2021	00-24	5400	300	5100	4181	919		
ER-NR*	20th February 2021	00-24	5500	300	5200	4181	1019		
ER-NR*	21st February 2021	00-24	5400	300	5100	4181	919		
ER-NR*	22nd February 2021	00-24	5500	300	5200	4181	1019		
ER-NR*	23rd February 2021	00-24	5400	300	5100	4181	919		
ER-NR*	24th February 2021	00-24	5500	300	5200	4181	1019		
ER-NR*	25th February 2021	00-24	5500	300	5200	4181	1019		
ER-NR*	26th February 2021	00-24	5500	300	5200	4181	1019		
ER-NR*	27th February 2021 to 28th February 2021	00-24	5500	300	5200	4280	920		

**National Load Despatch Centre  
Total Transfer Capability for February 2021**

Issue Date: 26th February 2021

Issue Time: 16:00 hrs

Revision No. 31

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
W3-ER	1st February 2021 to 28th February 2021	00-24							No limit is being specified.
ER-W3	1st February 2021 to 28th February 2021	00-24							No limit is being specified.
WR-SR <sup>^</sup>	1st February 2021	00-05	8000	500	7500	4073	3427		
		05-12	8000		7500		3427		
		12-22	6700		6200		2127		
		22-24	6700		6200		2127		
WR-SR <sup>^</sup>	2nd February 2021	00-05	8000	500	7500	4073	3427		
		05-12	8000		7500		3427		
		12-22	6700		6200		2127		
		22-24	6700		6200		2127		
WR-SR <sup>^</sup>	3rd February 2021	00-05	8000	500	7500	4073	3427		
		05-12	8000		7500		3427		
		12-22	6700		6200		2127		
		22-24	6700		6200		2127		
WR-SR <sup>^</sup>	4th February 2021	00-07	6700	500	6200	4073	2127		
		07-22	6200		5700		1627		
		22-24	6200		5700		1627		
WR-SR <sup>^</sup>	5th February 2021	00-05	8000	500	7500	4107	3393		
		05-09	8000		7500		3393		
		09-22	6700		6200		2093		
		22-24	6700		6200		2093		
WR-SR <sup>^</sup>	6th February 2021	00-07	8000	500	7500	4107	3393		
		07-12	7400		6900		2793		
		12-22	6050		5550		1443		
		22-24	6050		5550		1443		
WR-SR <sup>^</sup>	7th February 2021	00-05	8000	500	7500	4107	3393		
		05-07	8000		7500		3393		
		07-22	7400		6900		2793		
		22-24	7400		6900		2793		
WR-SR <sup>^</sup>	8th February 2021 to 9th February 2021	00-07	8000	500	7500	4107	3393		
		07-12	7750		7250		3143		
		12-24	6200		5700		1593		
WR-SR <sup>^</sup>	10th February 2021	00-05	8000	500	7500	4107	3393		
		05-12	8000		7500		3393		
		12-22	6700		6200		2093		
		22-24	6700		6200		2093		
WR-SR <sup>^</sup>	11th February 2021 to 12th February 2021	00-05	8000	500	7500	4107	3393		
		05-22	8000		7500		3393		
		22-24	8000		7500		3393		
WR-SR <sup>^</sup>	13th February 2021 to 14th February 2021	00-05	8000	500	7500	4107	3393		
		05-07	8000		7500		3393		
		07-22	7150		6650		2543		
		22-24	7150		6650		2543		
WR-SR <sup>^</sup>	15th February 2021 to 18th February 2021	00-05	8000	500	7500	4107	3393		
		05-22	8000		7500		3393		
		22-24	8000		7500		3393		
WR-SR <sup>^</sup>	19th February 2021	00-05	8000	500	7500	4107	3393		
		05-07	8000		7500		3393		
		07-22	7500		7000		2893		
		22-24	7500		7000		2893		

**National Load Despatch Centre  
Total Transfer Capability for February 2021**

Issue Date: 26th February 2021

Issue Time: 16:00 hrs

Revision No. 31

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments			
WR-SR <sup>^</sup>	20th February 2021 to 26th February 2021	00-05	7500	500	7000	4107	2893					
		05-22	7500		7000		2893					
		22-24	7500		7000		2893					
WR-SR <sup>^</sup>	27th February 2021	00-07	7500	500	7000	4107	2893					
		07-22	7300		6800		2693					
		22-24	7300		6800		2693					
WR-SR <sup>^</sup>	28th February 2021	00-07	7500	500	7000	4107	2893	-500	TTC/ATC revised due to S/D of 400 kV Jeypore-Gazuwaka-2 (along with continuous s/d of HVDC Bhadravati Pole -1)			
		07-22	7300		6800		2693	-700				
		22-24	7300		6800		2693	-700				
SR-WR *	1st February 2021 to 28th February 2021	00-24	4600	400	4200	550	3650					
ER-SR <sup>^</sup>	1st February 2021 to 18th February 2021	00-06	5900	250	5650		2673	2977				
		06-18					2758	2892				
		18-24					2673	2977				
ER-SR <sup>^</sup>	19th February 2021 to 26th February 2021	00-06	5900	250	5650		2673	2977				
		06-07					5650	2758		2892		
		07-18					5900	5650		2758	2892	
		18-24					5900	5650		2673	2977	
ER-SR <sup>^</sup>	27th February 2021	00-07	5900	250	5650	2673	2977					
		07-18					5550	5300		2758	2892	
		18-24					5550	5300		2673	2977	
ER-SR <sup>^</sup>	28th February 2021	00-07	5900	250	5650	2673	2977		TTC/ATC revised due to S/D of 400 kV Jeypore-Gazuwaka-2 (along with continuous s/d of HVDC Bhadravati Pole -1)			
		07-18					5550	5300		2758	2892	-350
		18-24					5550	5300		2673	2977	-350
SR-ER *	1st February 2021 to 28th February 2021	00-24	No limit is being Specified.									
ER-NER*	1st February 2021 to 8th February 2021	00-02	1450	45	1405	474	931					
		02-07	1450		1405	474	931					
		07-12	1450		1405	474	931					
		12-17	1450		1405	474	931					
		17-21	1020		975	474	501					
		21-24	1450		1405	474	931					
ER-NER*	9th February 2021	00-02	1450	45	1405	474	931					
		02-07	1450		1405	474	931					
		07-12	1140		1095	474	621					
		12-17	1140		1095	474	621					
		17-21	770		725	474	251					
		21-24	1140		1095	474	621					
ER-NER*	10th February 2021 to 28th February 2021	00-02	1450	45	1405	474	931					
		02-07	1450		1405	474	931					
		07-12	1450		1405	474	931					
		12-17	1450		1405	474	931					
		17-21	1020		975	474	501					
		21-24	1450		1405	474	931					
NER-ER*	1st February 2021 to 8th February 2021	00-02	2850	45	2805	62	2743					
		02-07	2850		2805	62	2743					
		07-12	2850		2805	62	2743					
		12-17	2850		2805	62	2743					
		17-21	2950		2905	62	2843					
		21-24	2850		2805	62	2743					

**National Load Despatch Centre  
Total Transfer Capability for February 2021**

Issue Date: 26th February 2021

Issue Time: 16:00 hrs

Revision No. 31

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NER-ER*	9th February 2021	00-02	2850	45	2805	62	2743		
		02-07	2850		2805	62	2743		
		07-12	2700		2655	62	2593		
		12-17	2700		2655	62	2593		
		17-21	2800		2755	62	2693		
		21-24	2700		2655	62	2593		
NER-ER*	10th February 2021 to 28th February 2021	00-02	2850	45	2805	62	2743		
		02-07	2850		2805	62	2743		
		07-12	2850		2805	62	2743		
		12-17	2850		2805	62	2743		
		17-21	2950		2905	62	2843		
		21-24	2850		2805	62	2743		

**National Load Despatch Centre  
Total Transfer Capability for February 2021**

Issue Date: 26th February 2021

Issue Time: 16:00 hrs

Revision No. 31

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
----------	------	-------------------	---------------------------------	--------------------	-------------------------------------	--	--	-------------------------------------	----------

<b>W3 zone Injection</b>	1st February 2021 to 28th February 2021	00-24	No limit is being specified (In case of any constraints appearing in the system, W3 zone export would be revised accordingly)						
--------------------------	---	-------	---	--	--	--	--	--	--

**Note: TTC/ATC of S1-(S2&S3) corridor, Import of S3(Kerala), Import of Punjab and Import of DD & DNH is uploaded on NLDC website under Intra-Regional Section in Monthly ATC.**

\* Fifty Percent (50 % ) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

\*\*Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.

1) S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala

2) W3 comprises of the following regional entities :

a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak  
f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPC, n)Vandana Vidyut o)RKM, p)GMR Raikheda, q)Ind Barath and any other regional entity generator in Chhattisgarh

# The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis.

In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown :

- 1) The TTC value will be revised to normal values after restoration of shutdown.
- 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section

^Though 2X315 MVA, 400/220 kV ICTs at Maradam are N-1 non-compliant, the TTC of WR-SR and ER-SR corridor has not been restricted due to the same considering that this aspect will be managed by AP SLDC through appropriate measures like SPS implementation.

^In case of drawl of Karnataka beyond 3800 MW, the voltages in Bengaluru area are observed to be critically low. This issue may be taken care of by Karnataka SLDC by taking appropriate measures.

SR-WR TTC/ATC figures have been calculated considering 01 unit (800 MW) at Kudgi TPS in service. The figures are subject to change with change in generation at Kudgi TPS.

WR-NR/Import of NR TTC has been calculated considering generation at Pariccha TPS as 350 MW. TTC figures are subject to change with significant change in generation at Pariccha TPS.

Simultaneous Import Capability									
Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR*	1st February 2021 to 04th February 2021	00-06	23350 22400**	800	22550 21600**	14866 13916**	7684		
		06-09	23350 22400**		22550 21600**	15255 14305**	7295		
		09-17	23350 22400**		22550 21600**	15255 14305**	7295		
		17-18	23350 22400**		22550 21600**	15255 14305**	7295		
		18-24	23350 22400**		22550 21600**	14866 13916**	7684		
NR*	05th February 2021	00-06	23350 22400**	800	22550 21600**	14924 13974**	7626		
		06-09	23350 22400**		22550 21600**	15313 14363**	7237		
		09-17	23350 22400**		22550 21600**	15313 14363**	7237		
		17-18	23350 22400**		22550 21600**	15313 14363**	7237		
		18-24	23350 22400**		22550 21600**	14924 13974**	7626		
NR*	06th February 2021 to 08th February 2021	00-06	22050 21100**	800	21250 20300**	14924 13974**	6326		
		06-09	22050 21100**		21250 20300**	15313 14363**	5937		
		09-17	22050 21100**		21250 20300**	15313 14363**	5937		
		17-18	22050 21100**		21250 20300**	15313 14363**	5937		
		18-24	22050 21100**		21250 20300**	14924 13974**	6326		



NR*	9th February 2021	00-06	22050 21100**	800	21250 20300**	14924 13974**	6326	
		06-08	22050 21100**		21250 20300**	15313 14363**	5937	
		08-09	20650 19700**		19750 18900**	15313 14363**	4537	
		09-17	20650 19700**		19750 18900**	15313 14363**	4537	
		17-18	20650 19700**		19750 18900**	15313 14363**	4537	
		18-24	20650 19700**		19750 18900**	14924 13974**	4926	
NR*	10th February 2021 to 11th February 2021	00-06	23350 22400**	800	22550 21600**	14948 13998**	7602	
		06-08	23350 22400**		22550 21600**	15337 14387**	7213	
		08-09	21950 21000**		21150 20200**	15337 14387**	5813	
		09-17	21950 21000**		21150 20200**	15337 14387**	5813	
		17-18	21950 21000**		21150 20200**	15337 14387**	5813	
		18-24	21950 21000**		21150 20200**	14948 13998**	6202	
NR*	12th February 2021	00-06	23350 22400**	800	22550 21600**	14948 13998**	7602	
		06-09	23350 22400**		22550 21600**	15337 14387**	7213	
		09-17	23350 22400**		22550 21600**	15337 14387**	7213	
		17-18	23350 22400**		22550 21600**	15337 14387**	7213	
		18-24	23350 22400**		22550 21600**	14948 13998**	7602	

NR*	13th February 2021 to 15th February 2021	00-06	23350 22400**	800	22550 21600**	15063 14113**	7487	
		06-09	23350 22400**		22550 21600**	15452 14502**	7098	
		09-17	23350 22400**		22550 21600**	15452 14502**	7098	
		17-18	23350 22400**		22550 21600**	15452 14502**	7098	
		18-24	23350 22400**		22550 21600**	15063 14113**	7487	
NR*	16th February 2021 to 19th February 2021	00-06	22800 21850**	800	22000 21050**	15063 14113**	6937	
		06-09	22800 21850**		22000 21050**	15452 14502**	6548	
		09-17	22800 21850**		22000 21050**	15452 14502**	6548	
		17-18	22800 21850**		22000 21050**	15452 14502**	6548	
		18-24	22800 21850**		22000 21050**	15063 14113**	6937	
NR*	20th February 2021	00-06	23350 22400**	800	22550 21600**	15063 14113**	7487	
		06-09	23350 22400**		22550 21600**	15452 14502**	7098	
		09-17	23350 22400**		22550 21600**	15452 14502**	7098	
		17-18	23350 22400**		22550 21600**	15452 14502**	7098	
		18-24	23350 22400**		22550 21600**	15063 14113**	7487	
NR*	21st February 2021	00-06	22800 21850**	800	22000 21050**	15063 14113**	6937	
		06-09	22800 21850**		22000 21050**	15452 14502**	6548	
		09-17	22800 21850**		22000 21050**	15452 14502**	6548	
		17-18	22800 21850**		22000 21050**	15452 14502**	6548	
		18-24	22800 21850**		22000 21050**	15063 14113**	6937	

NR*	22nd February 2021	00-06	23350 22400**	800	22550 21600**	15063 14113**	7487	
		06-09	23350 22400**		22550 21600**	15452 14502**	7098	
		09-17	23350 22400**		22550 21600**	15452 14502**	7098	
		17-18	23350 22400**		22550 21600**	15452 14502**	7098	
		18-24	23350 22400**		22550 21600**	15063 14113**	7487	
NR*	23rd February 2021	00-06	22800 21850**	800	22000 21050**	15063 14113**	6937	
		06-09	22800 21850**		22000 21050**	15452 14502**	6548	
		09-17	22800 21850**		22000 21050**	15452 14502**	6548	
		17-18	22800 21850**		22000 21050**	15452 14502**	6548	
		18-24	22800 21850**		22000 21050**	15063 14113**	6937	
NR*	24th February 2021	00-06	23350 22400**	800	22550 21600**	15063 14113**	7487	
		06-09	23350 22400**		22550 21600**	15452 14502**	7098	
		09-17	23350 22400**		22550 21600**	15452 14502**	7098	
		17-18	23350 22400**		22550 21600**	15452 14502**	7098	
		18-24	23350 22400**		22550 21600**	15063 14113**	7487	
NR*	25th February 2021	00-06	23350 22400**	800	22550 21600**	15063 14113**	7487	
		06-09	23350 22400**		22550 21600**	15452 14502**	7098	
		09-17	23350 22400**		22550 21600**	15452 14502**	7098	
		17-18	23350 22400**		22550 21600**	15452 14502**	7098	
		18-24	23350 22400**		22550 21600**	15063 14113**	7487	

NR*	26th February 2021	00-06	23350 22400**	800	22550 21600**	15063 14113**	7487	
		06-09	23350 22400**		22550 21600**	15452 14502**	7098	
		09-17	23350 22400**		22550 21600**	15452 14502**	7098	
		17-18	23350 22400**		22550 21600**	15452 14502**	7098	
		18-24	23350 22400**		22550 21600**	15063 14113**	7487	
NR*	27th February 2021 to 28th February 2021	00-06	23350 22400**	800	22550 21600**	15162 14212**	7388	
		06-09	23350 22400**		22550 21600**	15551 14601**	6999	
		09-17	23350 22400**		22550 21600**	15551 14601**	6999	
		17-18	23350 22400**		22550 21600**	15551 14601**	6999	
		18-24	23350 22400**		22550 21600**	15162 14212**	7388	
NER*	1st February 2021 to 8th February 2021	00-02	1450	45	1405	474	931	
		02-07	1450		1405	474	931	
		07-12	1450		1405	474	931	
		12-17	1450		1405	474	931	
		17-21	1020		975	474	501	
		21-24	1450		1405	474	931	
NER*	9th February 2021	00-02	1450	45	1405	474	931	
		02-07	1450		1405	474	931	
		07-12	1140		1095	474	621	
		12-17	1140		1095	474	621	
		17-21	770		725	474	251	
		21-24	1140		1095	474	621	
NER*	10th February 2021 to 28th February 2021	00-02	1450	45	1405	474	931	
		02-07	1450		1405	474	931	
		07-12	1450		1405	474	931	
		12-17	1450		1405	474	931	
		17-21	1020		975	474	501	
		21-24	1450		1405	474	931	

WR*									
SR**	1st February 2021	00-06	13900	750	13150	6746	6404		
		06-12	13900		13150	6831	6319		
		12-18	12600		11850	6831	5019		
		18-24	12600		11850	6746	5104		
SR**	2nd February	00-06	13900	750	13150	6746	6404		
		06-12	13900		13150	6831	6319		
		12-18	12600		11850	6831	5019		
		18-24	12600		11850	6746	5104		
SR**	3rd February 2021	00-06	13900	750	13150	6746	6404		
		06-12	13900		13150	6831	6319		
		12-18	12600		11850	6831	5019		
		18-24	12600		11850	6746	5104		
SR**	4th February 2021	00-06	12600	750	11850	6746	5104		
		06-07	12600		11850	6831	5019		
		07-18	12100		11350	6831	4519		
		18-24	12100		11350	6746	4604		
SR**	5th February 2021	00-06	13900	750	13150	6780	6370		
		06-09	13900		13150	6865	6285		
		09-18	12600		11850	6865	4985		
		18-24	12600		11850	6780	5070		
SR**	6th February 2021	00-06	13900	750	13150	6780	6370		
		06-07	13900		13150	6865	6285		
		07-12	13300		12550	6865	5685		
		12-18	11950		11200	6865	4335		
		18-24	11950		11200	6780	4420		
SR**	7th February 2021	00-06	13900	750	13150	6780	6370		
		06-07	13900		13150	6865	6285		
		07-18	13300		12550	6865	5685		
		18-24	13300		12550	6780	5770		
SR**	8th February 2021 to 9th February 2021	00-06	13900	750	13150	6780	6370		
		06-07	13900		13150	6865	6285		
		07-12	13650		12900	6865	6035		
		12-18	12100		11350	6865	4485		
		18-24	12100		11350	6780	4570		
SR**	10th February 2021	00-06	13900	750	13150	6780	6370		
		06-12	13900		13150	6865	6285		
		12-18	12600		11850	6865	4985		
		18-24	12600		11850	6780	5070		
SR**	11th February 2021 to 12th February 2021	00-06	13900	750	13150	6780	6370		
		06-18	13900		13150	6865	6285		
		18-24	13900		13150	6780	6370		

SR**	13th February 2021 to 14th February 2021	00-06	13900	750	13150	6780	6370		
		06-07	13900		13150	6865	6285		
		07-18	13050		12300	6865	5435		
		18-24	13050		12300	6780	5520		
SR**	15th February 2021 to 18th February 2021	00-06	13900	750	13150	6780	6370		
		06-18	13900		13150	6865	6285		
		18-24	13900		13150	6780	6370		
SR**	19th February 2021	00-06	13900	750	13150	6780	6370		
		06-07	13900		13150	6865	6285		
		07-18	13400		12650	6865	5785		
		18-24	13400		12650	6780	5870		
SR**	20th February 2021 to 26th February 2021	00-06	13400	750	12650	6780	5870		
		06-18	13400		12650	6865	5785		
		18-24	13400		12650	6780	5870		
SR**	27th February 2021	00-06	13400	750	12650	6780	5870		
		06-07	13400		12650	6865	5785		
		07-18	12850		12100	6865	5235		
		18-24	12850		12100	6780	5320		
SR**	28th February 2021	00-06	13400	750	12650	6780	5870	-500	TTC/ATC revised due to S/D of 400 kV Jeypore-Gazuwaka-2 (along with continuous s/d of HVDC Bhadravati Pole -1)
		06-07	13400		12650	6865	5785	-500	
		07-18	12850		12100	6865	5235	-1050	
		18-24	12850		12100	6780	5320	-1050	
* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).									
**Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.									
* For approving STOA Bilateral transactions, margin available in Simultaneous Import of NR would be apportioned on WR-NR Corridor & ER-NR Corridor in the following ratio: Margin in Simultaneous import of NR = A WR-NR ATC =B ER-NR ATC = C  Margin for WR-NR applicants = A * B/(B+C) Margin for ER-NR Applicants = A * C/(B+C)									
Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section									
#Though 2X315 MVA, 400/220 kV ICTs at Maradam are N-1 non-compliant, the TTC of SR Import has not been restricted due to the same considering that this aspect will be managed by AP SLDC through appropriate measures like SPS implementation.									
In case of drawl of Karnataka beyond 3800 MW, the voltages in Bengaluru area are observed to be critically low. This issue may be taken care of by Karnataka by taking appropriate measures.									
WR-NR/Import of NR TTC has been calculated considering generation at Pariccha TPS as 350 MW. TTC figures are subject to change with significant change in generation at Pariccha TPS.									

Simultaneous Export Capability									
Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR*	1st February 2021 to 12th February 2021	00-06	4500	700	3800	388	3412		
		06-18			3800	1584	2216		
		18-24			3800	388	3412		
NR*	13th February 2021 to 28th February 2021	00-06	4500	700	3800	388	3412		
		06-18			3800	1884	1916		
		18-24			3800	388	3412		
NER*	1st February 2021 to 8th February 2021	00-02	2850	45	2805	62	2743		
		02-07	2850		2805	62	2743		
		07-12	2850		2805	62	2743		
		12-17	2850		2805	62	2743		
		17-21	2950		2905	62	2843		
		21-24	2850		2805	62	2743		
NER*	9th February 2021	00-02	2850	45	2805	62	2743		
		02-07	2850		2805	62	2743		
		07-12	2700		2655	62	2593		
		12-17	2700		2655	62	2593		
		17-21	2800		2755	62	2693		
		21-24	2700		2655	62	2593		
NER*	10th February 2021 to 28th February 2021	00-02	2850	45	2805	62	2743		
		02-07	2850		2805	62	2743		
		07-12	2850		2805	62	2743		
		12-17	2850		2805	62	2743		
		17-21	2950		2905	62	2843		
		21-24	2850		2805	62	2743		
WR*									
SR*^	1st February 2021 to 28th February 2021	00-24	3700	400	3300	1150	2150		

\* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section

^SR Export TTC/ATC figures have been calculated considering 01 unit (800 MW) at Kudgi TPS in service. The figures are subject to change with change in generation at Kudgi TPS.

<b>Limiting Constraints (Corridor wise)</b>		<b>Applicable Revisions</b>
<b>Corridor</b>	<b>Constraint</b>	
<b>WR-NR</b>	N-1 contingency of 1000 MVA, 765/400 kV ICT at Orai will overload the other ICT	Rev- 0
	N-1 contingency of 1500 MVA, 765/400 kV ICT at Agra will overload the other ICT	Rev- 1 to 31
<b>NR-ER</b>	(n-1) contingency of 400 kV Saranath-Pusauli	Rev- 0 to 31
<b>ER-NR</b>	1. N-1 contingency of 400 kV Mejia-Maithon A line will overload the other ckt. 2. Inter-regional flow pattern towards NR	Rev- 0 to 31
<b>WR-SR and ER-SR</b>	N-1 of one ICT of 765/400 kV, 1500 MVA ICT at Nizamabad will overload the other ICT	Rev- 0 to 31
	N-1 of one ckt of 765KV Angul-Srikakulam D/C will overload the other ckt	Rev- 23 to 26
	Low Voltage at Gazuwaka (East) Bus.	Rev- 0 to 31
<b>SR-WR</b>	a) N-1 contingency of one ckt of 400 kV Kolhapur-PG - Kolhapur-MS D/C will overload of the other ckt b) N-1 contingency of 500 MVA ICT at 400 kV Kolhapur-MS will overload the other 2x315 MVA ICTs	Rev- 0 to 31
<b>ER-NER</b>	a) N-1 contingency of 400 kV Bongaigaon - Azara line b) High Loading of 220 kV Salakati - BTPS D/C	Rev- 0 to 31
<b>NER-ER</b>	a) N-1 contingency of 400 kV Silchar- Azara line b) High Loading of 400 kV Silchar-Killing Line	Rev- 0 to 31
<b>W3 zone Injection</b>	---	Rev- 0 to 31

<b>Limiting Constraints (Simultaneous)</b>		<b>Applicable Revisions</b>	
<b>NR</b>	<b>Import</b>	1. N-1 contingency of 400 kV Mejia-Maithon A line will overload the other ckt. 2. Inter-regional flow pattern towards NR	Rev- 0 to 31
		N-1 contingency of 1000 MVA, 765/400 kV ICT at Orai will overload the other ICT	Rev- 0
	<b>Export</b>	N-1 contingency of 1500 MVA, 765/400 kV ICT at Agra will overload the other ICT	Rev-1 to 28
		(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.	Rev- 0 to 31
		(n-1) contingency of 400 kV Saranath-Pusauli	Rev- 0 to 31
<b>NER</b>	<b>Import</b>	a) N-1 contingency of 400 kV Bongaigaon - Azara line b) High Loading of 220 kV Salakati - BTPS D/C	Rev- 0 to 31
	<b>Export</b>	a) N-1 contingency of 400 kV Silchar- Azara line b) High Loading of 400 kV Silchar-Killing Line	Rev- 0 to 31
<b>SR</b>	<b>Import</b>	N-1 of one ICT of 765/400 kV, 1500 MVA ICT at Nizamabad will overload the other ICT	Rev- 0 to 22
		N-1 of one ckt of 765KV Angul-Srikakulam D/C will overload the other ckt	Rev- 23 to 31
		Low Voltage at Gazuwaka (East) Bus	Rev- 0 to 31
	<b>Export</b>	N-1 contingency of one ckt of 400 kV Kolhapur-PG - Kolhapur-MS D/C will overload of the other ckt N-1 contingency of 500 MVA ICT at 400 kV Kolhapur-MS will overload the other 2x315 MVA ICTs	Rev- 0 to 31



**National Load Despatch Centre  
Total Transfer Capability for February 2021**

Revision No	Date of Revision	Period of Revision	Reason for Revision/Comment	Corridor Affected
1	28th Dec 2020	Whole Month	a) Revision in STOA margin due to change in LTA Quantum from RWE_APL2_SECI-III (Ghadsisa, Wind) to Haryana from earlier 95 MW to 160 MW. b) Revision in TTC/ATC due to change in direction of HVDC BNC-AGRA as per grid requirement	WR-NR/Import of NR
2	28th January 2021	Whole Month	a) Revision in STOA margin of WR-NR/Import of NR due to change in LTA quantum from RWE_APL2_SECI-III (Ghadsisa, Wind) to Haryana from earlier 160 MW to 212.19 MW. b) Revision in STOA margin of WR-NR/Import of NR due to change in LTA quantum from ALFANAR_SECI-III to BYPL & BRPL from earlier 39.1 MW to 41.9 MW respectively.	WR-NR/Import of NR
			1) Change in Load-Generation of NER 2) Addition of 3rd unit (1x150 MW) of 4 x 150 MW Kameng Generation 3) Commissioning of 400 kV Imphal(PG) - New Kohima - New Mariani link and associated elements 4) Commissioning of 400/220 kV, 315 MVA ICT II at New Mariani 5) LTA figure revised in NER-ER after declaration of commercial operation of Kameng HEP (4x150MW) unit3 w.e.f 00:00Hrs of 22.01.2021	NER Import/Export
3	30th January 2021	01st Feb 2021	Revised TTC/ATC due to s/d of HVDC Raigarh - Pugalur Pole1 due to testing of Pole-3	WR-SR/SR Import
4	31st January 2021	02nd Feb 2021	Revised TTC/ATC due to s/d of HVDC Raigarh - Pugalur Pole1 due to testing of Pole-3	WR-SR/SR Import
5	01st February 2021	03rd Feb 2021	Revised TTC/ATC due to s/d of HVDC Raigarh - Pugalur Pole1 due to testing of Pole-3	WR-SR/SR Import
6	2nd February 2021	4th Feb 2021	Revised TTC/ATC due to s/d of HVDC Raigarh - Pugalur Pole1 due to testing of Pole-3	WR-SR/SR Import
7	3rd February 2021	5th Feb 2021	Revised TTC/ATC due to s/d of HVDC Raigarh - Pugalur Pole1 due to testing of Pole-3	WR-SR/SR Import
8	4th February 2021	5th Feb 2021 to 28th Feb 2021	Operationalization of LTA granted to M/s Adani Wind Energy Kutchh Three Limited :- a) 39.1 MW to UPPCL b) 18.4 MW to Chandigarh	WR-NR/NR Import
			c) 34.5 MW to KSEB	WR-SR/SR Import
9	4th February 2021	6th Feb 2021	TTC/ATC revised due to S/D of :- a) HVDC Raigarh – Pugalur Pole 1 (testing of Pole 3) b) 765kV Sholapur- Raichur-2	WR-SR/SR Import
10	5th February 2021	6th Feb 2021	TTC/ATC revised due to forced outage of HVDC Champa-Kurukshetra Pole-2	WR-NR/Import of NR
11	5th February 2021	7th Feb 2021	TTC/ATC revised due to forced outage of HVDC Champa-Kurukshetra Pole-2	WR-NR/Import of NR
			TTC/ATC revised due to S/D of 765kV Raichur- Sholapur-2	WR-SR/SR Import
12	6th February 2021	8th Feb 2021	TTC/ATC revised due to S/D of - a) HVDC Raigarh – Pugalur Pole 1 (testing of Pole 3) b) 765kV N.Parli- Warora- 2	WR-SR/SR Import
13	7th February 2021	9th Feb 2021	TTC/ATC revised due to S/D of - a) HVDC Raigarh – Pugalur Pole 1 (testing of Pole 3) b) 765kV N.Parli- Warora- 2	WR-SR/SR Import
			c) 400 kV Bongaigaon - Azara	NER Import/Export
14	8th February 2021	9th Feb 2021	TTC/ATC revised due to S/D of - HVDC Champa -Kurukshetra Pole 2 Shutdown of 765 kV Ajmer - Chittorgarh D/C	WR-NR, ER-NR & NR Import
15	8th February 2021	10th Feb 2021	TTC/ATC revised due to S/D of - a) 765 kV Ajmer - Chittorgarh D/C b) HVDC Raigarh – Pugalur Pole 1 (testing of Pole 3)	WR-NR, ER-NR & NR Import
				WR-SR/SR Import
16	9th Feb 2021	10th Feb 2021 to 28th Feb 2021	Operationalization of LTA granted to M/s Alfanar Energy Private Limited on available margins at Bhuj PS :- a) 14.4 to BSES Rajdhani Power Limited , Delhi b) 4.7 to BSES Yamuna Power Limited , Delhi c) 4.7 to TATA Power Delhi Distribuion Limited	WR-NR/Import of NR
17	9th Feb 2021	11th Feb 2021	TTC/ATC revised due to S/D of 765kV Ajmer - Chittorgarh D/C	WR-NR/Import of NR
18	11th Feb 2021	13th Feb 2021	TTC/ATC revised due to S/D of 765kV Wardha-Nizamabad-2	WR-SR/SR Import
19	12th Feb 2021	14th Feb 2021	TTC/ATC revised due to S/D of 765kV Wardha-Nizamabad-2	WR-SR/SR Import
20	12th Feb 2021	13th Feb 2021 to 28th Feb 2021	Revised due to operationalisation of 300MW MTOA granted form Azure Solar Power ,Rajashtan to Odisha	NR-ER/ NR Export
			Revised due to revised LTA granted for transfer of power from Nabinagar-1	ER-NR/ NR Import
21	14th Feb 2021	16th Feb 2021 to 19th Feb 2021	Revised TTC/ATC due to shutdown of 400KV Mainpuri-Orai (UP) D/C & 400KV Orai(UP)-Banda D/C	WR-NR/ER-NR/NR Import
22	17th Feb 2021	19th Feb 2021	TTC/ATC revised due to S/D of HVDC Bhadravati pole-1	ER-SR/WR-SR/SR Import
23	18th Feb 2021	19th Feb 2021	Revised TTC/ATC due to shutdown of HVDC Bhadravati Pole-1 considering Telangana LIS as 950 MW and present sysytem condition	ER-SR/WR-SR/SR Import
24	18th Feb 2021	20th Feb 2021 to 27th Feb 2021	Revised TTC/ATC due to continuous shutdown of HVDC Bhadravati Pole-1	WR-SR/SR Import
25	19th Feb 2021	21st Feb 2021	Revised TTC/ATC due to shutdown of 400KV Mainpuri-Orai (UP) D/C & 400KV Orai(UP)-Banda D/C	WR-NR/ER-NR/NR Import
26	22nd Feb 2021	23rd Feb 2021	Revised TTC/ATC due to shutdown of 400KV Mainpuri-Orai (UP) D/C & 400KV Orai(UP)-Banda D/C	WR-NR/ER-NR/NR Import
27	23rd Feb 2021	25th Feb 2021	Revised TTC/ATC due to shutdown of 400KV Mainpuri-Orai (UP) D/C & 400KV Orai(UP)-Banda D/C	WR-NR/ER-NR/NR Import
28	24th Feb 2021	25th Feb 2021	Revised due to revival of 400 kV Orai- Mainpuri D/C	WR-NR/ER-NR/NR Import
29	25th Feb 2021	27th Feb 2021	TTC/ATC revised due to S/D of 400 kV Jeypore-Gazuwaka-1 (along with continuous s/d of HVDC Bhadravati Pole -1)	WR-SR/SR Import
30	26th Feb 2021	27th Feb 2021 to 28th Feb 2021	Revised STOA margin due to operationalisation of 99 MW LTA from Chuzachen HEP to Haryana	ER-NR/ NR Import
31	26th Feb 2021	28th Feb 2021	TTC/ATC revised due to S/D of 400 kV Jeypore-Gazuwaka-2 (along with continuous s/d of HVDC Bhadravati Pole -1)	WR-SR/SR Import

ASSUMPTIONS IN BASECASE					
				Month : February 2021	
S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
I	NORTHERN REGION				
1	Punjab	7082	5944	3303	3219
2	Haryana	6885	6321	1819	1819
3	Rajasthan	11247	11020	7767	7739
4	Delhi	5022	3487	672	672
5	Uttar Pradesh	14329	15067	8642	8612
6	Uttarakhand	1773	1733	886	604
7	Himachal Pradesh	1015	861	190	139
8	Jammu & Kashmir	1494	1461	109	109
9	Chandigarh	251	159	0	0
10	ISGS/PPs	19	19	14286	11153
	Total NR	49117	46071	37675	34067
II	EASTERN REGION				
1	Bihar	4849	3097	352	344
2	Jharkhand	1502	1034	378	353
3	Damodar Valley Corporation	2755	2556	4353	3476
4	Orissa	3582	2895	2946	2400
5	West Bengal	6439	4457	4879	3510
6	Sikkim	112	45	0	0
7	Bhutan	162	168	270	214
8	ISGS/PPs	-162	-168	12566	8973
	Total ER	19239	14083	25743	19269
III	WESTERN REGION				
1	Maharashtra	18778	13739	12230	9486
2	Gujarat	15979	11721	11083	7999
3	Madhya Pradesh	15354	7101	7911	4031
4	Chattisgarh	4046	2689	2384	1953
5	Daman and Diu	339	292	0	0
6	Dadra and Nagar Haveli	814	774	0	0
7	Goa-WR	625	390	0	0
8	ISGS/PPs	4017	3424	41810	30230
	Total WR	59952	40130	75417	53699

S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
IV	SOUTHERN REGION				
1	Andhra Pradesh	9090	5024	6476	5986
2	Telangana	9542	10582	4884	4648
3	Karnataka	10315	5023	8110	3639
4	Tamil Nadu	14023	10332	6537	5162
5	Kerala	3838	2287	1665	95
6	Pondy	303	309	0	0
7	Goa-SR	47	48	0	0
8	ISGS/IPPs	0	0	13941	10412
	Total SR	47158	33605	41613	29942
V	NORTH-EASTERN REGION				
1	Arunachal Pradesh	105	66	12	8
2	Assam	1192	861	288	243
3	Manipur	224	109	0	0
4	Meghalaya	322	266	230	189
5	Mizoram	117	67	48	28
6	Nagaland	121	94	8	8
7	Tripura	225	135	75	75
8	ISGS/IPPs	139	85	2580	2126
	Total NER	2444	1683	3241	2676
	Total All India	177771	135487	183689	139653