National Load Despatch Centre Total Transfer Capability for February 2013

Issue Date: 2	21/02/2013		Issue Time	· 1300 hrs			Revision No.	11
issue Date: 2	.1/02/2013		155ue Tiile	. 1300 1118		T and T	1	**
Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Comments
	1st February 2013 to 18th February 2013	00-24	1500	200	1300	286	1014	
		00-08	1500	200	1300	286	1014	Revised due to Shutdown of 400kV
	19th February 2013	08-20'	1200	200	1000	286	714	Agra-Gwalior ckt#1
-	20th February 2013 to	20-24	1500	200	1300	286	1014	
-	21st February 2013	00-24	1500	200	1300	286	1014	Review and dynamic studies carried
NR-WR#	22nd February 2013	20-24	1700	-	1500	-	1214	out to assess transfer capability
		08-20'	1400	200	1200	286	914	Revised due to Shutdown of 400kV Agra-Gwalior ckt#2
	23rd Eabruary 2013	00-08 19-24	1700		1500		1214	Review and dynamic studies carried out to assess transfer capability
	23rd February 2013	08-19'	1400		1200		914	Revised due to Shutdown of 400kV Agra-Gwalior ckt#1
-	24th February 2013 to	00-24	1700	200	1500	286	1214	
	28th February 2013 1st February 2013 to	00-24	1700	200	1500	1040	460	LTA revised due to commisioning of
-	15th February 2013 16th February 2013 to							CGPL unit-40. Review and dynamic studies carried
	18th February 2013	00-24	2000	200	1800	1040	760	out to assess transfer capability
		00-08	2000	200	1800	1040	760	
	19th February 2013	08-20'	1600	200	1400	1040	360	Revised due to Shutdown of 400kV Agra-Gwalior ckt#1
		20-24	2000	200	1800	1040	760	
WR-NR#	20th February 2013 to 21th February 2013	00-24	2000	200	1800	1040	760	
	22nd February 2013	00-08 20-24	2000	- 200	1800	- 1040	760	
		08-20'	1600		1400		360	Revised due to Shutdown of 400kV Agra-Gwalior ckt#2
	23rd February 2013	00-08 19-24	2000		1800		760	
		08-19'	1600		1400		360	Revised due to Shutdown of 400kV Agra-Gwalior ckt#1
	24th February 2013 to 28th February 2013	00-24	2000	200	1800	1040	760	
NR-ER	1st February 2013 to 28th February 2013	00-17 23-24	800	200	600	0	600	
	1st February 2013 to	17-23 00-17	900		700	1912	700 488	
ER-NR	28th February 2013	23-24 17-23	2700	300	2400	1912	488	
W3-ER	1st February 2013 to 28th February 2013	00-24	1400	300	1100	0	1100	
ER-W3	1st February 2013 to	00-24	1000	250	750	750	0	
	28th February 2013							
WR-SR	1st February 2013 to 28th February 2013	00-24	1000	0	1000	992	8	
SR-WR	1st February 2013 to 28th February 2013	00-24	1000	0	1000	0	1000	
		00-05	950		950		780	Revised due to full availability of ER
	1st February 2013 to 5th February 2013		950	0		170	780	ISGS, TSTPP st-II and less drawal by
		10-19		0		170		
	5th February 2013	05-10 19-24	950*	0	950*	170	780*	Odisha.
·	5th February 2013	05-10 19-24 00-05 18-19	950		950* 950		780	
		05-10 19-24 00-05 18-19 10-18'	950 750	0	950* 950 750	170	780 580	Odisha. Revised due to Shutdown of 400kV Meramundali-Bolangir.
	5th February 2013	05-10 19-24 00-05 18-19 10-18' 05-10 19-24	950 750 950*		950* 950 750 950*		780 580 780*	Revised due to Shutdown of 400kV
ER-SR	5th February 2013	05-10 19-24 00-05 18-19 10-18' 05-10 19-24 00-05 10-19	950 750		950* 950 750		780 580	Revised due to Shutdown of 400kV
ER-SR	5th February 2013 6th February 2013	05-10 19-24 00-05 18-19 10-18' 05-10 19-24 00-05	950 750 950*	0	950* 950 750 950*	170	780 580 780*	Revised due to Shutdown of 400kV
ER-SR	5th February 2013 6th February 2013 7th February 2013	05-10 19-24 00-05 18-19 10-18' 05-10 19-24 00-05 10-19 05-10	950 750 950* 950	0	950* 950 750 950* 950	170	780 580 780* 780	Revised due to Shutdown of 400kV Meramundali-Bolangir. Revised due to outage of two units of
ER-SR	5th February 2013 6th February 2013	05-10 19-24 00-05 18-19 10-18' 05-10 19-24 00-05 10-19 05-10 19-24 00-05 10-19 05-10	950 750 950* 950 950*	0	950* 950 950 950* 950 950*	170	780 580 780* 780 780	Revised due to Shutdown of 400kV Meramundali-Bolangir.
ER-SR	5th February 2013 6th February 2013 7th February 2013 8th February 2013	05-10 19-24 00-05 18-19 10-18' 05-10 19-24 00-05 10-19 05-10 19-24 00-05 10-19 05-10 19-24 00-05	950 750 950* 950 950* 950* 500 500*	0	950* 950 950 950* 950 950* 500 500*	170	780 580 780* 780 780* 330 330*	Revised due to Shutdown of 400kV Meramundali-Bolangir. Revised due to outage of two units of Talcher Stage-1 and shutdown of
ER-SR	5th February 2013 6th February 2013 7th February 2013	05-10 19-24 00-05 18-19 10-18' 05-10 19-24 00-05 10-19 05-10 19-24 00-05 10-19 05-10 19-24	950 750 950* 950 950* 500	0	950* 950 750 950* 950 950* 950* 950* 950* 950* 950*	170	780 580 780* 780 780* 330	Revised due to Shutdown of 400kV Meramundali-Bolangir. Revised due to outage of two units of Talcher Stage-1 and shutdown of

National Load Despatch Centre Total Transfer Capability for February 2013

Issue Date: 21/02/2013			Issue Time: 1300 hrs			Revision No. 11			
Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Comments	
		00-17			1	1			
ER-NER	1st February 2013 to 28th February 2013	23-24	450	35	415	220	195		
	2800 reoldary 2013	17-23	450		415	220	195		
NER-ER	1st February 2013 to	00-17 23-24	490	100	390	0	390		
	28th February 2013	17-23	270		170		170		
S1-S2	1st February 2013 to 28th February 2013	00-24	5500	200	5300	4400	900	Revised due to non-commissioning of Kudamkulam unit	
Import of Punjab	1st February 2013 to 28th February 2013	00-24	5400	300	5100	3243	1857		
Import TTC for DD & DNH	1st February 2013 to 28th February 2013	00-24	980	0	980	LTA and MTOA as per ex-pp schedule			
W3 zone	1st February 2013 to 28th February 2013	00-17, 23-24	8000	8000 200 8500	7800	6413	1387	6413 MW corresponds to maximum effective LTA from W3. Export Margin from W3 would vary as per	
Injection		17-23	8500		8300	0413	1887	the maintenance schedule of generators in the zone.	

ER-SR TTC declared at Talcher Interconnector and Gazuwaka HVDC B/B seam
 A S1 comprises of AP and Karnataka: S2 comprises of Tamil Nadu, Kerala and Pondicherry
 W3 comprises of the following regional entities and would be operational wet 0000 hrs of 18th September 2012
 Chattisgark, b) Jindal Power Limited (PL), o) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak
 BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat
 * addirional 250 MW can be transferred to SR if injection point is South Odisha

Limiting Constraints

Corridor	Constraint
NR-WR	(n-1) contingency of 400kV Bina(PG)-Bina(MP)
WR-NR	(n-1) contingency of 400 kV Satna-Bina leading to overloading of 765/ 400 kV Bina transformer
NR-ER	(n-1) contingency of 400 kV Pusauli-Biharsharif
ER-NR	(n-1) contingency of 400 kV Farakka-Malda
W3-ER	(n-1) contingency of 400 kV Sterlite-Rourkela
ER-W3	High loading of 400 kV Raipur-Wardha, Raipur-Bhadrawati T/C, Bhilai-Bhadrawati S/C, Bhilai-Koradi and Bhilai-Scom ⁸ (n-1) contingency of 400kV Rourkela-Raigarh
WR-SR	Bhadrawati HVDC B/B link capacity
SR-WR	Bhadrawati HVDC B/B link capacity
ER-SR	(n-1) contingency of 400 kV Vijaywada-Nellore* Low Voltage in Chennai Area (n-1) contingency of 400 kV Rourkela-Talcher*
SR-ER	(n-1) contingency of 400 kV Farakka-Malda* (n-1) contingency of 400 kV Kadappa-Kolar and Neyvelli- Sriperumbudur
ER-NER	(n-1) contingency of 400 kV Farakka-Malda* High Loading of 220 kV BTPS-Agia (n-1) contingency of 400 kV Balipara – Bongaigaon-I
NER-ER	(n-1) contingency of 400 kV Binaguri-Bongaigaon-I (n-1) contingency of 400 kV Balipara-Bongaigaon-I High loading of 132 kV LTPS – Mariani S/C* (n-1) contingency of 220 kV Samaguri – Saruajai 1*
S1-S2	(n-1) contingency of 400 kV Hosur-Salem
Import of Punjab	(n-1) contingency of ICT at Moga
W3 zone export TTC	(n-1) contingency of 400 kV Raipur-Wardha and High loading of 400 kV Bhilai-Koradi

*Primary constraints

Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Comments
ER								
	1st February 2013 to 15th February 2013	00-24	4400		3900		948	LTA revised due to commisioning of CGPL unit-40.
	16th February 2013 to 18th February 2013	00-24	4700		4200		1248	Review and dynamic studies carried out to assess transfer capability
		00-08	4700	500	4200	2052	1248	
	19th February 2013	08-20'	4300	500	3800	2952	848	Revised due to Shutdown of 400kV Agra-Gwalior ckt#1
		20-24	4700		4200		1248	
NR#	20th February 2013 to 21st February 2013	00-24	4700		4200		1248	
		00-08 20-24	4700		4200	2952	1248	
	22nd February 2013	08-20'	4300	500	3800		848	Revised due to Shutdown of 400kV Agra-Gwalior ckt#2
	23rd February 2013	00-08 19-24	4700	500	4200		1248	
		08-19'	4300		3800		848	Revised due to Shutdown of 400kV Agra-Gwalior ckt#1
	24th February 2013 to 28th February 2013	00-24	4700	500	4200	2952	1248	
NER	1st February 2013 to	00-17 23-24	450	35	415	220	195	
	28th February 2013	17-23	450		415	220	195	
WR								
	1st February 2013 to	00-05 10-19	1950		1950	1162	788	Revised due to full availability of ER
	5th February 2013	05-10 19-24	1950*	0	950*		788*	ISGS, TSTPP st-II and less drawal by Odisha.
		00-05 18-19	1950		1950		788	
	6th February 2013	10-18'	1750	0	1750	1162	588	Revised due to Shutdown of 400kV Meramundali-Bolangir.
		05-10 19-24	1950*		950*		788*	Meranduldan-Bolangii.
SR	7th February 2013	00-05 10-19	1950	0	1950	1162	788	
	, and containly 2010	05-10 19-24	1950*	0	950*		788*	
	8th February 2013	00-05 10-19	1500	0	1500	1162	338	Revised due to outage of two units of Talcher Stage-I and shutdown of
	our rebruary 2013	05-10 19-24	1500*	U	1500*	1162	338*	Bolangir-Jeypore.
	9th February 2013 to	00-05 10-19	1950	0	1950	1162	788	
	28th February 2013	05-10 19-24	1950*	0	950*	1162	788*	

* additional 250 MW can be transferred to SR if injection point is South Odisha

Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Comments
ER-NR + ER-NER	1st February 2013 to 28th February 2013	00-17 23-24	3000	350	2650	2132	518	
ER-IVER	2011 1 cordary 2015	17-23	3000		2650	2132	518	
	1st February 2013 to 18th February 2013	00-17 23-24	2300		2100		1814	
	1801 February 2015	17-23	2400		2200		1914	
		00-08 23-24	2300		2100		1814	
	19th February 2013	08-17'	2000	200	1800	286	1514	Revised due to Shutdown of 400kV
		17-20	2100		1900		1614	Agra-Gwalior ckt#1
		20-23	2400		2200		1914	
	20th February 2013 to 21st February 2013	00-17 23-24	2300		2100		1814	
NR#		17-23	2400		2200		1914	
	22nd February 2013	00-08 20-24	2500	- 200	2300	286	2014	Review and dynamic studies carried out to assess transfer capability
		08-20'	2200		2000		1714	Revised due to Shutdown of 400kV Agra-Gwalior ckt#2
	23rd February 2013	00-08 19-24	2500		2300		2014	Review and dynamic studies carried out to assess transfer capability
		08-19'	2200		2000		1714	Revised due to Shutdown of 400kV Agra-Gwalior ckt#1
	24th February 2013 to 28th February 2013	00-24	2500	200	2300	286	2014	
NER	1st February 2013 to 28th February 2013	00-17 23-24	490	100	390	0	390	
	2001 February 2013	17-23	270		170		170	
WR								
SR	1st February 2013 to	00-17 23-24	1700	0	1700	197	1503	
	28th February 2013	17-23	1700		1700		1503	

Limiting Constraints

NR	Import	(n-1) contingency of 400 kV Farakka-Malda*
	•	(n-1) contingency of 400 kV Satna-Bina leading to overloading of 765/400 kV Bina transformer*
	Export	(n-1) contingency of 400kV Bina(PG)-Bina(MP)
		(n-1) contingency of 400 kV Pusauli-Biharsharif
NER	Import	High Loading of 220 kV BTPS-Agia
		(n-1) contingency of 400 kV Balipara – Bongaigaon-I
		(n-1) contingency of 400 kV Farakka-Malda*
	Export	High loading of 132 kV LTPS - Mariani*
		(n-1) contingency of 400 kV Binaguri-Bongaigaon & 400 kV Balipara-Bongaigaon-I
SR	Import	(n-1) Coningency of 400kV Gooty-Somanhalli & 400kV Gooty-Nelamangala line
		(n-1) contingency of 400 kV Rourkela-Talcher
		Low Voltage in Chennai Area
		(n-1) contingency of 400 kV Vijaywada-Nellore
	Export	(n-1) contingency of Chandrapur-Parli
		(n-1) contingency of 400 kV Maithon Kahalgaon
		(n-1) contingency of 400 kV Kadappa-Kolar and Neyvelli- Sriperumbudur
ER-NR + ER-NER	Frencet	(n-1) contingency of 400 kV Farakka-Malda

ASSUMPTIONS IN BASECASE

		Loa	ad	Generation		
S.No.	Name of State/Area	Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)	
Ι	NORTHERN REGION					
1	Punjab	5062	4141	2242	217	
2	Haryana	5017	4047	3122	312	
3	Rajasthan	7048	6700	3855	388	
4	Delhi	4179	3012	1416	141	
5	Uttar Pradesh	10478	9100	5500	533	
6	Jammu & Kashmir	1838	1380	235	25	
7	Uttarakhand	1333	1100	512	32	
8	Himachal Pradesh	1055	940	230	4	
9	Chandigarh	187	86	0	1070	
10	ISGS	20407	20500	16279	1079	
	Total NR	36197	30506	33392	2734	
	EASTERN REGION					
1	West Bengal	5300	3900	4600	375	
2	Jharkhand	900	770	390	35	
3	Orissa	3000	2200	2800	171	
4	Bihar	1500	1300	130	10	
5	Damodar Valley Corporation	2200	2000	1550	265	
6	Sikkim	60	50	0	200	
7	Bhutan	110	110	1400	27	
8	ISGS			6300	518	
	Total ER	13070	10330	17170	1401	
III	WESTERN REGION					
1	Chattisgarh	2977	2132	2518	202	
2	Madhya Pradesh	7112	4894	3443	280	
3	Maharashtra	15798	12916	13113	945	
4	Gujarat	10470	8369	9933	756	
5	Goa	327	198			
6	Daman and Diu	260	181			
7	Dadra and Nagar Haveli	612	479			
8	ISGS			13063	1199	
	Total WR	37556	29169	42070	3384	
IV	SOUTHERN REGION					
1	Andhra Pradesh	11120	9901	8032	675	
2	Tamil Nadu	10756	9471	5146	392	
3	Karnataka	8500	6242	5977	392	
4	Kerala	3305	2690	222	115	
5	Pondy	303	247			
6	Goa	84	84	44050	4004	
7	ISGS	0.4000	00005	11053	1081	
	Total SR	34068	28635	30430	2657	
v	NORTH-EASTERN REGION					
1	Manipur	105	74	0		
2	Meghalaya	280	196	121	11	
3	Mizoram	75	53	6		
4	Nagaland	115	81	12	1	
5	Assam	1200	800	230	21	
6	Tripura	200	140	100	10	
7	Arunachal Pradesh	105	74	0		
	ISGS	I		966	53	
8	1000			3001		
8	Total NER	0 2080	0 1418	1435	97	