

National Load Despatch Centre
Total Transfer Capability for February 2018

Issue Date: 28th November 2017

Issue Time: 1800 hrs

Revision No. 1

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
NR-WR*	1st February 2018 to 28th February 2018	00-06	2500	500	2000	55	1945			
		06-18								
		18-24								
WR-NR*	1st February 2018 to 28th February 2018	00-24	10050	500	9550	9322	228		Revised STOA margins due to reconfiguration of Rihand TPS Stage-III from Northern Region to Western Region	
NR-ER*	1st February 2018 to 28th February 2018	00-06	2000	200	1800	193	1607			
		06-18	2000		1800	303	1497			
		18-24	2000		1800	193	1607			
ER-NR*	1st February 2018 to 28th February 2018	00-24	4500	300	4200	3030	1170			
W3-ER	1st February 2018 to 28th February 2018	00-24	No limit is being specified.							
ER-W3	1st February 2018 to 28th February 2018	00-24	No limit is being specified.							
WR-SR	1st February 2018 to 28th February 2018	00-05	5700	500	5200	3675	1525			
		05-22	5700		5200		1525			
		22-24	5700		5200		1525			
SR-WR *	1st February 2018 to 28th February 2018	00-24	No limit is being Specified.							
ER-SR	1st February 2018 to 28th February 2018	00-06	3800	250	3550	3289	261			
		06-18					3374			176
		18-24					3289			261
SR-ER *	1st February 2018 to 28th February 2018	00-24	No limit is being Specified.							
ER-NER	1st February 2018 to 28th February 2018	00-17	1370	45	1325	225	1100			
		17-23	1310		1265		1040			
		23-24	1370		1325		1100			
NER-ER	1st February 2018 to 28th February 2018	00-17	1460	45	1415	0	1415			
		17-23	1420		1375		1375			
		23-24	1460		1415		1415			
W3 zone Injection	1st February 2018 to 28th February 2018	00-24	No limit is being specified (In case of any constraints appearing in the system, W3 zone export would be revised accordingly)							
Note: TTC/ATC of S1-(S2&S3) corridor, Import of S3(Kerala), Import of Punjab and Import of DD & DNH is uploaded on NLDC website under Intra-Regional Section in Monthly ATC.										

National Load Despatch Centre
Total Transfer Capability for February 2018

Issue Date: 28th November 2017

Issue Time: 1800 hrs

Revision No. 1

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
----------	------	-------------------	---------------------------------	--------------------	-------------------------------------	--	--	-------------------------------------	----------

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

1) S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala

2) W3 comprises of the following regional entities :

a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCCL, n)Vandana Vidyut o)RKM, p)GMR Raikheda, q)Ind Barath and any other regional entity generator in Chhattisgarh

The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown :

- 1) The TTC value will be revised to normal values after restoration of shutdown.
- 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER									
NR	1st February 2018 to 28th February 2018	00-05	14350	800	13550	12352	1198		Revised STOA margins due to reconfiguration of Rihand TPS Stage-III from Northern Region to Western Region
		05-08	14350		13550		1198		
		08-18	14350		13550		1198		
		18-23	13050		12250		0		
		23-24	14350		13550		1198		
NER	1st February 2018 to 28th February 2018	00-17	1370	45	1325	225	1100		
		17-23	1310		1265		1040		
		23-24	1370		1325		1100		
WR									
SR	1st February 2018 to 28th February 2018	00-05	9500	750	8750	6963	1787		
		05-06	9500		8750	6963	1787		
		06-18	9500		8750	7048	1702		
		18-22	9500		8750	6963	1787		
		22-24	9500		8750	6963	1787		

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

* For approving STOA Bilateral transactions, margin available in Simultaneous Import of NR would be apportioned on WR-NR Corridor & ER-NR Corridor in the following ratio:
 Margin in Simultaneous import of NR = A
 WR-NR ATC = B
 ER-NR ATC = C

 Margin for WR-NR applicants = $A * B / (B+C)$
 Margin for ER-NR Applicants = $A * C / (B+C)$

Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR*	1st February 2018 to 28th February 2018	00-06	4500	700	3800	248	3552		
		06-18			3800	368	3432		
		18-24	4500		3800	248	3552		
NER	1st February 2018 to 28th February 2018	00-17	1460	45	1415	0	1415		
		17-23	1420		1375		1375		
		23-24	1460		1415		1415		
WR									
SR *	1st February 2018 to 28th February 2018	00-24	No limit is being Specified.						

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Limiting Constraints (Corridor wise)

		Applicable Revisions
Corridor	Constraint	
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak	Rev-0, 1
WR-NR	1. (n-1) Contingency of 765kV Gwalior-Agra one ckt leads to 2750 MW loading on second circuit. Loading of 400kV Singrauli-Anpara S/C. 2.High	Rev-0, 1
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli	Rev-0, 1
ER-NR	(n-1) contingencies of N.Ranchi - Chandawa S/c & (n-1) contingencies of 400kV MPL- Maithon S/c	Rev-0, 1
WR-SR and ER-SR	a. (n-1) contingency of one ckt of 765 kV Wardha-Nizamabad D/C will lead to 874 MW loading on 400kV Vemagiri(PG)-Gazuwaka (When 400kV Vemagiri(PG)-Nunna S/C is not in service) b. (n-1) contingency of 400 kV Vemagiri - Vijaywada S/C will lead to high loading (874 MW) on 400 kV Vemagiri - Gazuwaka S/C (When 400 kV Vemagiri(PG) - Nunna S/C in kept in service) Low Voltage at Gazuwaka (East) Bus.	Rev-0, 1
ER-NER	a. (n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa b. High loading of 220 kV Balipara-Sonabil line(200 MW)	Rev-0, 1
NER-ER	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of 220 kV Samaguri - Sonabil line	Rev-0, 1
W3 zone Injection	---	Rev-0, 1

Limiting Constraints (Simultaneous)

		Applicable Revisions
NR	Import	(n-1) contingencies of N.Ranchi - Chandawa S/c & (n-1) contingencies of 400kV MPL- Maithon S/c. 1. (n-1) Contingency of 765kV Gwalior-Agra one ckt leads to 2750 MW loading on second circuit. 2.High Loading of 400kV Singrauli-Anpara S/C.
	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak. (n-1) contingency of 400 kV Saranath-Pusauli
NER	Import	a. (n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa b. High loading of 220 kV Balipara-Sonabil line(200 MW)
	Export	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of 220 kV Samaguri - Sonabil line
SR	Import	a. (n-1) contingency of one ckt of 765 kV Wardha-Nizamabad D/C will lead to 874 MW loading on 400kV Vemagiri(PG)-Gazuwaka (When 400kV Vemagiri(PG)-Nunna S/C is not in service) b. (n-1) contingency of 400 kV Vemagiri - Vijaywada S/C will lead to high loading (874 MW) on 400 kV Vemagiri - Gazuwaka S/C (When 400 kV Vemagiri(PG) - Nunna S/C in kept in service)
		Low Voltage at Gazuwaka (East) Bus.

**National Load Despatch Centre
Total Transfer Capability for February 2018**

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor Affected
1	28th Nov 2017	Whole month	Revised STOA margins due to reconfiguration of Rihand TPS Stage-III from Northern Region to Western Region	WR-NR/Import of SR

ASSUMPTIONS IN BASECASE					
				Month : February'18	
S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
I	NORTHERN REGION				
1	Punjab	7260	4982	2738	2593
2	Haryana	7075	4623	1422	1421
3	Rajasthan	9478	10567	5408	5393
4	Delhi	4322	2497	664	664
5	Uttar Pradesh	14386	15146	7921	8037
6	Uttarakhand	1865	1387	704	415
7	Himachal Pradesh	1575	624	250	134
8	Jammu & Kashmir	2368	1898	549	377
9	Chandigarh	245	139	0	0
10	ISGS/IPPs	25	26	19108	11535
	Total NR	48600	41891	38765	30569
II	EASTERN REGION				
1	Bihar	2561	2650	285	181
2	Jharkhand	860	890	266	210
3	Damodar Valley Corporation	2639	2731	4022	3974
4	Orissa	3014	3115	2366	2222
5	West Bengal	5149	5319	4227	4159
6	Sikkim	50	52	0	0
7	Bhutan	215	216	290	290
8	ISGS/IPPs	264	264	9339	8929
	Total ER	14752	15237	20795	19965
III	WESTERN REGION				
1	Maharashtra	18871	15370	12854	11475
2	Gujarat	13221	12028	10342	8753
3	Madhya Pradesh	10461	7272	4720	3977
4	Chattisgarh	4153	3073	2934	2168
5	Daman and Diu	324	281	0	0
6	Dadra and Nagar Haveli	714	729	0	0
7	Goa-WR	584	298	0	0
8	ISGS/IPPs	3874	3530	37426	34493
	Total WR	52202	42582	68275	60866

IV	SOUTHERN REGION				
1	Andhra Pradesh	8091	6737	5785	4120
2	Telangana	10020	7660	5232	3940
3	Karnataka	10686	7609	6873	3620
4	Tamil Nadu	14692	12232	7258	5466
5	Kerala	3727	2350	1313	76
6	Pondy	374	376	0	0
7	Goa-SR	84	85	0	0
8	ISGS/IPPs	0	0	14904	12929
	Total SR	47676	37050	41366	30151
V	NORTH-EASTERN REGION				
1	Arunachal Pradesh	100	54	0	0
2	Assam	962	761	214	123
3	Manipur	120	87	0	0
4	Meghalaya	242	174	190	58
5	Mizoram	78	58	8	8
6	Nagaland	88	76	12	6
7	Tripura	184	125	81	80
8	ISGS/IPPs	159	100	1516	1147
	Total NER	1935	1435	2021	1422
	Total All India	159918	132980	169205	141912