National Load Despatch Centre Total Transfer Capability for January 2014

Issue Date: 27/11/2013 Issue Time: 1300 hrs Revision No. 2

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
NR-WR *	1st January 2014 to 31st January 2014	00-24	2500	500	2000	286	1714			
WR-NR ¹	1st January 2014 to 31st January 2014	00-17 23-24 17-23	3900 3900	500	3400 3400	3181 3181	219 219	200	Revised due to change in Load Generation in WR/NR	
				I.						
NR-ER *	1st January 2014 to 31st January 2014	00-17 23-24 17-23	1000	200	800 900	200	600 700			
ER-NR *	1st January 2014 to 31st January 2014	00-17 23-24	3800	300	3500	2118	1382	1200	Commissioning of 400 kV Purnea- Biharshariff D/C and Network reconfiguration at Malda & Purnea	
		17-23		<u> </u>			1382		reconliguration at Maida & Purnea	
W3-ER	1st January 2014 to 31st January 2014	00-24	1800	300	1500	0	1500			
ER-W3	1st January 2014 to 31st January 2014	00-24	1000	300	700	700	0			
WR-SR	1st January 2014 to 31st January 2014	00-24	1000	0	1000	1000	0			
SR-WR *	1st January 2014 to 31st January 2014	00-24	1000	0	1000	0	1000			
		00-05								
	1st January 2014 to 31st January 2014	10-19	750	0	750		93	-350	Change in Load Generation Balance	
ER-SR		05-10 19-24	1100		1100	657	443	3	in ER	
SR-ER *	1st January 2014 to 31st January 2014	00-17 23-24	1100	0	1100	197	903			
		17-23	1100		1100		903			
	1.4 I 2014	00-17	700		650		440	250	Commissioning of 400 kV Purnea-	
ER-NER ²	1st January 2014 to 31st January 2014	23-24 17-23	720 640	50	670 590	230	360	270 190	Biharshariff D/C and Network reconfiguration at Malda & Purnea.	
	1st January 2014 to	00-17	570		470		470	190	recomiguration at ividina & r diffea.	
NER-ER	31st January 2014	23-24 17-23	570	100	470	0	470			
S1-S2	1st January 2014 to 31st January 2014	00-24	6200	400	5800	5400	400			
Import of Punjab	1st January 2014 to 31st January 2014	00-24	5600	300	5300	3800	1500			
Import TTC for DD & DNH	1st January 2014 to 31st January 2014	00-24	980	0	980	LTA and MTOA				
W3 zone	1st January 2014 to	00-08 23-24	8500		8300		670	-500	Revised due to change in Inter-	
Injection	31st January 2014	nuary 2014 08-16'	8000	200	7800	7630	170	-1000	Regional flow pattern and Load	
	·	16-17	9000		8800		1170		generation change in ER/WR.	
		17-23	9500		9300		1670			

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

¹⁾ ER-SR TTC declared at Talcher Interconnector and Gazuwaka HVDC B/B seam

²⁾ S1 comprises of AP and Karnataka: S2 comprises of Tamil Nadu, Kerala and Pondicherry

³⁾ W3 comprises of the following regional entities:
a) Chattisgarh, b) Jindal Power Limited (JPL), c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak

f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCL

National Load Despatch Centre Total Transfer Capability for January 2014

Issue Date: 27/11/2013 Issue Time: 1300 hrs Revision No. 2

The figure is based on LTA/MTOA approved by CTU. In actual Operation, due to Units being on Maintenance/ Fuel shortage the LTA/MTOA utilized would be les. RLDC/ NLDC would factor this situation while issuing STOA approvals.

1. WR-NR Total Transfer capability will be reduced to 3100 MW in case of outage of any one of the following sections:

- 765 kV Gwalior-Agra one circuit
 765 kV Bina-Gwalior one circuit

2. ER-NER Total Transfer capability will be reduced to 450 MW in case of outage of any one of the 400kV Purnea-Biharshariff circuit.

Limiting Constraints

Corridor	Constraint
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.
WR-NR	High loading of 765 kV Agra-Gwalior (1000 MW SPS setting on each circuit of 765 kV Gwalior-Agra)
NR-ER	(n-1) contingency of 400 kV Allahabad-Pusauli
ER-NR	(n-1) contingency of 400 kV Kahalgaon-Biharshariff
W3-ER	(n-1) contingency of 400kV Sterilte-Rourkela S/C
ER-W3	High loading of 400 kV Raipur-Bhadrawati T/C, Bhilai-Bhadrawati S/C, Bhilai-Koradi and Bhilai-Seoni* (n-1) contingency of 400kV Raigarh-Sterlite
WR-SR	Bhadrawati HVDC B/B link capacity
SR-WR	Bhadrawati HVDC B/B link capacity
ER-SR	Peak: (n-1) contingency of 400 kV Rourkela-Talcher
EK-SK	Off-Peak: 1. Talcher-Kolar HVDC Capacity; 2. (n-1) contingency of 400 kV Jeypore-Gazuwaka
ER-SR	
SR-ER	
ER-NER	(n-1) contingency of 400 kV Kahalgaon-Biharshariff
NER-ER	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa
S1-S2	(n-1) contingency of 400 kV Kolar-Hosur D/C line, 400kV Hosur-Salem S/C
T	and 400kV Somanahalli-Salem S/C line.
Import of Punjab	(n-1) contingency of ICT at Patiala/Moga
W3 zone Injection	(n-1) contingency of 400 kV 400 kV Raipur-Wardha

^{*}Primary constraints

Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER									
NR¹	1st January 2014 to 31st January 2014	00-17 23-24 17-23	7700 7700	800	6900 6900	5299	1601 1601	1400	Change in Load Generation in WR/NR and commissioning of 400kV Purnea-Biharshariff
NER ²	1st January 2014 to 31st January 2014	00-17 23-24 17-23	720 640	50	670 590	230	440	270	D/C, Network Changes. Commissioning of 400 kV Purnea-Biharshariff D/C and Network reconfiguration at Malda & Purnea.
WR		17 23	0.10		370		200	170	Maida & Furnea.
SR	1st January 2014 to	00-05 10-19	1750	0	1750	1657	93	-350	Change in Load Generation Balance in ER
	31st January 2014	05-10 19-24	2100		2100	1657	443		

- 1. WR-NR Total Transfer capability will be reduced to 3100 MW in case of outage of any one of the following sections:
 - 765 kV Gwalior-Agra one circuit
 - 765 kV Bina-Gwalior one circuit

2. ER-NER Total Transfer capability will be reduced to 450 MW in case of outage of any one of the 400kV Purnea-Biharshariff circuit.

Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR*	1st January 2014 to 31st January 2014	00-17 23-24	3500	700	2800	286	2514		
		17-23	3600		2900		2614	1	
NER	1st January 2014 to 31st January 2014	00-17 23-24	570	100	470	0	470		
		17-23	570		470		470		
WR									
WK									
SR*	1st January 2014 to 31st January 2014	00-17 23-24	2100	0	2100	197	1903		
		17-23	2100		2100		1903		

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Limiting Constraints

	Import	(n-1) contingency of 400 kV Kahalgaon-Biharshariff High loading of 765 kV Agra-Gwalior (1000 MW SPS setting on each circuit of 765 kV Gwalior-Agra)
NR	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak. (n-1) contingency of 400 kV Allahabad-Pusauli
NER	Import Export	(n-1) contingency of 400 kV Kahalgaon-Biharshariff N-1 contingency of 400/220 kV, 2x315 MVA ICTs at Misa
SR	Import	Bhadrawati HVDC B/B link capacity Peak: (n-1) contingency of 400 kV Rourkela-Talcher Off-Peak: 1. Talcher-Kolar HVDC Capacity; 2. (n-1) contingency of 400 kV Jeypore-Gazuwaka
	Export	

^{*}Primary constraints

National Load Despatch Centre Total Transfer Capability for January 2014

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor Affected
1	04-11-2013	Whole Month	Margin on NR-ER Corridor revised considering the LTA/MTOA on NR-ER Path	NR-ER
			Revised due to change in Load Generation in WR/NR	WR-NR
2	27-11-2013	M/b o o M o n t b	Commissioning of 400 kV Purnea-Biharshariff D/C and Network reconfiguration at Malda & Purnea.	ER-NR/ER-NER
2	27-11-2013	Whoe Month	Change in Load Generation Balance in ER	ER-SR
			Revised due to change in Inter-Regional flow pattern and Load generation change in ER/WR.	W3 Zone Injection

ASSUMPTIONS IN BASECASE

Month : January '14

		Loa	ad	Gener	ation
S.No.	Name of State/Area	Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
I	NORTHERN REGION				
1	Punjab	7000	4924	2546	2351
2	Haryana	5559	4660	2770	2770
3	Rajasthan	7051	6539	4002	4002
4	Delhi	3974	3720	1514	1514
5	Uttar Pradesh	11000	10322	6008	5756
6	Jammu & Kashmir	1876	1185	584	429
7	Uttarakhand	1543	902	713	340
8	Himachal Pradesh	1327	730	444	523
9	Chandigarh	224	118	0	0
10	ISGS/IPPs			16740	11303
	Total NR	39554	33100	35321	28988
II	EASTERN REGION				
1	West Bengal	4900	4500	4837	3944
2	Jharkhand	1110	770	561	561
3	Orissa	3500	2200	2430	1699
4	Bihar	1820	1320	0	0
5	Damodar Valley Corporation	2600	2035	3439	3039
6	Sikkim	40	40		
7	Bhutan	110	110	648	648
8	ISGS/IPPs	131	241	6494	6762
	Total ER	14211	11216	18409	16653
III	WESTERN REGION				
1	Chattisgarh	3181	2462	1804	1065
2	Madhya Pradesh	7637	5600	9905	7817
3	Maharashtra	15506	12500	4366	2928
4	Gujarat	11119	10121	11221	8374
5	Goa	432	281	0	0
6	Daman and Diu	245	208	0	0
7	Dadra and Nagar Haveli	604	471	0	0
8	ISGS/IPPs	590	590	16763	15466
	Total WR	39314	32233	44059	35650
			,		

IV	SOUTHERN REGION				
1	Andhra Pradesh	10900	9350	7204	6066
2	Tamil Nadu	11300	8617	6433	4962
3	Karnataka	7800	6499	5213	3549
4	Kerala	3225	2234	1917	760
5	Pondy	320	244	0	0
6	Goa	80	80	0	0
7	ISGS/IPPs			11130	10168
	Total SR	33625	27024	31897	25505
٧	NORTH-EASTERN REGION				
1	Manipur	130	91	0	0
2	Meghalaya	280	196	110	95
3	Mizoram	85	60	8	4
4	Nagaland	120	84	20	10
5	Assam	1350	970	220	180
6	Tripura	260	130	100	100
7	Arunachal Pradesh	130	91	0	0
8	ISGS/IPPs			1020	735
	Total NER	2355	1622	1478	1124
	Total All In Un	100575	408/25	424	400000
	Total All India	129059	105195	131164	107920