

**National Load Despatch Centre  
Total Transfer Capability for January 2015**

Issue Date: 30/12/2014

Issue Time: 1300 hrs

Revision No. 2

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR-WR *	1st January 2015 to 31st January 2015	00-24	2500	500	2000	1055	945		
WR-NR	1st January 2015 to 31st January 2015	00-17	4700	500	4200	4768	0		
		23-24							
		17-23							
NR-ER*	1st January 2015 to 31st January 2015	00-06	2000	200	1800	293	1507		
		06-18'							
		18-24							
ER-NR	1st January 2015 to 31st January 2015	00-17	3400	300	3100	2431	669		
		23-24							
		17-23							
W3-ER <sup>§</sup>	1st January 2015 to 31st January 2015	00-24	1800	300	1500	351	1149		
ER-W3	1st January 2015 to 31st January 2015	00-24	1000	300	700	973	0		
WR-SR ##	1st January 2015 to 31st January 2015	00-24	2100	750	1350	1350	0		
SR-WR *	1st January 2015 to 31st January 2015	00-24	No limit is being Specified.						
ER-SR ##	1st January 2015 to 31st January 2015	00-06	2650	0	2650	2585	65		
		18-24							
		06-18'							
SR-ER *	1st January 2015 to 31st January 2015	00-24	No limit is being Specified.						
ER-NER	1st January 2015 to 31st January 2015	00-17	650	50	600	210	390		
		23-24							
		17-23							
NER-ER	1st January 2015 to 31st January 2015	00-17	540	30	510	0	510		
		23-24							
		17-23							
S1-S2	1st January 2015 to 31st January 2015	00-24	3325	300	3025	2775	250	300	Revised due to NCTPS Stage -2 Unit-1 Outage Extension
Import of Punjab	1st January 2015 to 31st January 2015	00-24	5700	300	5400	3790	1610		
Import TTC for DD & DNH	1st January 2015 to 31st January 2015	00-24	1200	0	1200	LTA and MTOA as per ex-pp schedule			
W3 zone Injection	1st January 2015 to 31st January 2015	00-17	9400	200	9200	6862	2338		
		23-24							
		17-23							

\* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

- ## 1) 215 MW quantum of LTA is not being scheduled as per the CERC order dated 1st Oct 2014 for petition number 92/MP/2014  
## 2) 211 MW quantum of MTOA is not being scheduled as per the communication sent by GM (commercial), Powergrid dated 30th Sep 2014.  
## 3) considering (1), (2) & likelihood of commencement of above transactions, the margins would be released for short term transactions on day ahead basis.

§ As per Simulations, predominant direction of flow is on West to North Corridor. Hence, in case injection point is in Western Region (W1,W2,W3), STOA/PX transactions from West to North on West-East-North corridor shall not be allowed as such transaction increases congestion in the West to North Corridor.

- 1) ER-SR TTC declared at Talcher Interconnector and Gazuwaka HVDC B/B seam  
2) S1 comprises of AP and Karnataka: S2 comprises of Tamil Nadu, Kerala and Pondicherry  
3) W3 comprises of the following regional entities :  
a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak  
f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCCL, n)Vandana Vidyut

**National Load Despatch Centre  
Total Transfer Capability for January 2015**

Issue Date: 30/12/2014

Issue Time: 1300 hrs

Revision No. 2

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
----------	------	-------------------	---------------------------------	--------------------	-------------------------------------	--	--	-------------------------------------	----------

# The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown :

- 1) The TTC value will be revised to normal values after restoration of shutdown.
- 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

**Limiting Constraints**

Corridor	Constraint
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.
WR-NR	High Loading of 400kV Singrauli-Anpara & High loading of 765 kV Agra-Gwalior (1250 MW SPS setting on each circuit of 765 kV Gwalior-Agra) and Loop flows on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda (power flowing from WR to NR on 765kV Gwalior-Agra D/C and from NR to WR on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda).
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli
ER-NR	n-1 contingencies of 400KV Kahalgaon-Banka S/C and 400 kV Farraka-Malda S/C
W3-ER	i. (n-1) Contingency of 400 kV MPL-Maithon S/C ii. (n-1) contingency of 400kV Sterlite-Rourkela S/C
ER-W3	(n-1) contingency of 400kV Raigarh-Jharsuguda-Rourkela
WR-SR & ER-SR	1. (n-1) contingency of one circuit of 400kV Parli(PG)-Sholapur(PG) 2. ER-SR TTC has been declared assuming more than 1100 MW generation at Talcher Stage-2. In case Talcher Stage-2 generation goes below 1100 MW, then the ER-SR TTC would be revised downward as constraints within ER would emerge.
ER-NER	n-1 contingencies of 400KV Kahalgaon-Banka S/C and 400 kV Farraka-Malda S/C
NER-ER	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA ICT at Misa
S1-S2	(n-1) contingency of one circuit of 400 kV Kolar-Hosur D/C line
Import of DD & DNH	(n-1) contingency of 400/220KV 315MVA ICT at VAPI
Import of Punjab	(n-1) contingency of ICT at Dhuri and (n-1) contingency of 220kV Moga(PG)-Moga(PSTCL)
W3 zone Injection	(n-1-1) contingency of 400 kV Raipur-Bhadrawati D/C section and High loading of 400kV Raipur-Wardha (850 MW SPS setting on each circuit of 400kV Raipur-Wardha)

\*Primary constraints

### Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER									
NR	1st January 2015 to 31st January 2015	00-17 23-24	8100	800	7300	7199	101		
		17-23	8100		7300		101		
NER	1st January 2015 to 31st January 2015	00-17 23-24	650	50	600	210	390		
		17-23	720		670		460		
WR									
SR <sup>##</sup>	1st January 2015 to 31st January 2015	00-06 18-24	4750	750	4000	3935	65		
		06-18'	4750		4000	4000	0		

### Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR*	1st January 2015 to 31st January 2015	00-06 18-24	4500	700	3800	1348	2452		
		06-18'	4500		3800	1413	2387		
NER	1st January 2015 to 31st January 2015	00-17 23-24	540	30	510	0	510		
		17-23	590	40	550		550		
WR									
SR *	1st January 2015 to 31st January 2015	00-24	No limit is being Specified.						

\* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

## 1) 215 MW quantum of LTA is not being scheduled as per the CERC order dated 1st Oct 2014 for petition number 92/MP/2014  
## 2) 211 MW quantum of MTOA is not being scheduled as per the communication sent by GM (commercial), Powergrid dated 30th Sep 2014.  
## 3) Considering (1), (2) & likelihood of commencement of above transactions, the margins would be released for short term transactions on day ahead basis.

### Limiting Constraints

NR	Import	n-1 contingencies of 400KV Kahalgaon-Banka S/C and 400 kV Farraka-Malda S/C High loading of 765 kV Agra-Gwalior (1250 MW SPS setting on each circuit of 765 kV Gwalior-Agra) and high loop flows on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda (power flowing from WR to NR on 765kV Gwalior-Agra D/C and from NR to WR on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda).
	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak. (n-1) contingency of 400 kV Saranath-Pusauli
NER	Import	n-1 contingencies of 400KV Kahalgaon-Banka S/C and 400 kV Farraka-Malda S/C
	Export	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa
SR	Import	1. (n-1) contingency of one circuit of 400kV Parli(PG)-Sholapur(PG) 2. ER-SR TTC has been declared assuming more than 1100 MW generation at Talcher Stage-2. In case Talcher Stage-2 generation goes below 1100 MW, then the ER-SR TTC would be revised downward as constraints within ER would emerge.

\*Primary constraints

