National Load Despatch Centre Total Transfer Capability for January 2019

Issue Date: 04th January 2019 Issue Time: 1330 hrs Revision No. 5

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
	1 of Tenners	00-06				195	1805		
NR-WR*	1st January 2019 to 31st	06-18	2500	500	2000	250	1750		
	January 2019	18-24				195	1805		
	1st January	00.24	12250	500	11750	9275	2475		
MAD ND*	2019	00-24	11300**	500	10800**	8325**	2475**		
WR-NR*	2nd January	00.24	12250	500	11750	9383	2367		
	2019 to 31st January 2019	00-24	11300**	500	10800**	8433**	2367**		
	1st January	00-06	2000		1800	193	1607		
NR-ER*	2019 to 31st	06-18	2000	200	1800	303	1497		
	January 2019	18-24	2000		1800	193	1607		
	1st January 2019 to 2nd January 2019	00-24	5250	300	4950	3867	1083		
	3rd January	00-0730	5250	300	4950	3867	1083		
ER-NR*	2019	0730-24	4850	300	4550	3867	683		
	4th January 2019 to 08th January 2019	00-24	4850	300	4550	3867	683		
	9th January 2019 to 31st January 2019	00-24	5250	300	4950	3867	1083		
		l	ı						
W3-ER	1st January 2019 to 31st January 2019	00-24				No limit i	s being specified.		
ER-W3	1st January 2019 to 31st January 2019	00-24				No limit i	s being specified.		
	1st January	00-05	5200		4700		165		
	2019 to 4th	05-22	5200	500	4700	4535	165		
	January 2019	22-24	5200		4700		165		
WR-SR	5.1 1	00-05	5550		5050		515	350	Revised TTC due to: (i) Change in load generation balance
	5th January 2019 to 31st January 2019	05-22	5550	500	5050	4535	515	350	(ii) Commissioning of circuit 3 & 4 of 765 kV Angul-Jharsuguda (iii) Prevailing pattern of load in
		22-24	5550		5050		515	350	downstream of 400/220 kV Maradam ICTs
SR-WR *	1st January 2019 to 31st January 2019	00-24				No limit i	s being Specified.		

National Load Despatch Centre Total Transfer Capability for January 2019

Issue Date: 04th January 2019 Issue Time: 1330 hrs Revision No. 5

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
		00-06				2762	1788		
	1st January 2019 to 4th	06-18	4800	250	4550	2847	1703		
	January 2019		4000	230	4330	- '		1	
	•	18-24				2762	1788		
ER-SR		00-06				2762	1938		Revised TTC due to: (i) Change in load generation balance
	5th January 2019 to 31st January 2019	06-18	4950	250	4700	2847	1853	150	(ii) Commissioning of circuit 3 & 4 of 765 kV Angul-Jharsuguda (iii) Prevailing pattern of load in
		18-24				2762	1938		downstream of 400/220 kV Maradam ICTs
SR-ER *	1st January 2019 to 31st January 2019	00-24				No limit is	s being Specified.		
		00.15	1100		1055		020		<u> </u>
	1st January	00-17 17-23	1100 1160	45	1055 1115	225	830 890		
	2019	23-24	1100	43	1055	223	830		
ER-NER	2nd January	00-17	1350		1305		1080		
	2019 to 31st	17-23	1230	45	1185	225	960		
	January 2019	23-24	1350	73	1305	223	1080		
	1st January	00-17	2000		1955		1955		
NER-ER	2019 to 31st	17-23	2070	45	2025	0	2025	-	
	January 2019	23-24	2000		1955		1955		
	·								
W3 zone Injection	1 2019 to 31st 1 00-24. INo limit is being specified (In case of any constraints appearing in the system W3 zone export would be revised accordingly)								

Note: TTC/ATC of S1-(S2&S3) corridor, Import of S3(Kerala), Import of Punjab and Import of DD & DNH is uploaded on NLDC website under Intra-Regional Section in Monthly ATC.

- $1) \ S1 \ comprises \ of \ Telangana, \ AP \ and \ Karnataka; \ S2 \ comprises \ of \ Tamil \ Nadu \ and \ Puducherry; \ S3 \ comprises \ Kerala$
- 2) W3 comprises of the following regional entities:
- a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak
- $f)\ BALCO,\ g)\ Sterlite\ (\#1,3,4),\ h)\ NSPCL,\ i)\ Korba,\ j)\ Sipat,\ k)\ KSK\ Mahanadi,\ L)DB\ Power,\ m)\ KWPCL,\ n)Vandana\ Vidyut\ o)RKM,\ p)GMR\ Raikheda,\ q)Ind\ Barath\ and\ any\ other\ regional\ entity\ generator\ in\ Chhattisgarh$

The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/Fuel shortage/New units being commissionned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown:

- 1) The TTC value will be revised to normal values after restoration of shutdown.
- 2) The TTC value willl be revised to normal values if the shutdown is not being availed in real time.

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

^{**}Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.

Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER									
		00-06	16350		15550		2383		
	1st January	05.45	15400** 17500	000	14600** 16700	13167	2383** 3553		
	2019	06-17	16550** 15700	800	15750** 14900	12217**	3553** 1733		
		17-24	14750**		13950**		1733**		
		00-06	16350		15550		2275		
	2nd January	1 116 17	15400** 17500	800	14600** 16700	13275 12325**	2275** 3425		
	2019		16550** 15700		15750** 14900		3425** 1625		
		17-24	14750**		13950**		1625**		
NR		00-06	16350 15400**		15550 14600**		2275 2275**		
		06-730	17500		16700	13275	3425		
	3rd January 2019	0730-	16550** 17100	800	15750** 16300	12325**	3425** 3025		
		17	16150**		15350**		3025**		
		17-24	15300 14350**		14500 13550**		1225 1225**		
		00-06	15950		15150		1875		
	04th January 2019 to 08th January 2019	06 17	15000** 17100	965	14200** 16300	13275	1875** 3025		
			16150** 15300	800	15350** 14500	12325**	3025** 1225		
		17-24	14350**		13550**		1225**		

			16350		15550		2275		
		00-06	15400**		14600**		2275**		
NR	09th January 2019 to 31st	06-17	17500	800	16700	13275	3425		
IVIX	January 2019	00-17	16550**	300	15750**	12325**	3425**		
			15700		14900		1625		
		17-24	14750**		13950**		1625**		
		00-17	1100		1055		830		
	1st January	17-23	1160	45	1115	225	890		
	2019	23-24	1100		1055		830		
NER		00-17	1350		1305		1080		
NEK	2nd January 2019 to 31st January 2019	17-23	1230	1230 45 1350	1185	225	960		
		23-24	1350		1305		1080		
WR									_
,,,,,,									
	1st January	00-06	10000		9250	7297	1953		
	2019 to 4th	06-18	10000	750	9250	7382	1868		
	January 2019	18-24	10000		9250	7297	1953		
SR		00-06	10500		9750	7297	2453	500	Revised TTC due to: (i) Change in load generation balance
	5th January 2019 to 31st January 2019	06-18	10500	750	9750	7382	2368	500	(ii) Commissioning of circuit 3 & 4 of 765 kV Angul- Jharsuguda
		18-24	10500		9750	7297	2453	500	(iii) Prevailing pattern of load in downstream of 400/220 kV Maradam ICTs

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Margin in Simultaneous import of NR = A

WR-NR ATC =B

ER-NRATC = C

Margin for WR-NR applicants = A * B/(B+C)

Margin for ER-NR Applicants = A * C/(B+C)

^{**}Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.

^{*} For approving STOA Bilateral transactions, margin available in Simultaneous Import of NR would be apportioned on WR-NR Corridor & ER-NR Corridor in the following ratio:

Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
	1st January	00-06	4500		3800	388	3412		
NR*	2019 to 31st	06-18	4300	700	3800	553	3247		
	January 2019	18-24	4500		3800	388	3412		
	1st January	00-17	2000		1955		1955		
NER	2019 to 31st	17-23	2070	45	2025	0	2025		
	January 2019	23-24	2000		1955		1955		
WR									
VVIX									
SR *	1st January 2019 to 31st January 2019	00-24				No limit is be	eing Specified.		

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Limiting Constraints (Corridor wise)

		Applicable Revisions
Corridor	Constraint	
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak	Rev-0 to 5
	(n-1) Contingnecy of 765kV Aligarh-Jhatikara leads to 2500 MW loading on 765kV Aligarh-Greater Noida.	Rev-0 to 5
MAD NID	Frequent tripping of HVDC Champa - Kurukshetra poles	Rev-0 to 1
WR-NR	RVO operation of HVDC Champa Kurukshetra Poles Reversal of BNC-Agra pole towards BNC & blocking of APD-Agra pole due to lean hydro period in NER	Rev-2 to 5
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli	Rev-0 to 5
ER-NR	1. N-1 contingencies of 400 kv Mejia-Maithon A S/c 2. N-1 contingencies of 400 kv Kahalgaon-Banka S/c 3. N-1 contingencies of 400kV MPL- Maithon S/C	Rev-0 to 3
ER-IVE	1. N-1 contingencies of 400 kv Mejia-Maithon A S/c 2. N-1 contingencies of 400 kv Kahalgaon-Lakhisarai S/C 3. N-1 contingencies of 400kV MPL- Maithon S/C	Rev-4 to 5
WR-SR	n-1 contingency of 2x315 MVA, 400/220 kV ICTs at Mardam will lead to overloading of the second ICT	Rev-0 to 5
and ER-	n-1 contingency of 2x1500 MVA, 765/400 kV ICTs at Vemagiri (PG) will lead to overloading of the second ICT	Rev-1 to 5
SK	Low Voltage at Gazuwaka (East) Bus.	Rev-0 to 5
ER-NER	a. (n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa b. High loading of 220 kV Balipara-Sonabil line(200 MW)	Rev-0 to 5
NER-ER	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other ICT at Misa	Rev-0 to 5
W3 zone Injection		Rev-0 to 5

Limiting Constraints (Simultaneous)

			Applicable Revisions
		1. N-1 contingencies of 400 kv Mejia-Maithon A S/c 2. N-1 contingencies of 400 kv Kahalgaon-Banka S/c 3. N-1 contingencies of 400kV MPL- Maithon S/c	Rev-0 to 3
NR	Import	N-1 contingencies of 400 kv Mejia-Maithon A S/c N-1 contingencies of 400 kv Kahalgaon-Lakhisarai S/C N-1 contingencies of 400kV MPL- Maithon S/c	Rev-4 to 5
NK		(n-1) Contingnecy of 765kV Aligarh-Jhatikara leads to 2500 MW loading on 765kV Aligarh-Greater Noida.	Rev-0 to 5
		Frequent tripping of HVDC Champa - Kurukshetra poles	Rev-0 to 1
		RVO operation of HVDC Champa Kurukshetra Poles Reversal of BNC-Agra pole towards BNC & blocking of APD-Agra pole due to lean hydro period in NER	Rev-2 to 5
	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.	Rev-0 to 5
	Export	(n-1) contingency of 400 kV Saranath-Pusauli	KCV-0 to 3
NER	Import	a. (n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misab. High loading of 220 kV Balipara-Sonabil line(200 MW)	Rev-0 to 5
	Export	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other ICT at Misa	Rev-0 to 5
		n-1 contingency of 2x315 MVA, 400/220 kV ICTs at Mardam will lead to overloading of the second ICT	Rev-0 to 5
SR	Import	n-1 contingency of 2x1500 MVA, 765/400 kV ICTs at Vemagiri (PG) will lead to overloading of the second ICT	Rev-1 to 5
		Low Voltage at Gazuwaka (East) Bus.	Rev-0 to 5

National Load Despatch Centre Total Transfer Capability for January 2019

Revision No	Date of Revision	Period of Revision	Reason for Revision/Comment	Corridor Affected
1	26th Nov 2018	Whole Month	Revised considering (a) recent commissioning of 765 kV Jharsuguda - Dharamjaygarh 3&4, 765 kV Gadarwara - Warora PS D/C, 765 kV Warora PS - Parli D/C, LILO of Kurnool - Thirvualam D/C at Cuddapah, 400 kV Cuddapah-Hindupur D/C, Salem PS - Madhugiri PS S/C, 765 kV Dharamjaigarh - Champa S/C, 765 kV Champa-Raigarh S/C and 765 kV Sipat-Bilaspur ckt-3 and some other 400 kV lines	WR-SR/ER- SR/Import of SR
			Revised STOA margin due to operatiionalization of (a) 50 MW LTA from Green Infra Energy Limited to Delhi (b) 99.9 MW LTA from Green Infra Energy Limited to UP (c) 20 MW LTA from OKWPL to UP discom	WR- NR/Import of NR
2	2 28th Dec 2018 Whole Me		Revised STOA margin due to additional 20 MW LTA to Delhi from Ostro Kutch Wind Power Ltd (OKWPL)	WR- NR/Import of NR
			Revised TTC due to change in pattern of inter-regional flow towards NR	Import of NR
			Revised STOA margin due to operationalization of 108 MW MTOA from SKS Power Gen Ltd to Noida Power Company	WR- NR/Import of NR
3	31st Dec 2018	2nd Jan to 31st Jan 2019	Revised TTC due to: (i) Upgradation of 132 kV Silchar - Imphal D/C to 400 kV Level (ii) Commissioning of 132 kV Silchar- Melriat D/C (iii) Changes in load -generation balance in NER	ER- NER/Import of NER
4	2nd Jan 2019	3nd Jan to 08th Jan 2019	Revised due to shutdown of 400kV Kahalgaon-Banka D/C	ER- NR/Import of NR
5	4th Jan 2019	5th Jan to 31st Jan 2019	Revised TTC due to: (i) Change in load generation balance (ii) Commissioning of circuit 3 & 4 of 765 kV Angul- Jharsuguda (iii) Prevailing pattern of load in downstream of 400/220 kV Maradam ICTs	ER-SR/WR- SR/Import of SR

ASSUM	MPTIONS IN BASECASE				
				Month : January'19	
S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
I	NORTHERN REGION				
1	Punjab	7403	4583	4272	4196
2	Haryana	7726	5851	2071	2071
3	Rajasthan	11094	11137	6550	6549
4	Delhi	4835	2698	855	855
5	Uttar Pradesh	13811	13644	6532	6434
6	Uttarakhand	2014	1411	1013	663
7	Himachal Pradesh	1421	503	204	54
8	Jammu & Kashmir	1892	1450	551	494
9	Chandigarh	277	89	0	0
10	ISGS/IPPs	31	30	16917	8993
	Total NR	50505	41396	38965	30309
Ш	EASTERN REGION				
1	Bihar	3528	2449	247	177
2	Jharkhand	996	825	360	223
3	Damodar Valley Corporation	3010	2801	5213	4002
4	Orissa	3791	3036	2344	2044
5	West Bengal	7217	5307	5189	4516
6	Sikkim	77	83	0	0
7	Bhutan	207	211	643	534
8	ISGS/IPPs	1120	1066	12334	9261
	Total ER	19946	15777	26329	20756
Ш	WESTERN REGION				
1	Maharashtra	18055	12575	13762	9716
2	Gujarat	13539	11258	8981	7570
3	Madhya Pradesh	11708	7248	5031	4324
4	Chattisgarh	3956	2545	2893	2641
5	Daman and Diu	328	300	0	0
6	Dadra and Nagar Haveli	815	728	0	0
7	Goa-WR	556	300	0	0
8	ISGS/IPPs	4385	3459	38121	28319
	Total WR	53343	38412	68789	52570

S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
IV	SOUTHERN REGION				
1	Andhra Pradesh	7623	6640	6103	4712
2	Telangana	9109	6830	4737	3624
3	Karnataka	10386	5951	7633	4885
4	Tamil Nadu	14707	13791	6879	5234
5	Kerala	3727	2299	1462	374
6	Pondy	338	360	0	0
7	Goa-SR	76	81	0	0
8	ISGS/IPPs	0	0	14302	12230
	Total SR	45967	35953	41116	31060
V	NORTH-EASTERN REGION				
1	Arunachal Pradesh	126	71	0	0
2	Assam	1182	1001	185	142
3	Manipur	155	93	0	0
4	Meghalaya	325	359	115	169
5	Mizoram	100	67	8	8
6	Nagaland	113	76	12	12
7	Tripura	325	196	72	74
8	ISGS/IPPs	159	156	1888	1888
	Total NER	2486	2020	2280	2293
	Total All India	172247	133557	177478	136988