## National Load Despatch Centre Total Transfer Capability for January 2022

Issue Date: 28th October, 2021 Issue Time: 1700 hrs Revision No. 1

January 2022   18-24										
NE-WE 10 Lensing March 1990   100   100   11800   11810   11800   1181	Corridor	Date	Time Period (hrs)	Transfer Capability		Transfer Capability	Access (LTA)/ Medium Term Open Access	Available for Short Term Open Access	in TTC w.r.t. Last	Comments
NEW   Part   P			00-06				378	1622		
Ne.Fig.   1st January   1st	NR-WR*	2022 to 31st	06-18	2500	500	2000	956	1044		
MR.NE   14 January   1500   1000   18500   1000   18500   11801   18500   1000   18500   11801   18500   1000   18500   11801   1000		·	18-24				378	1622		
WEAR   18   January   2022   18   2000   18   1850    1000   17550    1051    1850    1180							11412			
Manuary 2022   13-14   1950   1850*   1000   17550*   10851**   10462**   7088   1070   17550*   10811**   10462**   10811**			00-06		1000		10462**	7088		
NR_ER   1st January   1st Ja	WR-NR*	2022 to 31st	06-18		1000			6699		a) Operationalization of LTA OF 39 MW from PGLR_SREPL to UPPCL
Ne. Fig.   2022 o. 3 1st   2		January 2022	18-24	19500	1000	18500	11412	7088		o) Operationalization of ETA OF 11 MW Holin Futurolist SETEMBRIE OF OFFICE
Ne. Fig.   2022 o. 3 1st   2										
No.   Part   P										Revised STOA margin due to operationalization of new LTA of 33 MW from AP41PL BHDL to
The color of the	NR-ER*				200					
ER-NR   2022 to 3 ist January 2022   3		January 2022	18-24	2000		1800	93	1707		
No limit is being specified.   No limit is being specified.   No limit is being specified.	ER-NR*	2022 to 31st	00-24	5900	400	5500	4322	1178		
No limit is being specified.   No limit is being specified.   No limit is being specified.	1	1 at I amount								
Security   1st January 2022   2021 of 31st   January 2022   2022 to 31st   January 2022   2023 to 31st   January 2022   2034 to 3355   2035   20	W3-ER	2022 to 31st	00-24						No limit is	s being specified.
VR-SR   2022 to 31st   January 2022   22-24   10350   650   9700   3878   5822	ER-W3	2022 to 31st	00-24						No limit is	s being specified.
VR-SR   2022 to 31st   January 2022   22-24   10350   650   9700   3878   5822		Let Ianuary	00.05	10350		9700		5822		
January 2022   22-24   10350   9700   5822	WR-SR				650		3878			
SR-WR * 2022 to 31st January 2022    Ist January 2022   1st January 2022   2st January 2st Januar										
ER-SR 2022 to 31st January 2022    1st January 2022	SR-WR*	2022 to 31st	00-24	4600	400	4200	913	3287		a) Operationalization of LTA OF 5 MW from BETAM to UP (NR)
ER-SR 2022 to 31st January 2022    1st January 2022			00-06				2675	2775		
SR-ER   SR-E	ED CD <sup>A</sup>			5800	350	5450				
SR-ER * 1st January 2022    SR-ER * 2022 to 31st January 2022   1st Ja	ER-SR			3800	330	3430				
Ser-Ner   Ser-Ner   Test January 2022   Test	SR.FR*	1st January					2675	2775	No limit is	sheing Shecified
Ist January 2022       Ist January 2022     18: 22     605     455     250       690     455     235       695     455     240       18: 22     605     455     240       18: 22     605     22: 24     750     705     455     250       705     455     250       705     455     250       705     455     250       705     455     250       705     455     250       705     455     250       705     455     250       705     455     250       705     455     250       705     455     250       705     455     250       705     455     250       705     455     250       81     3289       3370     81     3289       3375     81     3274       3315     81     3334       3275     81     3194	,,,, ,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,		2.							Ü.
Ist January 2022       Ist January 2022     18: 22     605     455     250       690     455     235       695     455     240       18: 22     605     455     240       18: 22     605     22: 24     750     705     455     250       705     455     250       705     455     250       705     455     250       705     455     250       705     455     250       705     455     250       705     455     250       705     455     250       705     455     250       705     455     250       705     455     250       705     455     250       705     455     250       81     3289       3370     81     3289       3375     81     3274       3315     81     3334       3275     81     3194	1		00.02	750		705	155	250	1	
ER-NER*   1st January 2022   2022 to 31st January 2022   1s-22   45   45   690   455   235   695   455   240   665   455   105   660   455   105   450										
NER-ER*  January 2022  12-18 740 695 455 240 560 455 105 22-24 750 705 455 250   00-02 3415 02-07 3415 3370 81 3289 3370 81 3289 3370 81 3289 3370 81 3289 3370 81 3289 3370 81 3289 3370 81 3389 3375 81 3274 3375 81 3274 3375 81 3274 3375 81 3274 3375 81 3274 3375 81 3274 3375 81 3274	FD_NFD*		07-12	735	15	690	455	235		
NER-ER*   18-22   605   560   455   105	EX-MEK.				43					
NER-ER*   00-02   3415   3370   81   3289   3370   81   3289   3270   81   3289   3370   81   3289   3274   3355   81   3274   3355   81   3234   3355   81   3234   3355   81   3234   3355   3355   81   3324   3355   3355   81   3324   3355		,								
NER-ER* 1st January 2022 to 31st January 2022										
NER-ER*   1st January 2022 to 31st January 2022   18-22   3320   45   3355   81   3274   3275   81   3294   3295   3315   3194   3275   81   3194   3194   3194   3275   3194   3275   3194   3275   3194   3275   3194   3275   3194   3275   3194   3275   3194   3275   3										
NER-ER* 2022 to 31st January 2022 18-22 3320 45 3315 81 3234 3275 81 3194					4.5					
Fanuary 2022 18-22 3320 3275 81 3194	NER-ER*		12-18	3360	45	3315	81	3234		
22-24 3415 3370 81 3289		January 2022	18-22							
			22-24	3415		3370	81	3289		

## **National Load Despatch Centre Total Transfer Capability for January 2022**

Issue Date: 28th October, 2021 Issue Time: 1700 hrs Revision No. 1

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
W3 zone Injection	1st January 2022 to 31st January 2022	00-24	No limit is be	limit is being specified (In case of any constraints appearing in the system, W3 zone export would be revised accordingly)						

Note: TTC/ATC of S1-(S2&S3) corridor, Import of S3(Kerala), Import of Punjab and Import of DD & DNH is uploaded on NLDC website under Intra-Regional Section in Monthly ATC.

Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

\*\*Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity

- 1) S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala
- 2) W3 comprises of the following regional entities:
- a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak
- f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCL, n) Vandana Vidyut o)RKM, p)GMR Raikheda, q)Ind Barath and any other regional entity generator in Chhattisgarh
- # The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissionned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown:

- The TTC value will be revised to normal values after restoration of shutdown.
   The TTC value will be revised to normal values if the shutdown is not being availed in real time.

Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section

^Though 2X315 MVA, 400/220 kV ICTs at Maradam are N-1 non-compliant, the TTC of WR-SR and ER-SR corridor has not been restricted due to the same considering that this aspect will be managed by AP SLDC through appropiate neasures like SPS implemetation.

^In case of drawl of Karnataka beyond 3800 MW, the voltages in Bengaluru area are observed to be critically low. This issue may be taken care of by Karnataka SLDC by taking appropiate measures.

SR-WR TTC/ATC figures have been calculated considering 01 unit (800 MW) at Kudgi TPS in service. The figures are subject to change with change in generation at Kudgi TPS.

WR-NR/Import of NR TTC has been calculated considering generation at Pariccha TPS as 350 MW. TTC figures are subject to change with significant change in generation at Pariccha TPS.

Simultane	ous Import Capal	bility							
Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
		00-06	25400 24450**		24000 23050**	15734 14784**	8266		
		06-09	25400 24450**		24000 23050**	16123 15173**	7877		a) operationalization of LTA OF 39 MW
NR	1st January 2022 to 31st January 2022	09-17	25400 24450**	1400	24000 23050**	16123 15173**	7877		from PGLR_SREPL to UPPCL b) operationalization of LTA OF 11 MW from Tuticorin-BETAMWIND to UPPCI
		17-18	25400 24450**	]	24000 23050**	16123 15173**	7877		c) Discontinuation of 50 MW MTOA Arunachal Pradesh to NPCL(UP)
		18-24	25400 24450**		24000	15734 14784**	8266		
		00-02	750		705	455	250		
	1st January 2022	02-07	750		705	455	250		
NER*	to 31st January	07-12	735	45	690	455	235		
. 11211	2022	12-18	740		695	455	240		
		18-22 22-24	605 750		560 705	455 455	105 250		
		22-24	730		703	433	230		
$\mathbf{WR}^*$									

6553

6638

6553

8597

8512

8597

15150

15150

15150

Margin in Simultaneous import of NR = A

1st January 2022

to 31st January 2022

00-06

06-18

18-24

16150

16150

16150

1000

WR-NR ATC =B

 $SR^{*\#}$ 

ER-NR ATC = C

Margin for WR-NR applicants = A \* B/(B+C)Margin for ER-NR Applicants = A \* C/(B+C)

Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section

#Though 2X315 MVA, 400/220 kV ICTs at Maradam are N-1 non-compliant, the TTC of SR Import has not been restricted due to the same considering that this aspect will be managed by AP SLDC through appropriate measures like SPS implementation.

In case of drawl of Karnataka beyond 3800 MW, the voltages in Bengaluru area are observed to be critically low. This issue may be taken care of by Karnataka by taking appropiate measures.

WR-NR/Import of NR TTC has been calculated considering generation at Pariccha TPS as 350 MW. TTC figures are subject to change with significant change in generation at Pariccha TPS.

<sup>\*</sup> Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

<sup>\*\*</sup>Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.

<sup>\*</sup> For approving STOA Bilateral transactions, margin available in Simultaneous Import of NR would be apportioned on WR-NR Corridor & ER-NR Corridor in the following ratio:

Simultane	Simultaneous Export Capability												
Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments				
		00-06				471	3329						
NR*	1st January 2022 to 31st January 2022	06-18	4500	700	3800	2447	1353		Revised STOA margin due to operationalization of new LTA of 33 MW from AP41PL_BHDL to ODISHA				
		18-24				471	3329						
		00-02	3415		3370	81	3289						
		02-07	3415	45	45	45	3370	81	3289				
NER*	1st January 2022 to 31st January	07-12	3400				3355	81	3274				
NEK.	2022	12-18	3360				43	43	3315	81	3234		
		18-22	3320									3275	81
		22-24	3415		3370	81	3289						
WR*													
SR*^	1st January 2022 to 31st January 2022	00-24	3700	400	3300	1731	1569		Revised STOA margin due to a) Operationalization of LTA of 24 MW from Spring energy to UP (NR) b) Operationalization of LTA of 5 MW from BETAM to UP (NR) c) Operationalization of LTA of 5 MW from BETAM to Odisha (ER) d) Operationalization of LTA of 21 MW from Hiriyur_Ostrokannada to Bihar (ER)				

<sup>\*</sup> Fifty Percent (50 % ) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section

SR Export TTC/ATC figures have been calculated considering 01 unit (800 MW) at Kudgi TPS in service. The figures are subject to change with change in generation at Kudgi TPS.

Limiting	Constraints (Corridor wise)	
		Applicable Revisions
Corridor	Constraint	
WR-NR	N-1 contingency of one ckt of 765 kV Vindhyachal-Varanasi will overload the other circuit	Rev- 0 to 1
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli	Rev- 0 to 1
ER-NR	Inter-regional flow pattern towards NR	Rev- 0 to 1
	N-1 of one ICT of 765/400 kV, 1500 MVA ICT at Nizamabad will overload the other ICT Low Voltage at Gazuwaka (East) Bus.	Rev- 0 to 1
CD W/D	a) N-1 contingency of one ckt of 400 kV Kolhapur-PG - Kolhapur-MS D/C will overload of the other ckt b) N-1 contingency of 500 MVA ICT at 400 kV Kolhapur-MS will overload the other 2x315 MVA ICTs	Rev- 0 to 1
ER-NER	<ul> <li>a) N-1 contingency of 400 kV Bongaigaon - Azara line</li> <li>b) High Loading of 220 kV Salakati - BTPS D/C</li> </ul>	Rev- 0 to 1
NER-ER	<ul> <li>a) N-1 contingency of 220 kV Salakati - Alipurduar I or II</li> <li>b) High Loading of 220 kV Salakati - Alipurduar II or I</li> </ul>	Rev- 0 to 1
W3 zone Injection		Rev- 0 to 1

## **Limiting Constraints (Simultaneous)**

			Applicable Revisions			
	Import	Inter-regional flow pattern towards NR	Rev- 0 to 1			
NR	Import	N-1 contingency of one ckt of 765 kV Vindhyachal-Varanasi will overload the other circuit	Rev- 0 to 1			
111	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.	Rev- 0 to 1			
	Export	(n-1) contingency of 400 kV Saranath-Pusauli	Kev- 0 to 1			
		a) N-1 contingency of 400 kV Bongaigaon - Killing line (0000 hrs to 2400 hrs)				
	Import	b) High Loading of 220 kV Balipara-Sonabil (0000 hrs to 0700 hrs)	Rev- 0 to 1			
NER		c) High Loading of 220 kV Salakati - BTPS D/C (0700 hrs to 1200 hrs)				
	<b>.</b>	a) N-1 contingency of 220 kV Salakati - Alipurduar I or II	D 0 1			
	Export	b) High Loading of 220 kV Salakati - Alipurduar II or I	Rev- 0 to 1			
		N-1 of one ICT of 765/400 kV, 1500 MVA ICT at Nizamabad will overload the other ICT	Rev- 0 to 1			
		Low Voltage at Gazuwaka (East) Bus	Kev- 0 to 1			
	Evmont	N-1 contingency of one ckt of 400 kV Kolhapur-PG - Kolhapur-MS D/C will overload of the other ckt	Rev- 0 to 1			
	Export	N-1 contingency of 500 MVA ICT at 400 kV Kolhapur-MS will overload the other 2x315 MVA ICTs	Kev- 0 to 1			

## National Load Despatch Centre Total Transfer Capability for January 2022

Revision No	Date of Revision	Period of Revision	Reason for Revision/Comment	Corridor Affected
			Revised STOA margin due to a) Operationalization of LTA OF 39 MW from PGLR_SREPL to UPPCL b) Operationalization of LTA OF 11 MW from Tuticorin-BETAMWIND to UPPCL c) Discontinuation of 50 MW MTOA Arunachal Pradesh to NPCL(UP)	WR-NR/ER-NR/NR Import
1	28th October 2021	Whole Month	Revised STOA margin due to operationalization of new LTA of 33 MW from AP41PL_BHDL to ODISHA	NR-ER/NR Export
			Revised STOA margin due to a) Operationalization of LTA of 24 MW from Spring energy to UP (NR) b) Operationalization of LTA of 5 MW from BETAM to UP (NR) c) Operationalization of LTA of 5 MW from BETAM to Odisha (ER) d) Operationalization of LTA of 21 MW from Hiriyur_Ostrokannada to Bihar (ER)	SR-WR/SR-ER/SR Export

ASSUN	IPTIONS IN BASECASE						
				Month : January 2022			
S.No.	Name of State/Area		Load	Generation			
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)		
I	NORTHERN REGION						
1	Punjab	10744	10867	3971	3971		
2	Haryana	9492	9088	2701	2701		
3	Rajasthan	10485	9635	8259	8259		
4	Delhi	5321	5152	796	795		
5	Uttar Pradesh	20631	20099	10623	10689		
6	Uttarakhand	2124	1886	928	939		
7	Himachal Pradesh	1354	1114	783	769		
8	Jammu & Kashmir	2363	1962	884	883		
9	Chandigarh	313	249	0	0		
10	ISGS/IPPs	48	48	21958	20013		
	Total NR	62875	60100	50903	49019		
Ш	EASTERN REGION						
1	Bihar	6537	5617	356	349		
2	Jharkhand	1958	1503	511	501		
3	Damodar Valley Corporation	2985	2723	5856	4190		
4	Orissa	4513	4310	3998	3798		
5	West Bengal	9704	8401	7033	6210		
6	Sikkim	119	116	0	0		
7	Bhutan	181	181	2325	2325		
8	ISGS/IPPs	810	810	15771	11533		
	Total ER	26808	23662	35850	28906		
III	WESTERN REGION						
1	Maharashtra	17405	16509	11624	10789		
2	Gujarat	13918	11320	8601	7246		
3	Madhya Pradesh	9254	8534	3596	3845		
4	Chattisgarh	4309	3965	2531	2835		
5	Daman and Diu	276	236	0	0		
6	Dadra and Nagar Haveli	744	870	0	0		
7	Goa-WR	534	420	0	0		
8	ISGS/IPPs	1784	3263	36712	32338		
	Total WR	48224	45117	63064	57053		

IV	SOUTHERN REGION				
1	Andhra Pradesh	8024	7220	6268	5204
2	Telangana	9100	8117	5196	5078
3	Karnataka	8396	6654	6023	4850
4	Tamil Nadu	15210	13068	7256	6376
5	Kerala	3778	2349	1614	961
6	Pondy	264	264	0	0
7	Goa-SR	82	82	0	0
8	ISGS/IPPs	37	37	14805	14794
	Total SR	44891	37791	41162	37263
V	NORTH-EASTERN REGION				
1	Arunachal Pradesh	140	95	118	118
2	Assam	1849	1588	615	574
3	Manipur	207	86	105	103
4	Meghalaya	315	255	302	229
5	Mizoram	150	55	60	60
6	Nagaland	173	155	96	93
7	Tripura	435	260	300	300
8	ISGS/IPPs	0	0	2371	2370
	Total NER	3269	2494	3967	3847
	Total All India	186067	169164	194946	176088