## **National Load Despatch Centre Total Transfer Capability for July 2016**

Issue Date: 28/3/2016 Issue Time: 1730 hrs Revision No. 0

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR-WR *	1st July 2016 to 31st July 2016	00-24	2500	500	2000	55	1945		
WR-NR*	1st July 2016 to 31st July 2016	00-24	7400	500	6900	6103	797		
		00-06	2000		1800	293	1507	I	
NR-ER*	1st July 2016 to	06-18'	2000	200	1800	358	1442		
NK-EK	31st July 2016	18-24	2000	200	1800	293	1507		
	1 at July 2016 to	16-24	2000		1800	293	1307		
ER-NR*	1st July 2016 to 31st July 2016	00-24	4400	300	4100	2431	1669		
	1 . 7 1 2016 .	<u> </u>				NT 11 14 1	1 : :c: 1		
W3-ER <sup>\$</sup>	1st July 2016 to	00-24					s being specified.	A A ID	
	31st July 2016					No Re-routing is	allowed via W3-El	K-NK.	
ER-W3	1st July 2016 to	00-24				No limit i	s being specified.		
	31st July 2016		- · · · · · · · · · · · · · · · · · · ·						
WR-SR	1st July 2016 to 31st July 2016	00-24	4000	750	3250	3250	0		
SR-WR *	1st July 2016 to	00-24				No limit i	s being Specified.		
	31st July 2016								
	1 . I 1 2016 .	00-06				2505			
ER-SR	1st July 2016 to	18-24	2650	0	2650	2585	65		
	31st July 2016	06-18'				2650	0		
CD ED *	1st July 2016 to	00-24				NI - 11 14 1	- li Cii		
SR-ER *	31st July 2016	00-24				No limit i	s being Specified.		
	1st July 2016 to	00-17	1250		1205		995		
ER-NER	31st July 2016	23-24		45		210			
	,	17-23	1100		1055		845		
	1st July 2016 to	00-17	1200		1155		1155		
NER-ER	31st July 2016	23-24		45		0			
	,	17-23	1290		1245		1245		
W3 zone	1st July 2016 to		No limit is	haing specifi	ad (in case of a	kawad inter region	nal flows or any co	etrointe	
	•	00-24		0 1	*	_	•		
Injection	31st July 2016		арре	earing in the s	ystem, w 5 Zon	e export would be	revised accordingly	y)	
Note: TTC/AT	CC of S1-S2 corrid	or, Impor	t of Punjab a	nd Import of	DD & DNH	is uploaded on NI	LDC website unde	r Intra-Re	gional Section in Monthly ATC.

\* Fifty Percent (50 % ) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral &

First Come First Serve).

#### National Load Despatch Centre Total Transfer Capability for July 2016

Issue Date: 28/3/2016 Issue Time: 1730 hrs Revision No. 0

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
----------	------	-------------------------	--	-----------------------	--	--	--	---	----------

- \$ As per Simulations, predominant direction of flow is on West to North Corridor. Hence, in case injection point is in Western Region (W1,W2,W3), STOA/PX transactions from West to North on West-East-North corridor shall not be allowed as such transaction increases congestion in the West to North Corridor.
- 1) S1 comprises of Telangana, AP and Karnataka: S2 comprises of Tamil Nadu, Kerala and Puducherry
- 2) W3 comprises of the following regional entities:
- a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak
- f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCL, n) Vandana Vidyut
- # The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/Fuel shortage/New units being commissionned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown:

- 1) The TTC value will be revised to normal values after restoration of shutdown.
- 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

#### **Limiting Constraints**

Corridor	Constraint
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak
WR-NR	1. (n-1) Contingnecy of 765kV Gwalior-Agra one ckt leads to 2750 MW loading on second circuit.  2. High Loading of 400kV Singrauli-Anpara S/C.
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli
ER-NR	n-1 contingency of one cicuit of 400 kV Biharshariff- Lakhisarai leads to high loading on the other cicuit
WR-SR & ER-SR	(n-1) contingency of one circuit of 765 kV Raichur - Sholapur will lead to 2500 MW loading on the other circuit
ER-NER	Low Voltage at Gazuwaka (East) Bus.  (n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA ICT at Misa. n-1 contingency of 400/132 kV, 2 x 200 MVA ICTs at Silchar
NER-ER	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA ICT at Misa
W3 zone Injection	

#### **Simultaneous Import Capability**

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER									
NR <sup>*</sup>	1st July 2016 to 31st July 2016	00-05 05-08' 08-19'	9900 9900 9900	800	9100 9100 9100	8534	566 566 566		
NER	1st July 2016 to 31st July 2016	19-24 00-17 23-24 17-23	9900 1250 1100	45	9100 1205 1055	210	566 995 845		
WR									
SR	1st July 2016 to 31st July 2016	00-06 06-18' 18-24	6650 6650 6650	750	5900 5900 5900	5835 5900 5835	65 0 65		

<sup>\*</sup> Fifty Percent (50 % ) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Margin in Simultaneous import of NR = A

WR-NR ATC =B

ER-NRATC = C

Margin for WR-NR applicants = A \* B/(B+C)Margin for ER-NR Applicants = A \* C/(B+C)

<sup>\*</sup> For approving STOA Bilateral transactions, margin available in Simultaneous Import of NR would be apportioned on WR-NR Corridor & ER-NR Corridor in the following ratio:

# **Simultaneous Export Capability**

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR*	1st July 2016 to 31st July 2016	00-06 06-18' 18-24	4500 4500	700	3800 3800 3800	348 413 348	3452 3387 3452		
NER	1st July 2016 to 31st July 2016	00-17 23-24 17-23	1200 1290	45	1155 1245	0	1155		
WR									
SR *	1st July 2016 to 31st July 2016	00-24				No limit is be	eing Specified.		

<sup>\*</sup> Fifty Percent (50 % ) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

### **Limiting Constraints**

	g Constraints	
		(n-1) contingency of one circuit of 400 kV Biharshariff- Lakhisarai leads to high loading on the other circuit
	Import	1. (n-1) Contingnecy of 765kV Gwalior-Agra one ckt leads to 2750 MW loading on second circuit.
NR		2.High Loading of 400kV Singrauli-Anpara S/C.
	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.
	Export	(n-1) contingency of 400 kV Saranath-Pusauli
	T	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA
NER	Import	ICT at Misa. n-1 cntingency of 400/132 kV, 2 x 200 MVA ICTs at Silchar
NEK	<b>.</b>	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA
	Export	ICT at Misa.
CD	T	(n-1) contingency of one circuit of 765 kV Raichur - Sholapur will lead to 2500 MW loading on the other circuit
SR	Import	Low Voltage at Gazuwaka (East) Bus.

# National Load Despatch Centre Total Transfer Capability for July 2016

Revision	Date of	Period of	Reason for Revision	Corridor
No	Revision	Revision		Affected

ASSU	MPTIONS IN BASECASE				
				Month : July '16	
S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
ı	NORTHERN REGION				
1	Punjab	9417	9264	4060	4183
2	Haryana	7660	7356	2137	2137
3	Rajasthan	8189	8166	4373	4373
4	Delhi	5287	5321	920	920
5	Uttar Pradesh	12769	13458	5813	5944
6	Uttarakhand	1612	1357	754	981
7	Himachal Pradesh	1181	991	1070	1035
8	Jammu & Kashmir	2271	1484	732	727
9	Chandigarh	302	242	0	0
10	ISGS/IPPs	0	0	22339	21201
	Total NR	48688	47639	42198	41501
Ш	EASTERN REGION				
1	Bihar	2941	2113	200	131
2	Jharkhand	1089	865	400	380
3	Damodar Valley Corporation	2723	2359	3400	3101
4	Orissa	4005	2948	3109	2039
5	West Bengal	7030	5995	4768	3422
6	Sikkim	79	50	0	0
7	Bhutan	215	215	1514	1195
8	ISGS/IPPs	620	920	9770	9508
	Total ER	18701	15465	23161	19776
Ш	WESTERN REGION				
1	Maharashtra	19604	13832	14300	9615
2	Gujarat	14023	9261	10629	6492
3	Madhya Pradesh	7485	5137	3789	2723
4	Chattisgarh	3467	2632	2116	1346
5	Daman and Diu	307	253	0	0
6	Dadra and Nagar Haveli	741	643	0	0
7	Goa-WR	406	236	0	0
8	ISGS/IPPs	1078	1075	27818	23042
	Total WR	47111	33069	58651	43218

IV	SOUTHERN REGION				
1	Andhra Pradesh	6506	5552	5427	5181
2	Telangana	7319	6912	2324	1982
3	Karnataka	8101	6015	6437	5128
4	Tamil Nadu	15406	13893	8405	5905
5	Kerala	3782	2485	1596	659
6	Pondy	391	335	0	0
7	Goa-SR	89	89	0	0
8	ISGS/IPPs	20	20	13317	11829
	Total SR	41614	35301	37506	30684
V	NORTH-EASTERN REGION				
1	Arunachal Pradesh	122	95	0	0
2	Assam	1052	964	261	240
3	Manipur	145	81	0	0
4	Meghalaya	250	175	208	189
5	Mizoram	86	63	8	0
6	Nagaland	111	104	22	16
7	Tripura	250	152	89	88
8	ISGS/IPPs	100	60	1529	1418
	Total NER	2115	1694	2117	1952
	Total All India	158474	133414	165162	138341