

**National Load Despatch Centre  
Total Transfer Capability for July 2017**

Issue Date: 06th July 2017

Issue Time: 1230 hrs

Revision No. 8

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR-WR*	1st July 2017 to 31st July 2017	00-06	2500	500	2000	55	1945		
		06-18				65	1935		
		18-24				55	1945		
WR-NR*	1st July 2017 to 4th July 2017	00-24	9050	500	8550	7951	599		Revised due to shutdown of HVDC Rihand Dadri Pole-1
	5th July 2017 and 6th July 2017	00-530	9050	500	8550	7951	599		
		530-14	7750	500	7250	7951	0		
		14-24	9050	500	8550	7951	599		
	7th July 2017	00-0730'	9050	500	8550	7951	599		
		0730-24	8550	500	8050	7951	99	-500	
8th July 2017 to 14th July 2017	00-24	8550	500	8050	7951	99	-500		
15th July 2017 to 31st July 2017	00-24	9050	500	8550	7951	599			
NR-ER*	1st July 2017 to 31st July 2017	00-06	2000	200	1800	193	1607		
		06-18'	2000		1800	303	1497		
		18-24	2000		1800	193	1607		
ER-NR*	1st July 2017 to 31st July 2017	00-24	4500	300	4200	2983	1217		
W3-ER	1st July 2017 to 31st July 2017	00-24	No limit is being specified.						
ER-W3	1st July 2017 to 31st July 2017	00-24	No limit is being specified.						
WR-SR	1st July 2017	00-05	4350	500	3850	3888	0		
		05-22	4350		3850		0		
		22-24	4350		3850		0		
	2nd July 2017	00-05	4350	500	3850	3888	0		
		05-0730	4350		3850		0		
		0730-22	2950		2450		0		
	3rd July 2017 to 31st July 2017	22-24	2950	500	2450	3888	0		
		00-05	4350		3850		0		
		05-22	4350		3850		0		
22-24	4350	3850	0						
SR-WR *	1st July 2017 to 31st July 2017	00-24	No limit is being Specified.						
ER-SR	1st July 2017 to 31st July 2017	00-06	3450	250	3200	3061	139		
		06-18'				3146	54		
		18-24				3061	139		
SR-ER *	1st July 2017 to 31st July 2017	00-24	No limit is being Specified.						
ER-NER	1st July 2017 to 4th July 2017	00-17	1035	45	990	225	765		
		17-23	1010		965		740		
		23-24	1035		990		765		
	5th July 2017	00-08	1035	45	990	225	765		
		08-16	790		745		520		
		16-17	1035		990		765		
		17-23	1010		965		740		
		23-24	1035		990		765		
	6th July 2017 to 31st July 2017	00-17	1035	45	990	225	765		
		17-23	1010		965		740		
		23-24	1035		990		765		

**National Load Despatch Centre  
Total Transfer Capability for July 2017**

Issue Date: 06th July 2017

Issue Time: 1230 hrs

Revision No. 8

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NER-ER	1st July 2017 to 4th July 2017	00-17	1180	45	1135	0	1135		
		17-23	1050		1005		1005		
		23-24	1180		1135		1135		
	5th July 2017	00-08	1180	45	1135	0	1135		
		08-16	930		885		885		
		16-17	1180		1135		1135		
		17-23	1050		1005		1005		
		23-24	1180		1135		1135		
	6th July 2017 to 31st July 2017	00-17	1180	45	1135	0	1135		
		17-23	1050		1005		1005		
		23-24	1180		1135		1135		

<b>W3 zone Injection</b>	1st July 2017 to 31st July 2017	00-24	No limit is being specified (In case of any constraints appearing in the system, W3 zone export would be revised accordingly)						
<b>Note: TTC/ATC of S1-(S2&amp;S3) corridor, Import of S3(Kerala), Import of Punjab and Import of DD &amp; DNH is uploaded on NLDC website under Intra-Regional Section in Monthly ATC.</b>									

\* Fifty Percent (50 % ) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

1) S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala

2) W3 comprises of the following regional entities :

- a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) Lanco Amarkantak  
f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, l) DB Power, m) KWPC, n) Vandana Vidyut o) RKM, p) GMR Raikheda, q) Ind Barath and any other regional entity generator in Chhattisgarh

# The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown :

- The TTC value will be revised to normal values after restoration of shutdown.
- The TTC value will be revised to normal values if the shutdown is not being availed in real time.

**Simultaneous Import Capability**

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
<b>ER</b>									
<b>NR</b>	1st July 2017 to 4th July 2017	00-05	12900	800	12100	10934	1166		Revised due to shutdown of HVDC Rihand Dadri Pole-1
		05-08	12900		12100		1166		
		08-18	12900		12100		1166		
		18-23	11600		10800		0		
		23-24	12900		12100		1166		
	5th July 2017 and 6th July 2017	00-0530	12900	800	12100	10934	1166		
		0530-08	11100		10300		0		
		08-14	11100		10300		0		
		14-18	12900		12100		1166		
		18-23	11600		10800		0		
	7th July 2017	00-05	12900	800	12100	10934	1166		
		05-0730	12900		12100		1166		
		0730-18	12200		11400		466	-700	
		18-23	11000		10200		0	-600	
		23-24	12200		11400		466	-700	
	8th July 2017 to 14th July 2017	00-05	12200	800	11400	10934	466	-700	
		05-08	12200		11400		466	-700	
		08-18	12200		11400		466	-700	
		18-23	11000		10200		0	-600	
		23-24	12200		11400		466	-700	
15th July 2017 to 31st July 2017	00-05	12900	800	12100	10934	1166			
	05-08	12900		12100		1166			
	08-18	12900		12100		1166			
	18-23	11600		10800		0			
	23-24	12900		12100		1166			
<b>NER</b>	1st July 2017 to 4th July 2017	00-17	1035	45	990	225	765		
		17-23	1010		965		740		
		23-24	1035		990		765		
	5th July 2017	00-08	1035	45	990	225	765		
		08-16	790		745		520		
		16-17	1035		990		765		
		17-23	1010		965		740		
		23-24	1035		990		765		
	6th July 2017 to 31st July 2017	00-17	1035	45	990	225	765		
		17-23	1010		965		740		
		23-24	1035		990		765		
	<b>WR</b>								
<b>SR</b>	1st July 2017	00-05	7800	750	7050	6949	101		
		05-06	7800		7050		6949	101	
		06-18	7800		7050		7034	16	
		18-22	7800		7050		6949	101	
		22-24	7800		7050		6949	101	
	2nd July 2017	00-05	7800	750	7050	6949	101		
		05-06	7800		7050		6949	101	
		06-0730	7800		7050		7034	16	
		0730-18	6400		5650		7034	0	
		18-22	6400		5650		6949	0	
		22-24	6400		5650		6949	0	
	3rd July 2017 to 31st July 2017	00-05	7800	750	7050	6949	101		
		05-06	7800		7050		6949	101	
		06-18	7800		7050		7034	16	
		18-22	7800		7050		6949	101	
		22-24	7800		7050		6949	101	

\* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

\* For approving STOA Bilateral transactions, margin available in Simultaneous Import of NR would be apportioned on WR-NR Corridor & ER-NR

Corridor in the following ratio:

Margin in Simultaneous import of NR = A

WR-NR ATC = B

ER-NR ATC = C

Margin for WR-NR applicants =  $A * B / (B + C)$

Margin for ER-NR Applicants =  $A * C / (B + C)$

**Simultaneous Export Capability**

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments				
<b>NR*</b>	1st July 2017 to 31st July 2017	00-06	4500	700	3800	248	3552						
		06-18'			3800	368	3432						
		18-24	4500		3800	248	3552						
<b>NER</b>	1st July 2017 to 4th July 2017	00-17	1180	45	1135	0	1135						
		17-23	1050		1005		1005						
		23-24	1180		1135		1135						
	5th July 2017	00-08	1180	45	1135	0	1135						
		08-16	930		885		885						
		16-17	1180		1135		1135						
		17-23	1050		1005		1005						
	6th July 2017 to 31st July 2017	23-24	1180	45	1135	0	1135						
		00-17	1180		1135		1135						
		17-23	1050		1005		1005						
	<b>WR</b>												
<b>SR *</b>	1st July 2017 to 31st July 2017	00-24	No limit is being Specified.										

\* Fifty Percent (50 % ) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

**Limiting Constraints (Corridor wise)**

Corridor	Constraint	Applicable Revisions
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak	All
WR-NR	(n-1) Contingency of 765kV Gwalior-Agra one ckt leads to 2750 MW loading on second circuit. High Loading of 400kV Singrauli-Anpara S/C.	All
	(n-1) Contingency of 765kV Gwalior-Agra one ckt leads to 2750 MW loading on second circuit. High Loading of 400kV Singrauli-Anpara S/C and restriction on power flow of HVDC V'chal from WR to NR.	Rev 8
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli	All
ER-NR	(n-1) contingencies of N.Ranchi - Chandawa S/c & (n-1) contingencies of 400kV MPL- Maithon S/c and high availability of Hydro power	All
WR-SR & ER-SR	(n-1) contingency of 765kV Aurangabad-Sholapur will lead to 874 MW loading on 400kV Vemagiri(PG)-Gazuwaka (With Opening of 400kV Vemagiri(PG)-Nunna S/C)	Rev 0
	(n-1) contingency of 400 kV Dichipalli-Ramagundam or (n-1) contingency of one circuit of 765kV Aurangabad-Sholapur will lead to 874 MW loading on 400kV Vemagiri(PG)-Gazuwaka (With Opening of 400kV Vemagiri(PG)-Nunna S/C)	Rev 1-4, Rev 6-8
	(n-1) contingency of other ckt of 765kV Raichur-Sholapur will lead to 874MW loading on 400kV Vemagiri(PG)-Gazuwaka (With Opening of 400kV Vemagiri(PG)-Nunna S/C)	Rev 5
	Low Voltage at Gazuwaka (East) Bus.	All
ER-NER	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa High loading of 220 kV Sonabil-Samaguri line(200 MW)	All
NER-ER	(n-1) contingency of 400 kV Byrnihat - Bongaigaon line High loading of 220 kV Sonabil-Samaguri line(200 MW)	All
W3 zone Injection	---	

**Limiting Constraints (Simultaneous)**

			Applicable Revisions
NR	Import	(n-1) contingencies of N.Ranchi - Chandawa S/c & (n-1) contingencies of 400kV MPL- Maithon S/C and high availability of Hydro power	All
		(n-1) Contingency of 765kV Gwalior-Agra one ckt leads to 2750 MW loading on second circuit. High Loading of 400kV Singrauli-Anpara S/C.	All
		(n-1) Contingency of 765kV Gwalior-Agra one ckt leads to 2750 MW loading on second circuit. High Loading of 400kV Singrauli-Anpara S/C and restriction on power flow of HVDC V'chal from WR to NR.	Rev 8
	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.	All
		(n-1) contingency of 400 kV Saranath-Pusauli	All
NER	Import	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa High loading of 220 kV Sonabil-Samaguri line(200 MW)	All
	Export	(n-1) contingency of 400 kV Byrnihat - Bongaigaon line High loading of 220 kV Sonabil-Samaguri line(200 MW)	All
SR	Import	(n-1) contingency of one circuit of 765kV Aurangabad-Sholapur will lead to 874 MW loading on 400kV Vemagiri(PG)-Gazuwaka (With Opening of 400kV Vemagiri(PG)-Nunna S/C)	Rev 0
		(n-1) contingency of 400 kV Dichipalli-Ramagundam or (n-1) contingency of one circuit of 765kV Aurangabad-Sholapur will lead to 874 MW loading on 400kV Vemagiri(PG)-Gazuwaka (With Opening of 400kV Vemagiri(PG)-Nunna S/C)	Rev 1-4, Rev 6-8
		(n-1) contingency of other ckt of 765kV Raichur-Sholapur will lead to 874MW loading on 400kV Vemagiri(PG)-Gazuwaka (With Opening of 400kV Vemagiri(PG)-Gazuwaka (With Opening of 400kV Vemagiri(PG)-Nunna S/C)	Rev 5
		Low Voltage at Gazuwaka (East) Bus	All

**National Load Despatch Centre  
Total Transfer Capability for July 2017**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>	<b>Corridor Affected</b>
1	27th April 2017	Whole month	STOA Margins revised due to change in LTA / MTOA approved by CTU	ER - NR / Import of NR
			Revised considering commissioning of one pole of HVDC Champa - Kurukshetra, the present load generation balance and change in LTA/MTOA approved by CTU	WR - NR / Import of NR
			Revised considering the commissioning of 765 kV Durg - Wardha D/C, second ICT at Vemagiri, 765 kV Wardha - Nizamabad D/C, two ICTs at Nizamabad, and 400 kV Nizamabad-Dichipally D/C.	WR - SR / ER - SR / Import of SR
2	5th May 2017	Whole month	Revised considering the latest LTA/MTOA granted by CTU	WR - SR / ER - SR / Import of SR
3	9th May 2017	Whole month	Revised considering the latest LTA/MTOA granted by CTU	WR - SR / Import of SR
4	23rd May 2017	Whole month	Revised considering present Inter-regional flow pattern	Import of NR
5	01st July 2017	02nd July 2017	Revised due to shutdown of 765kV Raichur-Sholapur-1	WR - SR / Import of SR
6	03rd July 2017	05th July 2017	Revised due to day-time shutdown of 400/220 kV ICT-II at Misa Substation	ER - NER /NER-ER
7	04th July 2017	05th & 06th July 2017	Due to Shutdown of Champa-Kurukshetra pole-1 for testing of Pole-2	WR-NR/ NR Import
8	06th July 2017	07th to 14 July 2017	Revised due to shutdown of HVDC Rihand Dadri Pole-1	WR-NR/ NR Import

ASSUMPTIONS IN BASECASE					
				Month : July'17	
S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
I	NORTHERN REGION				
1	Punjab	10671	9480	4285	4302
2	Haryana	8203	8052	1533	1533
3	Rajasthan	8264	9534	4458	4458
4	Delhi	5767	6332	940	940
5	Uttar Pradesh	14322	14317	10032	10036
6	Uttarakhand	1869	1634	985	962
7	Himachal Pradesh	1184	1068	921	863
8	Jammu & Kashmir	2359	1498	920	930
9	Chandigarh	327	300	0	0
10	ISGS/IPPs	27	27	19979	18386
	Total NR	52992	52241	44053	42410
II	EASTERN REGION				
1	Bihar	3920	2608	238	238
2	Jharkhand	1193	836	397	337
3	Damodar Valley Corporation	2961	2554	4468	3768
4	Orissa	4173	3199	3342	2325
5	West Bengal	8359	5800	5216	4148
6	Sikkim	88	89	0	0
7	Bhutan	245	245	982	982
8	ISGS/IPPs	560	567	11255	8518
	Total ER	21469	15868	25869	20286
III	WESTERN REGION				
1	Maharashtra	14940	11898	9694	7279
2	Gujarat	12432	10131	9835	7466
3	Madhya Pradesh	7044	5925	3569	3099
4	Chattisgarh	3353	3104	1915	2461
5	Daman and Diu	286	279	0	0
6	Dadra and Nagar Haveli	740	717	0	0
7	Goa-WR	399	296	0	0
8	ISGS/IPPs	2701	2844	32655	29850
	Total WR	41896	35194	57668	50154
IV	SOUTHERN REGION				
1	Andhra Pradesh	7900	7330	6080	5500
2	Telangana	7305	5815	4523	3329
3	Karnataka	8717	7530	5689	4314
4	Tamil Nadu	14750	12574	8145	6750
5	Kerala	3450	1780	1499	283
6	Pondy	395	395	0	0
7	Goa-SR	89	89	0	0
8	ISGS/IPPs	0	0	11044	9692
	Total SR	42606	35513	36980	29868
V	NORTH-EASTERN REGION				
1	Arunachal Pradesh	143	89	0	0
2	Assam	1227	1069	240	200
3	Manipur	150	76	0	0
4	Meghalaya	268	200	214	164
5	Mizoram	95	69	8	8
6	Nagaland	122	83	22	16
7	Tripura	254	157	75	75
8	ISGS/IPPs	100	60	2030	1888
	Total NER	2359	1803	2589	2351
	Total All India	161566	140864	168142	146052