National Load Despatch Centre Total Transfer Capability for July 2019

Issue Date: 05th April 2019

Issue Time: 1800 hrs

Revision No. 1

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
	1st July 2019	00-06				195	1805			
NR-WR*	to 31st July	06-18	2500	500	2000	250	1750			
	2019	18-24				195	1805			
	1st July 2019		13250		12750	9485	3265			
WR-NR*	to 31st July 2019	00-24	12300**	500	11800**	8535**	3265**			
	1st July 2019	00-06	2000		1800	193	1607			
NR-ER*	to 31st July	06-18	2000	200	1800	303	1497			
	2019	18-24	2000		1800	193	1607			
ER-NR*	1st July 2019 to 31st July 2019	00-24	5250	300	4950	3979	971			
W3-ER	1st July 2019 to 31st July 2019	00-24		No limit is being specified.						
ER-W3	1st July 2019 to 31st July 2019	00-24				No limit i	s being specified.			
		00-05	5550		5050		615			
WR-SR	1st July 2019 to 31st July	05-22	5550	500	5050	4435	615			
	2019	22-24	5550		5050	-	615			
SR-WR *	1st July 2019 to 31st July 2019	00-24	No limit is being Specified.							
		00-06				2762	1938			
ER-SR	1st July 2019 to 31st July	06-18	4950	250	4700	2847	1950			
	2019	18-24	1250	230	4700					
SR-ER *	1st July 2019 to 31st July 2019	00-24		2762 1938 No limit is being Specified.						

National Load Despatch Centre Total Transfer Capability for July 2019

Issue Date: 05th April 2019

Issue Time: 1800 hrs

Revision No. 1

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
		00-17	1010		965	709		Revised STOA margin due to the following:- a) Operationalization of 25.74 MW	
ER-NER	1st July 2019 to 31st July 2019	17-23	1080	45	1035	256	779		LTA from Tuticorin Mytrah Power to Assam. b) Operationalization of 5 MW
	2017	23-24	1010		965		709		LTA from Rajasthan (Solar Power) to Assam. c) Completion of the period of allocation of 40 MW power from Mouda Stg-II to Assam.
	1st July 2019	00-17	2220		2175		2175		
NER-ER	to 31st July	17-23	2460	45	2415	0	2415		
	2019	23-24	2220		2175		2175		
W3 zone Injection 1st July 2019 to 31st July 2019 00-24 No limit is being specified (In case of any constraints appearing in the system, W3 zone export would be revised accordingly)									
	ATC of S1-(S2&S ction in Monthly	,	or, Import of	S3(Kerala),	Import of Pun	jab and Import o	f DD & DNH is u	ploaded or	NLDC website under Intra-

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

**Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.

1) S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala

2) W3 comprises of the following regional entities :

a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCL, n)Vandana Vidyut o)RKM, p)GMR Raikheda, q)Ind Barath and any other regional entity generator in Chhattisgarh

The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissionned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown :

1) The TTC value will be revised to normal values after restoration of shutdown.

2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

Simultaneous Import Capability

Corrido r	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER									
		00-06	17650 16700**		16850 15900**		3386 3386**		
NR	1st July 2019 to	06-17	18900	800	18100	13464	4636		
	31st July 2019		17950**		17150**	12514**	4636**		
		17.04	17000		16200		2736		
		17-24	16050**		15250**		2736**		
		00-17	1010		965		709		Revised STOA margin due to the following:-
NER	1st July 2019 to 31st July 2019	17-23	1080	45	1035	256	779		 a) Operationalization of 25.74 MW LTA from Tuticorin Mytrah Power to Assam. b) Operationalization of 5 MW LTA from Rajasthan (Solar
		23-24	24 1010		965		709		Power) to Assam. c) Completion of the period of allocation of 40 MW power from Mouda Stg-II to Assam.
WR									
		00-06	10500		9750	7197	2553		
SR	1st July 2019 to 31st July 2019	06-18	10500	750	9750	7282	2468		
		18-24	10500		9750	7197	2553		

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

**Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.

* For approving STOA Bilateral transactions, margin available in Simultaneous Import of NR would be apportioned on WR-NR Corridor & ER-NR Corridor in the following ratio:

Margin in Simultaneous import of NR = A WR-NR ATC =B ER-NR ATC = C

Margin for WR-NR applicants = A * B/(B+C)Margin for ER-NR Applicants = A * C/(B+C)

Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR*	1st July 2019 to 31st July 2019	00-06	4500 700	700	3800	388	3412		
		18-24	4500	700	3800 3800	553 388	<u>3247</u> 3412		
	1st July 2019 to 31st July 2019	00-17	2700		2655	0	2655		
NER		17-23	2890		2845		2845		
	51st July 2019	23-24	2700		2655		2655		
WR									
W IX									
SR *	1st July 2019 to 31st July 2019	00-24		No limit is being Specified.					

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Limiting Constraints (Corridor wise)

		Applicable Revisions
Corridor	Constraint	
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Bhanpura-Modak	Rev-0 to 1
WR-NR	n-1 contingency of 2x1500 MVA, 765/400 kV ICTs at Agra (PG) will lead to overloading of the second ICT	Rev-0 to 1
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli	Rev-0 to 1
ER-NR	 N-1 contingencies of 400 kv Mejia-Maithon A S/C N-1 contingencies of 400 kv Kahalgaon-Banka S/C N-1 contingencies of 400kV MPL- Maithon S/C 	Rev-0 to 1
WR-SR	n-1 contingency of 2x315 MVA, 400/220 kV ICTs at Mardam will lead to overloading of the second ICT	Rev-0 to 1
and ER-	n-1 contingency of 2x1500 MVA, 765/400 kV ICTs at Vemagiri (PG) will lead to overloading of the second ICT	Rev-0 to 1
SR	Low Voltage at Gazuwaka (East) Bus.	Rev-0 to 1
	a. (n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa b. High loading of 220 kV Balipara-Sonabil line(200 MW)	Rev-0 to 1
NER-ER	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other ICT at Misa	Rev-0 to 1
W3 zone Injection		Rev-0 to 1

Limiting Constraints (Simultaneous)

			Applicable Revisions
NR	Import	 N-1 contingencies of 400 kv Mejia-Maithon A S/C N-1 contingencies of 400 kv Kahalgaon-Banka S/C N-1 contingencies of 400kV MPL- Maithon S/C 	Rev-0 to 1
Export		n-1 contingency of 2x1500 MVA, 765/400 kV ICTs at Agra (PG) will lead to overloading of the second ICT (n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak. (n-1) contingency of 400 kV Saranath-Pusauli	Rev-0 to 1 Rev-0 to 1
NER	Import	 a. (n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa b. High loading of 220 kV Balipara-Sonabil line(200 MW) 	Rev-0 to 1
	Export	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other ICT at Misa	Rev-0 to 1
		n-1 contingency of 2x315 MVA, 400/220 kV ICTs at Mardam will lead to overloading of the second ICT	Rev-0 to 1
SR	Import	n-1 contingency of 2x1500 MVA, 765/400 kV ICTs at Vemagiri (PG) will lead to overloading of the second ICT	Rev-0 to 1
		Low Voltage at Gazuwaka (East) Bus.	Rev-0 to 1

National Load Despatch Centre Total Transfer Capability for July 2019

Revision	Date of	Period of	Reason for Revision/Comment	Corridor
No	Revision	Revision		Affected
1	05th April 2019	Whole Month	a) Operationalization of 25.74 MW LTA from Tuticorin Mytrah Power to Assam. b) Operationalization of 5 MW LTA from Rajasthan (Solar Power) to Assam. c) Completion of the period of allocation of 40 MW power from Mouda Stg-II to Assam.	ER-NER/Import of NER

ASSUN	IPTIONS IN BASECASE				
				Month : July'19	
S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
Ι	NORTHERN REGION				
1	Punjab	10250	11742	4780	4800
2	Haryana	8317	8028	1804	1804
3	Rajasthan	11243	9679	7787	7799
4	Delhi	6320	6125	860	860
5	Uttar Pradesh	17229	17131	8644	8621
6	Uttarakhand	2195	1882	993	833
7	Himachal Pradesh	1609	1345	815	808
8	Jammu & Kashmir	3046	1923	1302	1301
9	Chandigarh	351	259	0	0
10	ISGS/IPPs	29	29	21398	19959
	Total NR	60589	58143	48383	46785
II	EASTERN REGION				
1	Bihar	4612	3116	208	168
2	Jharkhand	1369	849	389	274
3	Damodar Valley Corporation	2913	2723	5367	3690
4	Orissa	4405	3408	3020	1952
5	West Bengal	8931	5741	6226	4208
6	Sikkim	105	89	0	0
7	Bhutan	198	195	1048	1097
8	ISGS/IPPs	294	605	11522	9561
	Total ER	23135	16726	28250	20952
111	WESTERN REGION				
1	Maharashtra	16519	12329	11941	9637
2	Gujarat	13991	11043	10010	8186
3	Madhya Pradesh	8143	6183	4045	3434
4	Chattisgarh	3926	2901	2690	2080
5	Daman and Diu	320	292	0	0
6	Dadra and Nagar Haveli	744	731	0	0
7	Goa-WR	536	329	0	0
8	ISGS/IPPs	4397	2734	40908	20998
0	Total WR	47538	36543	55273	44335

S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
IV	SOUTHERN REGION				
1	Andhra Pradesh	8521	7712	6363	4357
2	Telangana	10865	9259	4607	4340
3	Karnataka	10097	4946	8740	4462
4	Tamil Nadu	15419	13443	8712	6913
5	Kerala	3666	2175	1458	381
6	Pondy	359	354	0	0
7	Goa-SR	70	69	0	0
8	ISGS/IPPs	0	0	13977	12028
	Total SR	48998	37958	43402	32481
V	NORTH-EASTERN REGION				
1	Arunachal Pradesh	134	62	0	0
2	Assam	1808	1295	255	192
3	Manipur	178	83	0	0
4	Meghalaya	284	206	301	214
5	Mizoram	101	68	66	33
6	Nagaland	127	83	21	12
7	Tripura	252	149	80	80
8	ISGS/IPPs		99		2352
	Total NER	3044	2046	3150	2883
	Total All India	184769	152866	191199	157257