National Load Despatch Centre Total Transfer Capability for June 2013

Issue Date: 12/06/2013

Issue Time: 1700 hrs

Revision No. 11

Corridor	# against any corride Date	Time Time Period (hrs)	Total Transfer Capability (TTC)	n has been dor Reliability Margin	Available Transfer Capability (ATC)	dor Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
NR-WR	1st June 2013 to 30th June 2013	00-24	2500	500	2000	286	1714		Revised due to commissioning of 765 kV Agra-Jhatikara.	
	1st June 2013 to 9th June 2013	00-24	5700 ^Δ	500	5200^{Δ}	2787^{Δ}	2413		Revised due to commissioning of 765 kV Agra-Jhatikara.	
	10th June 2013	00-08'	5700 [∆]	500	5200^{Δ}	2787^{Δ}	2413		Revised due to deferrment of 765	
	10th Julie 2013	08-24'	5700 [∆]	500	5200^{Δ}	2787^{Δ}	2413		kV Agra-Jhatikara Shutdown.	
WR-NR ¹	11th June 2013	00-07'	5700 ^Δ	500	5200^{Δ}	2787^{Δ}	2413			
WIR THE	11th Julie 2013	07-24'	3100 ^Δ	300	2800^{Δ}	2787^{Δ}	13		Revised due to Shutdown of 765 kV	
	12th June 2013	00-24	3100 [∆]	300	2800^{Δ}	2787^{Δ}	13		Agra-Jhatikara.	
	13th June 2013 to 30th June 2013	00-24	5700 ^Δ	500	5200^{Δ}	2787^{Δ}	2413		Revised due to commissioning of 765 kV Agra-Jhatikara.	
	1st June 2012 t-	00-17	1000		800		800			
NR-ER	1st June 2013 to 30th June 2013	23-24	1000	200	800	0	800			
	2011	17-23 00-09	1100 3600	300	900 3300	1913	900 1387			
	1st June 2013	09-18'	3000	300	2700	1913	787		Revised due to shutdown of 400 kV	
		18-24	3600	300	3300	1913	1387		Kahalgaon-Biharshariff 1	
	2nd June 2013	00-24	3600	300	3300	1913	1387			
	2.11	00-09	3600	300	3300	1913	1387		Revised due to shutdown of 400 kV	
	3rd June 2013	09-18' 18-24	3000 3600	300 300	2700 3300	1913 1913	787 1387	-	Kahalgaon-Biharshariff 2	
	4th June 2013	00-09								
ER-NR		18-24 09-18'	3600 3000	300 300	3300 2700	1913 1913	1387 787		Revised due to shutdown of 400 kV Kahalgaon-Biharshariff ckt-1.	
	5th June 2013	00-09	3600	300	3300	1913	1387		Revised due to shutdown of 400 kV	
		18-24 09-18'	3000	300	2700	1913	787		Kahalgaon-Biharshariff ckt-1.	
	<1.1. A010	09-18	5000	500	2700					
	6th June 2013 to 30th June 2013	23-24 17-23	3600	300	3300	1913 1913	1387 1387	-		
W3-ER	1st June 2013 to 30th June 2013	00-24	1650	300	1350	0	1350			
ER-W3	1st June 2013 to 30th June 2013	00-24	1000	300	700	700	0			
	1st June 2013 to	1					1	[Davised due to shares in LTA MTOA	
WR-SR	15th June 2013 to 15th June 2013 to	00-24	1000	0	1000	1000	0		Revised due to change in LTA/MTOA quantum.	
	30th June 2013	00-24	1000	0	1000	1000	0			
SR-WR	1st June 2013 to 30th June 2013	00-24	1000	0	1000	0	1000			
	1.41 0010	00-05	1000		1000		888			
	1st June 2013 to 12th June 2013	10-19 05-10	1000	0	1000	112	888	-	Revised considering present loading of 400KV Rourkela-Talcher D/C	
ER-SR#	13th June 2013	19-24 00-08 19-24	1000	0	1000	112	888		Revised due to Emergency shutdown of	
	2015	08-19'	700	Ŭ	700	700	0	300	Talcher-Kolar HVDC Pole-2.	
	14th June 2013 to	00-05 10-19	1000	0	1000	112	888			
	15th June 2013	05-10 19-24	1000	0	1000	112	888			
	16th June 2013 to	00-05 10-19	1000	0	1000	612	388			
	30th June 2013	05-10 19-24	1000	0	1000	612	388			

National Load Despatch Centre Total Transfer Capability for June 2013

Issue Date: 12/06/2013

Issue Time: 1700 hrs

Revision No. 11

	# against any corrido	or indicate	es that revision	n has been doi	ne for this corri				
Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
SR-ER	1st June 2013 to 30th June 2013	00-17 23-24	700	0	700	197	503		
		17-23	700		700		503		
		00-07					[1	
	1st June 2013 to 8th June 2013	18-24	575	35	540	230	310		Revised due to shutdown of 400 kV Binaguri-Bongoigaon ckt 2
		07-18'	400		365	230	135		n + Binagari Bongoigaon ent 2
ER-NER	9th June 2013 to 11th June 2013	00-24	575	35	540	230	310		
EK-NEK	12th June 2013 to	00-08 18-24	575	35	540	230	310		Revised due to shutdown of 400
	16th June 2013	08-18'	400	55	365	230	135		kV Binaguri-Bongoigaon ckt 2
	17th June 2013 to	00-10	400		305	230	155		
	30th June 2013	00-24	575	35	540	230	310		
NER-ER	1st June 2013 to 30th June 2013	00-17 23-24	520	100	420	0	420		
	30th June 2013	17-23	320		220		220		
	1						1	1	
	1st June 2013 to 15th June 2013	00-24	5400	200	5200	3800	1400		Revised due to Non-commissioning Kudamkulam unit-1 and change in LTA quantum as Talcher unit-4 has
S1-S2	16th June 2013 to 30th June 2013	00-24	5400	200	5200	4500	700		gone under annual maintenance from 00:00 Hrs of 27.05.2013 to 30.06.2013.
Import of Punjab #	1st June 2013 to 30th June 2013	00-24	5600	300	5300	3475	1825	125	LTA/MTOA quantum revised due to change in Allocation.
Import TTC for DD & DNH	1st June 2013 to 30th June 2013	00-24	980	0	980	LTA and MTO scheo			0
		00-08	9000		8800		1970		
	1st June 2013	08-17' 23-24	8000	200	7800	6830	970		Revised due to shutdown of 400 kV
		17-23	8500		8300		1470		Raipur-Wardha D/C from 01st June
		00-17	8000		7800		970		2013 to 2nd June 2013
W3 zone	2nd June 2013	17-19	8500	200	8300	6830	1470		
W3 zone Injection	2110 Julie 2013	19-23	9500	200	9300	0650	2470		
		23-24	9000		8800		1970		
	3rd June 2013 to 15th June 2013	00-17, 23-24	9000	200	8800	6830	1970		
	2010	17-23	9500		9300		2470		
	16th June 2013 to	00-17,	9000	200	8800	7630	1170		
	30th June 2013	23-24 17-23	9500	200	9300	/030	1670		1
50		17-25	9500		9300		10/0		

1) ER-SR TTC declared at Talcher Interconnector and Gazuwaka HVDC B/B seam

2) S1 comprises of AP and Karnataka: S2 comprises of Tamil Nadu, Kerala and Pondicherry

3) W3 comprises of the following regional entities :

a) Chattisgarh, b) Jindal Power Limited (JPL), c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak

f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat

g) In cases where TTC is revised on account of any transmission element shutdown, the revised TTC shall be effective till the time the transmission element under shutdown is restored back.

A. includes 1500 MW on the dedicated Mundra-Mohindergarh HVDC bipole of M/s Adani Power Limited which is scheduled separately from the generation at stage-III of APL Mundra (3*660 MW).

National Load Despatch Centre Total Transfer Capability for June 2013

Issue Date: 12/06/2013				Issue Tim	e: 1700 hrs		Revision N	Io. 11	
	# against any corri	idor indicate	es that revision	n has been doi	ne for this corr	idor			
Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
• 765 kV A	al Transfer capab Agra-Jhatikara he 765/400 kV 150	·		3100 MW in c	ase of outage o	f any one of the fo	llowing sections	:	

765 kV Gwalior-Agra one circuit
765 kV Bina-Gwalior one circuit

Limiting Constraints

Corridor	Constraint
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.
WR-NR	(n-1) contingency of 765/400 kV ICT at Agra
NR-ER	(n-1) contingency of 400 kV Allahabad-Pusauli
ER-NR	Outage in 400 kV Purnea-Muzaffarpur Section
W3-ER	(n-1) contingency of either 400 kv Mejia-Maithon or
	(n-1) contingency of 400 kv MPL -maithon
ER-W3	High loading of 400 kV Raipur-Bhadrawati T/C, Bhilai-Bhadrawati S/C, Bhilai-Koradi and Bhilai-Seoni*
EK-W3	(n-1) contingency of 400kV Rourkela-Raigarh
WR-SR	Bhadrawati HVDC B/B link capacity
SR-WR	Bhadrawati HVDC B/B link capacity
ER-SR	(n-1) contingency of 400 kV Rourkela-Talcher
SR-ER	
	(n-1) contingency of 400 kV Farakka-Malda*
ER-NER	High Loading of 220 kV BTPS-Agia
	(n-1) contingency of 400 kV Balipara – Bongaigaon
NER-ER	(n-1) contingency of 400 kV Balipara-Bongaigaon-I
	(n-1) contingency of 220 kV Samaguri – Saruajai I*
S1-S2	(n-1) contingency of 400 kV Hosur-Salem D/C line, 400kV Hosur-Salem & 400kV Somanahalli-Salem SC line.
Import of	(n-1) contingency of ICT at Patiala/Moga
Punjab	(in 1) contingency of for all automations
W3 zone	(n-1-1) contingency of 400 kV Raipur-Bhadrawati D/C section
Injection	(n 1 1) contingency of 100 k V Raipar Diadrawan D/C socion

Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER									
		00-09	9300^{Δ}	800	8500^{Δ}	4300	4200		
	1st June 2013	09-18'	8700^{Δ}	800	7900^{Δ}	4300	3600		Revised due to shutdown of 400 kV Kahalgaon-Biharshariff 1
		18-24	9300^{Δ}	800	8500^{Δ}	4300	4200		
	2nd June 2013	00-24	9300^{Δ}	800	8500^{Δ}	4300	4200		
		00-09	9300^{Δ}	800	8500^{Δ}	4300	4200		
	3rd June 2013	09-18'	8700^{Δ}	800	7900^{Δ}	4300	3600		Revised due to shutdown of 400 kV Kahalgaon-Biharshariff 2
		18-24	9300^{Δ}	800	8500^{Δ}	4300	4200		
v1	4th June 2013	00-09 18-24	9300^{Δ}	800	8500^{Δ}	4300	4200		Revised due to shutdown of 400 kV Kahalgaon-Biharshariff 1
NR ¹		09-18'	8700^{Δ}	800	7900^{Δ}	4300	3600		
	5th June 2013	00-09 18-24	9300^{Δ}	800	8500^{Δ}	4300	4200		Revised due to shutdown of 400 kV Kahalgaon-Biharshariff 1
		09-18'	8700^{Δ}	800	7900^{Δ}	4300	3600		
	6th June 2013 to 09th June 2013	00-24	9300 [∆]	800	8500^{Δ}	4300^{Δ}	4200		
	10th June 2013	00-08'	9300^{Δ}	800	8500^{Δ}	1.2.0.0	4200		Revised due to deferrment of
		08-24'	9300^{Δ}	800	8500^{Δ}	4300^{Δ}	4200		765 kV Agra-Jhatikara Shutdown.
	11th June 2013	00-07'	9300^{Δ}	800	8500^{Δ}		4200		
		07-24'	6700^{Δ}	600	6100^{Δ}	4300^{Δ}	1400		Revised due to Shutdown of 765
	12th June 2013	00-24	6700^{Δ}	600	6100^{Δ}	4300^{Δ}	1400		kV Agra-Jhatikara.
	13th June 2013 to 30th June 2013	00-24	9300 ^Δ	800	8500 ^Δ	4300 ^Δ	4200		
	1st June 2013 to 08th June 2013	00-07 18-24	575	35	540	230	310		Revised due to shutdown of 400 kV Binaguri-Bongoigaon
		07-18'	400		365	230	135		ckt 2
NER	9th June 2013 to 11th June 2013	00-24	575	35	540	230	310		
	12th June 2013 to 16th June 2013	00-08 18-24	575	35	540	230	310		Revised due to shutdown of 400 kV Binaguri-Bongoigaon
		08-18'	400		365	230	135		ckt 2
	17th June 2013 to 30th June 2013	00-24	575	35	540	230	310		
WR									
		00.05							De facilitate No.
SR#	1st June 2013 to	00-05 10-19	2000		2000		888		Revised due to Non- commissioning Kudamkulam
	15th June 2013	05-10	2000	0	2000	1112			unit-1 and change in LTA
		19-24	2000		2000		888		quantum.
		00-08	2000	0	2000	1112	888		Revised due to Emergency
	13th June 2013	19-24		-					shutdown of Talcher-Kolar HVDC Pole-2.
	14th June 2013 to	08-19'	1700		1700	1700	0		r vie-2.
	15th June 2013	00-24 00-05	2000	0	2000	1112	888		
	16th June 2013 to	10-19	2000	0	2000	1(12	388		
	30th June 2013	05-10 19-24	2000	0	2000	1612	388		

Δ. includes 1500 MW on the dedicated Mundra-Mohindergarh HVDC bipole of M/s Adani Power Limited which is scheduled separately from the generation at stage-III of APL Mundra (3*660 MW).

1. WR-NR Total Transfer capability will be reduced to 3100 MW in case of outage of any one of the following sections:

• 765 kV Agra-Jhatikara

• One of the 765/400 kV 1500 MVA ICT at Agra

• 765 kV Gwalior-Agra one circuit

• 765 kV Bina-Gwalior one circuit

Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR	1st June 2013 to 30th June 2013	00-17 23-24	3500	700	2800	286	2514		
50th Jun	50til Julie 2015	17-23	3600		2900		2614		
NER	NER 1st June 2013 to 30th June 2013	00-17 23-24	520	100	420	0	420		
		17-23	320		220		220		
WR									
WK									
SR	1st May 2013 to	00-17 23-24	1700	0	1700	197	1503		
	31st May 2013	17-23	1700		1700		1503		

Limiting Constraints

NR	Import	(n-1) contingency of 400 kV Farakka-Malda* (n-1) contingency of 765/400 kV ICT at Agra*
	Export	(n-1) contingency of 400 kV Allahabad-Pusauli
	Import	High Loading of 220 kV BTPS-Agia
		(n-1) contingency of 400 kV Balipara – Bongaigaon-I
NER		(n-1) contingency of 400 kV Farakka-Malda*
	Export	(n-1) contingency of 220 kV Samaguri – Saruajai I*
		(n-1) contingency of 400 kV Balipara-Bongaigaon-I
	Import	(n-1) contingency of 400 kV Rourkela-Talcher*
SR		Bhadrawati HVDC B/B link capacity.
	Export	Bhadrawati HVDC B/B link capacity.

*Primary constraints

ASSUMPTIONS IN BASECASE

S.No.		Lo	ad	Generation			
	Name of State/Area	Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)		
I	NORTHERN REGION						
1	Punjab	5637	5311	2111	2126		
2	Haryana	5363	5014	3289	3289		
3	Rajasthan	6574	5912	3466	3472		
4	Delhi	4605	3932	1416	1416		
5	Uttar Pradesh	10824	10831	6163	5976		
6	Jammu & Kashmir	1825	1671	604	592		
7	Uttarakhand	1476	1081	757	673		
8	Himachal Pradesh	1043	943	590	493		
9	Chandigarh	227	192	0	0		
10	ISGS			16916	1462		
	Total NR	37574	34888	35312	3266		
П	EASTERN REGION						
1	West Bengal	6658	5280	4836	367		
2	Jharkhand	1035	715	483	54		
3	Orissa	3597	2530	2451	161		
4	Bihar	1743	1430	101	10		
5	Damodar Valley Corporation	2461	2310	2954	295		
6	Sikkim	45	45	0	(
7	Bhutan	112	112	275	26		
8	ISGS			7384	585		
	Total ER	15651	12422	18484	1499		
1	WESTERN REGION						
	Chattisgarh	2977	2132	2518	198		
2	Madhya Pradesh	7112	4894	3601	2802		
3	Maharashtra	15798	12916	13113	9454		
4	Gujarat	10470	8369	10918	776		
5	Goa	327	198				
6	Daman and Diu	260	181				
7	Dadra and Nagar Haveli	612	479	12062	1100		
8	ISGS			13063	1199		
	Total WR	37556	29169	43213	3400		
IV	SOUTHERN REGION						
1	Andhra Pradesh	10283	9413	7290	656		
2	Tamil Nadu	10203	9413	6050	540		
3	Karnataka						
4	Kerala	8503	7453	4779 2007	423		
4	Pondy	3254 313	2414 241	2007	79		
6	-						
7	Goa ISGS	84	84	10846	1004		
1	Total SR	33250	28705	30972	2704		
		33250	20/05	30972	2704		
v	NORTH-EASTERN REGION						
1	Manipur	110	203	0			
2	Meghalaya	290	53	95	8		
3	Mizoram	75	84	4			
4	Nagaland	120	168	8			
5	Assam	1320	880	190	18		
6	Tripura	240	1537	85	8		
0		440		0			
7	Arunachal Pradesh	110	924	0			
	Arunachal Pradesh ISGS	110	924	1013			
7					57 92		