

**National Load Despatch Centre
Total Transfer Capability for June 2013**

Issue Date: 28/06/2013

Issue Time: 1830 hrs

Revision No. 17

against any corridor indicates that revision has been done for this corridor

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR-WR	1st June 2013 to 30th June 2013	00-24	2500	500	2000	286	1714		Revised due to commissioning of 765 kV Agra-Jhatikara.
WR-NR ¹	1st June 2013 to 9th June 2013	00-24	5700 ^Δ	500	5200 ^Δ	2787 ^Δ	2413		Revised due to commissioning of 765 kV Agra-Jhatikara.
	10th June 2013	00-08'	5700 ^Δ	500	5200 ^Δ	2787 ^Δ	2413		Revised due to deferral of 765 kV Agra-Jhatikara Shutdown.
		08-24'	5700 ^Δ	500	5200 ^Δ	2787 ^Δ	2413		
	11th June 2013	00-07'	5700 ^Δ	500	5200 ^Δ	2787 ^Δ	2413		Revised due to Shutdown of 765 kV Agra-Jhatikara.
		07-24'	3100 ^Δ	300	2800 ^Δ	2787 ^Δ	13		
	12th June 2013	00-24	3100 ^Δ	300	2800 ^Δ	2787 ^Δ	13		
13th June 2013 to 30th June 2013	00-24	5700 ^Δ	500	5200 ^Δ	2787 ^Δ	2413		Revised due to commissioning of 765 kV Agra-Jhatikara.	
NR-ER	1st June 2013 to 30th June 2013	00-17 23-24	1000	200	800	0	800		
		17-23	1100		900		900		
ER-NR	1st June 2013	00-09	3600	300	3300	1913	1387		Revised due to shutdown of 400 kV Kahalgaon-Biharshariff 1
		09-18'	3000	300	2700	1913	787		
		18-24	3600	300	3300	1913	1387		
	2nd June 2013	00-24	3600	300	3300	1913	1387		
		00-09	3600	300	3300	1913	1387		
	3rd June 2013	00-09	3600	300	3300	1913	1387		Revised due to shutdown of 400 kV Kahalgaon-Biharshariff 2
		09-18'	3000	300	2700	1913	787		
		18-24	3600	300	3300	1913	1387		
	4th June 2013	00-09 18-24	3600	300	3300	1913	1387		Revised due to shutdown of 400 kV Kahalgaon-Biharshariff ckt-1.
		09-18'	3000	300	2700	1913	787		
	5th June 2013	00-09 18-24	3600	300	3300	1913	1387		Revised due to shutdown of 400 kV Kahalgaon-Biharshariff ckt-1.
		09-18'	3000	300	2700	1913	787		
6th June 2013 to 30th June 2013	00-17 23-24	3600	300	3300	1913	1387			
	17-23				1913	1387			
W3-ER	1st June 2013 to 30th June 2013	00-24	1650	300	1350	0	1350		
ER-W3	1st June 2013 to 30th June 2013	00-24	1000	300	700	700	0		
WR-SR	1st June 2013 to 15th June 2013	00-24	1000	0	1000	1000	0		Revised due to change in LTA/MTOA quantum.
	16th June 2013 to 24th June 2013	00-24	1000	0	1000	1000	0		
	25th June 2013	00-0830 19-24	1000	0	1000	1000	0		Revised due to shutdown of HVDC Bhadrawati Pole-2.
		0830-19'	500		500	500	0		
26th June 2013 to 30th June 2013	00-24	1000	0	1000	1000	0			
SR-WR	1st June 2013 to 30th June 2013	00-24	1000	0	1000	0	1000		
ER-SR	1st June 2013 to 12th June 2013	00-05 10-19	1000	0	1000	112	888		Revised considering present loading of 400KV Rourkela-Talcher D/C
		05-10 19-24	1000		1000		888		
	13th June 2013	00-08 19-24	1000	0	1000	112	888		Revised due to Emergency shutdown of Talcher-Kolar HVDC Pole-2.
		08-19'	700		700	0			
	14th June 2013 to 15th June 2013	00-07 18-24	1000	0	1000	112	888		Revised due to shutdown of 400 kV Rourkela-Talcher ckt-1/2
		07-18'	600		600		488		
	16th June 2013 to 19th June 2013	00-07 18-24	1000	0	1000	612	388		Revised due to shutdown of 400 kV Rourkela-Talcher ckt-1/2
		07-18'	600		600		0		

**National Load Despatch Centre
Total Transfer Capability for June 2013**

Issue Date: 28/06/2013

Issue Time: 1830 hrs

Revision No. 17

against any corridor indicates that revision has been done for this corridor

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER-SR	20th June 2013 to 24th June 2013	00-24	1000	0	1000	612	388		
	25th June 2013	00-0830 19-24	1000	0	1000	612	388		
		0830-19'	1000		1000	1000	0		
26th June 2013 to 30th June 2013	00-24	1000	0	1000	612	388			
SR-ER	1st June 2013 to 30th June 2013	00-17 23-24	700	0	700	197	503		
		17-23	700		700		503		
ER-NER	1st June 2013 to 8th June 2013	00-07 18-24	575	35	540	230	310		Revised due to shutdown of 400 kV Binaguri-Bongoigaon ckt 2
		07-18'	400		365	230	135		
	9th June 2013 to 11th June 2013	00-24	575	35	540	230	310		
	12th June 2013 to 13th June 2013	00-08 18-24	575	35	540	230	310		Revised due to shutdown of 400 kV Binaguri-Bongoigaon ckt 2
		08-18'	400		365	230	135		
	14th June 2013 to 15th June 2013	00-24	575	35	540	230	310		Revised due to cancellation of 400 kV Binaguri-Bongaigaon ckt-2 shutdown.
	16th June 2013	00-24	575	35	540	230	310		Revised due to cancellation of 400 kV Binaguri-Bongaigaon ckt-2 shutdown.
	17th June 2013 to 21st June 2013	00-24	575	35	540	230	310		
	22nd June 2013 to 24th June 2013	00-08 18- 24	575	35	540	230	310		Revised due to shutdown of 400 kV Binaguri-Bongoigaon ckt-2
		08-18'	400		365	230	135		
25th June 2013 to 30th June 2013	00-08 18- 24	575	35	540	230	310		Revised due to shutdown of 400 kV Binaguri-Bongoigaon ckt-1	
	08-18'	400		365	230	135			
NER-ER#	1st June 2013 to 23rd June 2013	00-17 23-24	520	100	420	0	420		
		17-23	320		220		220		
	24th June 2013 to 28th June 2013	00-08 23-24	520	100	420	0	420		Revised due to shutdown of 400 kV Binaguri-Bongoigaon ckt-1/2
		08-17'	400		300		300		
		17-23	320		220		220		
	29th June 2013 to 30th June 2013	00-08 17-24	550	100	450	0	450	30	Revised due to load generation Balance.
08-17'		400	300		300				
S1-S2	1st June 2013 to 15th June 2013	00-24	5400	200	5200	3800	1400		Revised due to Non-commissioning Kudamkulam unit-1 and change in LTA quantum as Talcher unit-4 has gone under annual maintenance from 00:00 Hrs of 27.05.2013 to 30.06.2013.
	16th June 2013 to 30th June 2013	00-24	5400	200	5200	4500	700		
Import of Punjab	1st June 2013 to 30th June 2013	00-24	5600	300	5300	3475	1825		LTA/MTOA quantum revised due to change in Allocation.
Import TTC for DD & DNH	1st June 2013 to 30th June 2013	00-24	980	0	980	LTA and MTOA as per ex-pp schedule			

National Load Despatch Centre
Total Transfer Capability for June 2013

Issue Date: 28/06/2013

Issue Time: 1830 hrs

Revision No. 17

against any corridor indicates that revision has been done for this corridor

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
W3 zone Injection	1st June 2013	00-08	9000	200	8800	6830	1970		Revised due to shutdown of 400 kV Raipur-Wardha D/C from 01st June 2013 to 2nd June 2013
		08-17'	8000		7800		970		
		23-24	8500		8300		1470		
	2nd June 2013	00-17	8000	200	7800	6830	970		
		17-19	8500		8300		1470		
		19-23	9500		9300		2470		
		23-24	9000		8800		1970		
	3rd June 2013 to 15th June 2013	00-17, 23-24	9000	200	8800	6830	1970		
		17-23	9500		9300		2470		
	16th June 2013 to 30th June 2013	00-17, 23-24	9000	200	8800	7630	1170		
		17-23	9500		9300		1670		

1) ER-SR TTC declared at Talcher Interconnector and Gazuwaka HVDC B/B seam

2) S1 comprises of AP and Karnataka; S2 comprises of Tamil Nadu, Kerala and Pondicherry

3) W3 comprises of the following regional entities :

a) Chattisgarh, b) Jindal Power Limited (JPL) , c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak

f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat

g) In cases where TTC is revised on account of any transmission element shutdown, the revised TTC shall be effective till the time the transmission element under shutdown is restored back.

Δ. includes 1500 MW on the dedicated Mundra-Mohindergarh HVDC bipole of M/s Adani Power Limited which is scheduled separately from the generation at stage-III of APL Mundra (3*660 MW).

1. WR-NR Total Transfer capability will be reduced to 3100 MW in case of outage of any one of the following sections:

- 765 kV Agra-Jhatikara
- One of the 765/400 kV 1500 MVA ICT at Agra
- 765 kV Gwalior-Agra one circuit
- 765 kV Bina-Gwalior one circuit

Limiting Constraints

Corridor	Constraint
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.
WR-NR	(n-1) contingency of 765/400 kV ICT at Agra
NR-ER	(n-1) contingency of 400 kV Allahabad-Pusaui
ER-NR	Outage in 400 kV Purnea-Muzaffarpur Section
W3-ER	(n-1) contingency of either 400 kv Mejia-Maithon or (n-1) contingency of 400 kv MPL -maithon
ER-W3	High loading of 400 kV Raipur-Bhadrawati T/C, Bhilai-Bhadrawati S/C, Bhilai-Koradi and Bhilai-Seoni* (n-1) contingency of 400kV Rourkela-Raigarh
WR-SR	Bhadrawati HVDC B/B link capacity
SR-WR	Bhadrawati HVDC B/B link capacity
ER-SR	(n-1) contingency of 400 kV Rourkela-Talcher
SR-ER	
ER-NER	(n-1) contingency of 400 kV Farakka-Malda* High Loading of 220 kV BTPS-Agia (n-1) contingency of 400 kV Balipara – Bongaigaon
NER-ER	(n-1) contingency of 400 kV Balipara-Bongaigaon-I (n-1) contingency of 220 kV Samaguri – Saruajai I*
S1-S2	(n-1) contingency of 400 kV Hosur-Salem D/C line, 400kV Hosur-Salem & 400kV Somanahalli-Salem SC line.
Import of Punjab	(n-1) contingency of ICT at Patiala/Moga
W3 zone Injection	(n-1-1) contingency of 400 kV Raipur-Bhadrawati D/C section

*Primary constraints

Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
SR	1st June 2013 to 15th June 2013	00-05 10-19	2000	0	2000	1112	888		Revised due to Non-commissioning Kudamkulam unit-1 and change in LTA quantum.
		05-10 19-24	2000		2000		888		
	13th June 2013	00-08 19-24	2000	0	2000	1112	888		Revised due to Emergency shutdown of Talcher-Kolar HVDC Pole-2.
		08-19'	1700		1700	1700	0		
	14th June 2013 to 15th June 2013	00-07 18-24	2000	0	2000	1112	888		Revised due to shutdown of 400 kV Rourkela-Talcher ckt-1/2
		07-18'	1600		1600		488		
	16th June 2013 to 19th June 2013	00-07 18-24	2000	0	2000	1612	388		Revised due to shutdown of 400 kV Rourkela-Talcher ckt-1/2
		07-18'	1600		1600		0		
	20th June 2013 to 24th June 2013	00-24	2000	0	2000	1612	388		
	25th June 2013	00-0830 19-24	2000	0	2000	1612	388		Revised due to shutdown of HVDC Bhadrawati Pole-2.
0830-19'		1500	1500		1500	0			
26th June 2013 to 30th June 2013	00-24	2000	0	2000	1612	388			

Δ. includes 1500 MW on the dedicated Mundra-Mohindergarh HVDC bipole of M/s Adani Power Limited which is scheduled separately from the generation at stage-III of APL Mundra (3*660 MW).

- 1. WR-NR Total Transfer capability will be reduced to 3100 MW in case of outage of any one of the following sections:**
- 765 kV Agra-Jhatikara
 - One of the 765/400 kV 1500 MVA ICT at Agra
 - 765 kV Gwalior-Agra one circuit
 - 765 kV Bina-Gwalior one circuit

Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR	1st June 2013 to 30th June 2013	00-17 23-24	3500	700	2800	286	2514		
		17-23	3600		2900		2614		
NER	1st June 2013 to 23rd June 2013	00-17 23-24	520	100	420	0	420		
		17-23	320		220		220		
	24th June 2013 to 30th June 2013	00-08 23-24	520	100	420	0	420		Revised due to shutdown of 400 kV Binaguri-Bongoigaon ckt-1/2
		08-17'	400		300		300		
		17-23	320		220		220		
WR									
SR	1st May 2013 to 31st May 2013	00-17 23-24	1700	0	1700	197	1503		
		17-23	1700		1700		1503		

Limiting Constraints

NR	Import	(n-1) contingency of 400 kV Farakka-Malda* (n-1) contingency of 765/400 kV ICT at Agra*
	Export	(n-1) contingency of 400 kV Allahabad-Pusauli
NER	Import	High Loading of 220 kV BTPS-Agia (n-1) contingency of 400 kV Balipara – Bongaigaon-I (n-1) contingency of 400 kV Farakka-Malda*
	Export	(n-1) contingency of 220 kV Samaguri – Saruajai I* (n-1) contingency of 400 kV Balipara-Bongaigaon-I
SR	Import	(n-1) contingency of 400 kV Rourkela-Talcher* Bhadrawati HVDC B/B link capacity.
	Export	Bhadrawati HVDC B/B link capacity.

*Primary constraints

ASSUMPTIONS IN BASECASE

Month: June 2013

S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
I	NORTHERN REGION				
1	Punjab	5637	5311	2111	2126
2	Haryana	5363	5014	3289	3289
3	Rajasthan	6574	5912	3466	3472
4	Delhi	4605	3932	1416	1416
5	Uttar Pradesh	10824	10831	6163	5976
6	Jammu & Kashmir	1825	1671	604	592
7	Uttarakhand	1476	1081	757	673
8	Himachal Pradesh	1043	943	590	493
9	Chandigarh	227	192	0	0
10	ISGS			16916	14627
	Total NR	37574	34888	35312	32663
II	EASTERN REGION				
1	West Bengal	6658	5280	4836	3678
2	Jharkhand	1035	715	483	541
3	Orissa	3597	2530	2451	1611
4	Bihar	1743	1430	101	101
5	Damodar Valley Corporation	2461	2310	2954	2954
6	Sikkim	45	45	0	0
7	Bhutan	112	112	275	260
8	ISGS			7384	5854
	Total ER	15651	12422	18484	14999
III	WESTERN REGION				
1	Chattisgarh	2977	2132	2518	1985
2	Madhya Pradesh	7112	4894	3601	2802
3	Maharashtra	15798	12916	13113	9454
4	Gujarat	10470	8369	10918	7764
5	Goa	327	198		
6	Daman and Diu	260	181		
7	Dadra and Nagar Haveli	612	479		
8	ISGS			13063	11996
	Total WR	37556	29169	43213	34001
IV	SOUTHERN REGION				
1	Andhra Pradesh	10283	9413	7290	6560
2	Tamil Nadu	10813	9100	6050	5408
3	Karnataka	8503	7453	4779	4233
4	Kerala	3254	2414	2007	794
5	Pondy	313	241		
6	Goa	84	84		
7	ISGS			10846	10049
	Total SR	33250	28705	30972	27044
V	NORTH-EASTERN REGION				
1	Manipur	110	203	0	0
2	Meghalaya	290	53	95	80
3	Mizoram	75	84	4	0
4	Nagaland	120	168	8	6
5	Assam	1320	880	190	180
6	Tripura	240	1537	85	85
7	Arunachal Pradesh	110	924	0	0
8	ISGS	0	0	1013	577
	Total NER	2265	3848	1395	928
	Total All India	126297	109032	129376	109635