National Load Despatch Centre Total Transfer Capability for June 2014

Issue Date: 01/04/2014 Issue Time: 1430 hrs Revision No. 2

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR-WR *	1st June 2014 to 30th June 2014	00-24	2500	500	2000	361	1639		
WR-NR ¹	1st June 2014 to 30th June 2014	00-17 23-24 17-23	4200 4200	500	3700 3700	3656	44		
		17-23	4200		3700				
NR-ER*	1st June 2014 to 30th June 2014	00-17 23-24 17-23	1000 1100	200	800 900	200	600 700		
ER-NR ^{\$}	1st June 2014 to 30th June 2014	00-17 23-24	3800	300	3500	2789	711		
		17-23					711		
W3-ER	1st June 2014 to 30th June 2014	00-24	1800	300	1500	0	1500		
ER-W3	1st June 2014 to 30th June 2014	00-24	1000	300	700	700	0		
WR-SR	1st June 2014 to 30th June 2014	00-24	1000	0	1000	1000	0		
SR-WR *	1st June 2014 to 30th June 2014	00-24	1000	0	1000	0	1000		
ER-SR	1st June 2014 to 30th June 2014	00-05 10-19 05-10	750	0	750	657	93		Margin revised due to grant of 150 MW LTA towards SR from NEW grid and
	1st June 2014 to	19-24 00-17	750 1100		750 1100		93		grant of 208 MW LTA to TANGEDCO
SR-ER *	30th June 2014	23-24 17-23	1100	0	1100	197	903		
ER-NER	1st June 2014 to 30th June 2014	00-17 23-24 17-23	550 550	50	500 500	230	270 270		
NER-ER	1st June 2014 to 30th June 2014	00-17 23-24	500	100	400	0	400		
	30 4174110 2 01 .	17-23	450		350		350		
S1-S2	1st June 2014 to 30th June 2014	00-24	6200	500	5700	5508	192		Margin revised due to grant of 208 MW LTA to TANGEDCO
Import of Punjab	1st June 2014 to 30th June 2014	00-24	5600	300	5300	3800	1500		
Import TTC for DD & DNH	1st June 2014 to 30th June 2014	00-24	980	0	980	LTA and MTO			
W3 zone Injection	1st June 2014 to 30th June 2014	00-17 23-24 17-23	9000 9500	200	8800 9300	6746	2054 2554		

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

\$ As per Simulations, predominant direction of flow is on West to North Corridor. Hence, in case injection point is in Western Region (W1,W2,W3), STOA/PX transactions from West to North on West-East-North corridor shall not be allowed as such transaction increases congestion in the West to North Corridor.

- 1) ER-SR TTC declared at Talcher Interconnector and Gazuwaka HVDC B/B seam
- 2) S1 comprises of AP and Karnataka: S2 comprises of Tamil Nadu, Kerala and Pondicherry
- 3) W3 $\,$ comprises of the following regional entities :
- a) Chattisgarh, b) Jindal Power Limited (JPL), c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak
- f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCL

[#] The figure is based on LTA/MTOA approved by CTU. In actual Operation, due to Units being on Maintenance/ Fuel shortage the LTA/MTOA utilized would be les. RLDC/ NLDC would factor this situation while issuing STOA approvals

National Load Despatch Centre Total Transfer Capability for June 2014

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1 WD ND Total Transfer conchility will be reduced to 2100 MW in case of outgo of one circuit of 765 kV Cwelier Agre									

Limiting Constraints

Corridor	Constraint
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.
WR-NR	High loading of 765 kV Agra-Gwalior (1000 MW SPS setting on each circuit of 765 kV Gwalior-Agra)
NR-ER	(n-1) contingency of 400 kV Allahabad-Pusauli
ER-NR	(n-1) contingency of one circuit of 400kV Farakka –Malda D/C
W3-ER	(n-1) contingency of 400kV Sterilte-Rourkela S/C
ER-W3	(n-1) contingency of 400kV Raigarh-Jharsuguda-Rourkela
WR-SR & ER-SR	Commissioning of 765kV Raichur-Sholapur S/C Based on the operational experience after the synchronization of SR grid with NEW grid and due to inadvertent variation of 765kV Raichur-Sholapur line flow, observation of Low Frequency Oscillations(LFO) Considering transfer capability assessment by CTU on NEW-SR corridor.
SR-WR	Bhadrawati HVDC B/B link capacity
SR-ER	(n-1) and (n-1-1) contingencies of 400kV Talcher-Rourkela D/C
ER-NER	(n-1) contingency of one circuit of 400 kV Balipara – Bongaigaon D/C
NER-ER	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa
S1-S2	(n-1) contingency of 400 kV Kolar-Hosur D/C line, 400kV Hosur-Salem S/C and 400kV Somanahalli-Salem S/C line.
Import of Punjab	(n-1) contingency of ICT at Patiala/Moga
W3 zone Injection	(n-1-1) contingency of 400 kV Raipur-Bhadrawati D/C section

^{*}Primary constraints

Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER									
NR ¹	1st June 2014 to	00-17 23-24	8000	800	7200	6445	755		
NK	30th June 2014	17-23	8000		7200		755		
NER	1st June 2014 to 30th June 2014	00-17 23-24	550	50	500	230	270		
	30th June 2014	17-23	550		500		270		
WR									
an	1st June 2014 to 30th June 2014	00-05 10-19	1750	0	1750	1.655	93		Margin revised due to grant of 150 MW LTA towards
SR		05-10 19-24	1750		1750	1657	93		SR from NEW grid and grant of 208 MW LTA to TANGEDCO

1. WR-NR Total Transfer capability will be reduced to 3100 MW in case of outage of one circuit of 765 kV Gwalior-Agra

Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR*	1st June 2014 to	00-17 23-24	3500	700	2800	561	2239		
	30th June 2014	17-23	3600		2900		2339		
NER	1st June 2014 to 30th June 2014	00-17 23-24	500	100	400	0	400		
		17-23	450		350		350		
WR									
VV IX									
SR*	1st June 2014 to	00-17 23-24	2100	0	2100	197	1903		
	30th June 2014	17-23	2100		2100		1903		

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Limiting Constraints

NR —	Import	(n-1) contingency of one circuit of 400kV Farakka –Malda D/C High loading of 765 kV Agra-Gwalior (1000 MW SPS setting on each circuit of 765 kV Gwalior-Agra)
	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak. (n-1) contingency of 400 kV Allahabad-Pusauli
NER	Import	(n-1) contingency of one circuit of 400 kV Balipara – Bongaigaon D/C
NEK	Export	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa
SR	Import	1. Commissioning of 765kV Raichur-Sholapur S/C 2. Based on the operational experience after the synchronization of SR grid with NEW grid and due to inadvertent variation of 765kV Raichur-Sholapur line flow, observation of Low Frequency Oscillations(LFO).
	Export	3. Considering transfer capability asessment by CTU on NEW-SR corridor. (n-1) and (n-1-1) contingencies of 400kV Talcher-Rourkela D/C

^{*}Primary constraints

National Load Despatch Centre Total Transfer Capability for June 2014

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor Affected
			Margin revised due to withdrawal/cancellation of 150 MW MTOA from Corporate Power Limited	ER-SR
1	25.03.2014	1	Re-Routing of transactions on West-East-North Corridor discontinued on account of Inter-Regional Loop flows leading to physical congestion on WR-NR.	WR-NR/ ER-NR
			Margin Revised due to correction in LTA/MTOA figure.	NR-WR
2	01/04/2014	2	Margin revised due to grant of 150 MW LTA towards SR from NEW grid and grant of 208 MW LTA to TANGEDCO	ER-SR / S1-S2

ASSUMPTIONS IN BASECASE

Month: June '14

				Month Sune 14			
		Loa	ad	Generation			
S.No.	Name of State/Area	Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)		
ı	NORTHERN REGION						
1	Punjab	8807	8517	3164	3203		
2	Haryana	6743	6353	3958	3958		
3	Rajasthan	7803	7383	5144	5134		
4	Delhi	5199	5053	1382	1382		
5	Uttar Pradesh	12165	12581	6115	6128		
6	Jammu & Kashmir	1954	1798	546	564		
7	Uttarakhand	1656	1509	496	491		
8	Himachal Pradesh	1503	1361	852	821		
9	Chandigarh	294	225	0	0		
10	ISGS/IPPs			19790	17328		
	Total NR	46124	44780	41447	39009		
II	EASTERN REGION						
1	West Bengal	7059	4711	5170	4021		
2	Jharkhand	1108	808	590	590		
3	Orissa	3640	2570	3181	2432		
4	Bihar	2030	1500	70.5	70.5		
5	Damodar Valley Corporation	2460	2030	3179	2989		
6	Sikkim	86	40				
7	Bhutan	109	109	1235	1235		
8	ISGS/IPPs	245	245	8845	8315		
	Total ER	16737	12013	22270.5	19652.5		
III	WESTERN REGION						
1	Chattisgarh						
2	Madhya Pradesh						
3	Maharashtra						
4	Gujarat						
5	Goa						
6	Daman and Diu						
7	Dadra and Nagar Haveli				-		
8	ISGS/IPPs						
	Total WR	0	0	0	0		

IV	SOUTHERN REGION				
1	Andhra Pradesh	10848	9446	6571	5881
2	Tamil Nadu	12152	10588	8026	7002
3	Karnataka	8397	7303	6100	4619
4	Kerala	3390	2595	1781	863
5	Pondy	329	278		
6	Goa	83	83		
7	ISGS/IPPs			11027	10260
	Total SR	35199	30293	33505	28625
V	NORTH-EASTERN REGION				
1	Arunachal Pradesh	120	84	0	0
2	Assam	1380	990	250	225
3	Manipur	125	88	0	0
4	Meghalaya	300	210	60	55
5	Mizoram	75	53	4	4
6	Nagaland	110	77	12	12
7	Tripura	230	130	110	110
8	ISGS/IPPs			1592	1262
	Total NER	2340	1632	2028	1668
	Total All India	400400	00740	00050	22255
	Total All India	100400	88718	99250	88955