Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR-WR*	1st June 2014 to 30th June 2014	00-24	2500	500	2000	297	1703		
	1st June 2014 to 07th June 2014	00-17 23-24	4700	500	4200	4380	0		
	08th June 2014	17-23 00-17 23-24 17-23	4700 3950 3950	500	4200 3450 3450	4380	0 0		
WR-NR	09th June 2014	00-17 23-24 17-23	3950 3950 3950	500	3450 3450	4380	0		
	10th June 2014 to 30th June 2014	00-17 23-24 17-23	4700 4700	500	4200 4200	4380	0		
						I.			
		00-06	1000		800	293	507		
	1st June 2014 to	06-17'			800	423	377		
NR-ER*	30th June 2014	17-18'	1100	200	900	423	477		
		18-23			900	293	607		
		23-24	1000		800	293	507		
	1st June 2014 to 6th June 2014	00-17 23-24 17-23	4000	300	3700	2431	1269 1269		
	7th June 2014	00-07'	4000	300	3700	2431	1269		
	7th June 2014	07-24'	2300	300	2000	2431	0		
	8th June 2014 to 11th June 2014	00-24'	2300	300	2000	2431	0		
	12th June 2014	00-07' 07-24'	2300 2300	300	2000 2000	2431	0		
	13th June 2014	00-07'	2300	300	2000	2431	0		
		07-24'	2300		2000		0		
	14th June 2014	00-07'	4000	300	3700	2431	0		
	15th June 2014 to	07-24' 00-17 23-24	2300 4000	300	2000 3700	2431	0 1269		
ER-NR ^{\$}	16th June 2014	17-23					1269		
	17th June 2014	00-07' 07'-24	4000 2300	300	3700 2000	2431	1269 0		
	18th June 2014	00-17 23-24 17-23	4000	300	3700	2431	1269 1269		
	10.1 7 20.1	00-07'	4000	200	3700	2424	1269		
	19th June 2014	07'-24	2300	300	2000	2431	0		
	20th June 2014 to 21st June 2014	00-17 23-24	4000	300	3700	2431	1269		
		17-23 00-08	4000		3700		1269 1269		
	22nd June 2014	08-17'	3600	300	3300	2431	869		
		17-24	3600		3300		869		
	23th June 2014 to 30th June 2014	00-17 23-24	4000	300	3700	2431	1269		
		17-23					1269		

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
	1st June 2014 to 09th June 2014	00-24	1800	300	1500	551	949		
W3-ER ^{\$}	10th June 2014 to 11th June 2014	00-24	1500	300	1200	551	649		
	12th June 2014 to 30th June 2014	00-24	1500	300	1200	551	649		
ER-W3	1st June 2014 to 30th June 2014	00-24	1000	300	700	874	0		
	1st June 2014 to 20th June 2014	00-24	1000	0	1000	1000	0		
WR-SR	21st June 2014 to 23rd June 2014	00-24	1000	0	1000	850	150		
WK-SK	24th June 2014 to 27th June 2014	00-24	1000	0	1000	850	150		
	28th June 2014 to 30th June 2014	00-24	1000	0	1000	1000	0		
SR-WR *	1st June 2014 to 30th June 2014	00-24	1000	0	1000	0	1000		
	1st June 2014 to	00-06	2550		2650	2158	492		
	2nd June 2014	18-24 06-18'	2650	0	2650	2203	447		
		00-18	2650		2650	2158	447		
	3rd June 2014	07-18'	2350	0	2350	2203	147		
		18-24'	2350		2350	2158	192		
	4th June 2014 to 6th June 2014	00-06 18-24	2650	0	2650	2158	492		
		06-18'	2650		2.550	2203	447		
	7th June 2014	00-05	2650	0	2650	2158	492		
	/III June 2014	05-06'	2350 2350	U	2350 2350	2158 2203	192 147		
		00-24	2330		2550	2203	147		
	8th June 2014 to 9th June 2014	18-24 06-18'	2650	0	2650	2158	492 447		
	10th June 2014 to 15th June 2014	00-06 18-24	2650	0	2650	1717	933		
	15th Julie 2014	06-18'				1762	888		
		00-06	2650		2650	1717	933		
ED CD	16th June 2014	06-07'		0		1762	888		
ER-SR		07'-18 18'-24'	2350		2350	1762 1717	588 633		
	17th June 2014	00-06 18-24	2650	0	2650	1717	933		
		06-18'				1762	888		
		00-06	2650		2650	1717	933		
	18th June 2014	06-07'	2030	0	2030	1762	888		
	10th 3th 2014	07'-18	2500	3	2500	1762	738		
		18'-24'				1717	783		
	19th June 2014 to 20th June 2014	00-06 18-24 06-18'	2650	0	2650 2650	1717 1762	933 888		
		00-18			2030				
	21st June 2014	18-24	2500	0	2500	1467	1033		
	22md Iver 2014	06-18'	2500	0	2500	1512 1467	988		
	22nd June 2014	18-24 06-18'	2500	0	2500		988		
		00-06				1512 1467	1033		
	23rd June 2014	18-24	2500	0	2500				
		06-18'				1512	988		

Issue Date: 27/06/2014 Issue Time: 0820 hrs Revision No. 29

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
	24th June 2014	00-06	2500	0	2500	1467	1033		
	24th June 2014	18-24 06-18'	2300	U	2300	1512	988		
	25th June 2014 to	00-06	2500		2500	1467	1033		
ER-SR	27th June 2014	18-24 06-18'	2500	0	2500	1512	988		
	28th June 2014 to	00-06				1717	933		
	30th June 2014	18-24 06-18'	2650	0	2650	1762	888		
	1st June 2014 to	00-17	1100		1100		903		
SR-ER *	30th June 2014	23-24 17-23	1100	0	1100	197	903		
						205			
	1-4 1 2014 4	00-06 06-17'	645 645		595 595	205 210	390 385		
ER-NER	1st June 2014 to 30th June 2014	17-18	580	50	530	210	320		
		18-23 23-24	580 645		530 595	205 205	325 390		
	1st June 2014 to	00-17	500		400		400		
NER-ER	30th June 2014	23-24 17-23	450	100	350	0	350		
		17-23	430		330		330		
	1st June 2014 to 9th June 2014	00-24	2640	295	2345	2139	206		
	10th June 2014 to	00-24	2640	295	2345	1905	440		
	13th June 2014 14th June 2014 to						***		
	15th June 2014	00-24	2640	295	2345	2106	239		
	16th June 2014 17th June 2014	00-24 00-24	2920 2640	295 295	2625 2345	2215 2106	410 239		
	18th June 2014	00-24	2640	295	2345	2106	239		
	18th Julie 2014	17-24	2920	295	2625	2215	410		
	19th June 2014	00-19 19-24	2920 2920	295 295	2625 2625	2215 2215	410 410		
S1-S2	20th June 2014 to 22nd June 2014	00-24	2640	295	2345	2106	239		
	23rd June 2014	00-11	2640 2920	295	2345	2106	239 410		
	24th June 2014 to	11-24'		205	2625	2215			
	25th June 2014	00-24	2920	295	2625	2215	410		
	26th June 2014	00-24	2920	295	2625	2135	490		
	27th June 2014	00-0830	2920	295	2625	2135	490		
		0830-24	2640	295	2345	2026	319	-280	Revised due to revival of Vallur Unit 1.
	28th June 2014 to 30th June 2014	00-24	2640	295	2345	2026	319	-280	
Import of Punjab	1st June 2014 to 30th June 2014	00-24	5700	300	5400	3790	1610		
Import TTC for DD & DNH	1st June 2014 to 30th June 2014	00-24	980	0	980	LTA and MTO			
	1st June 2014 to	00-17	9400	200	9200	7050	2150		
	15th June 2014	23-24 17-23	9900	200	9700	7030	2650		
	16th June 2014	00-17 23-24	8900	200	8700	7050	1650		
	10th Julie 2014	17-23	9400	200	9200	7030	2150		
W3 zone		00-07'	9400		9200		2150		
Injection	17th June 2014	07'-17	8900	200	8700	7050	1650		
		17-23	9400		9200		2150		
		23-24 00-17	8900		8700		1650		
	18th June 2014 to 30th June 2014	23-24	9400	200	9200	7050	2150		
	John Julie 2014	17-23	9900		9700		2650		

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
----------	------	-------------------------	------------------------------------------	-----------------------	----------------------------------------------	----------------------------------------------------------------------	----------------------------------------------------------------	-------------------------------------------------	----------

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

- 1) ER-SR TTC declared at Talcher Interconnector and Gazuwaka HVDC B/B seam
- 2) S1 comprises of AP and Karnataka: S2 comprises of Tamil Nadu, Kerala and Pondicherry
- 3) W3 $\,$ comprises of the following regional entities :
- a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak
- f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCL, n)Vandana Vidyut

The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/Fuel shortage/New units being commissionned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis.

In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown:

- 1) The TTC value will be revised to normal values after restoration of shutdown.
- 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

Limiting Constraints

wr-Nr and Loop flows on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda (power flowing from WR to NI 765kV Gwalior-Agra D/C and from NR to WR on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda NR-ER (n-1) contingency of 400 kV Allahabad-Pusauli ER-NR (n-1) contingency of 400kV Farakka –Malda D/C W3-ER (n-1) contingency of 400kV Sterlite-Rourkela S/C ER-W3 (n-1) contingency of 400kV Raigarh-Jharsuguda-Rourkela 1. Commissioning of 765kV Raichur-Sholapur S/C 2. Based on the operational experience after the synchronization of SR grid with NEW grid and due to inadve variation of 765kV Raichur-Sholapur line flow, observation of Low Frequency Oscillations(LFO) 3. ER-SR TTC has been declared assuming more than 1100 MW generation at Talcher Stage-2. In ca Talcher Stage-2 generation goes below 1100 MW, then the ER-SR TTC would be revised downward constraints within ER would emerge. SR-WR Bhadrawati HVDC B/B link capacity SR-ER (n-1) and (n-1-1) contingencies of 400kV Talcher-Rourkela D/C (n-1) contingency of 400 kV Balipara – Bongaigaon D/C leading to thermal loading of 220kV BTPS-S/C NER-ER (n-1) contingency of 400 kV Kolar-Hosur D/C Import of Punjab W3 zone (n-1) contingency of 400 kV Raipur-Bhadrawati D/C section and High loading of 400kV Raipur-W	Corridor	Constraint
wr.nr and Loop flows on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda (power flowing from WR to NI 765kV Gwalior-Agra D/C and from NR to WR on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda NR-ER (n-1) contingency of 400 kV Allahabad-Pusauli ER-NR (n-1) contingency of 400kV Farakka –Malda D/C W3-ER (n-1) contingency of 400kV Sterlite-Rourkela S/C ER-W3 (n-1) contingency of 400kV Raigarh-Jharsuguda-Rourkela 1. Commissioning of 765kV Raichur-Sholapur S/C 2. Based on the operational experience after the synchronization of SR grid with NEW grid and due to inadve variation of 765kV Raichur-Sholapur line flow, observation of Low Frequency Oscillations(LFO) 3. ER-SR TTC has been declared assuming more than 1100 MW generation at Talcher Stage-2. In ca Talcher Stage-2 generation goes below 1100 MW, then the ER-SR TTC would be revised downward constraints within ER would emerge. SR-WR Bhadrawati HVDC B/B link capacity SR-ER (n-1) and (n-1-1) contingencies of 400kV Talcher-Rourkela D/C (n-1) contingency of 400 kV Balipara – Bongaigaon D/C leading to thermal loading of 220kV BTPS-S/C NER-ER (n-1) contingency of 400 kV Balipara – Bongaigaon D/C leading to thermal loading of 220kV BTPS-S/C Import of Punjab W3 zone (n-1-1) contingency of 400 kV Raipur-Bhadrawati D/C section and High loading of 400kV Raipur-W	NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.
ER-NR (n-1) contingency of 400kV Farakka –Malda D/C W3-ER (n-1) contingency of 400kV Sterlite-Rourkela S/C ER-W3 (n-1) contingency of 400kV Raigarh-Jharsuguda-Rourkela 1. Commissioning of 765kV Raichur-Sholapur S/C 2. Based on the operational experience after the synchronization of SR grid with NEW grid and due to inadve variation of 765kV Raichur-Sholapur line flow, observation of Low Frequency Oscillations(LFO) 3. ER-SR TTC has been declared assuming more than 1100 MW generation at Talcher Stage-2. In ca Talcher Stage-2 generation goes below 1100 MW, then the ER-SR TTC would be revised downward constraints within ER would emerge. SR-WR Bhadrawati HVDC B/B link capacity SR-ER (n-1) and (n-1-1) contingencies of 400kV Talcher-Rourkela D/C (n-1) contingency of 400 kV Balipara – Bongaigaon D/C leading to thermal loading of 220kV BTPS-S/C NER-ER (n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa S1-S2 (n-1) contingency of 400 kV Kolar-Hosur D/C Import of Punjab W3 zone (n-1-1) contingency of 400 kV Raipur-Bhadrawati D/C section and High loading of 400kV Raipur-W	WR-NR	High loading of 765 kV Agra-Gwalior (1250 MW SPS setting on each circuit of 765 kV Gwalior-Agra) and Loop flows on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda (power flowing from WR to NR on 765kV Gwalior-Agra D/C and from NR to WR on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda).
W3-ER (n-1) contingency of 400kV Sterlite-Rourkela S/C ER-W3 (n-1) contingency of 400kV Raigarh-Jharsuguda-Rourkela 1. Commissioning of 765kV Raichur-Sholapur S/C 2. Based on the operational experience after the synchronization of SR grid with NEW grid and due to inadve variation of 765kV Raichur-Sholapur line flow, observation of Low Frequency Oscillations(LFO) 3. ER-SR TTC has been declared assuming more than 1100 MW generation at Talcher Stage-2. In ca Talcher Stage-2 generation goes below 1100 MW, then the ER-SR TTC would be revised downward constraints within ER would emerge. SR-WR Bhadrawati HVDC B/B link capacity SR-ER (n-1) and (n-1-1) contingencies of 400kV Talcher-Rourkela D/C (n-1) contingency of 400 kV Balipara – Bongaigaon D/C leading to thermal loading of 220kV BTPS-S/C NER-ER (n-1) contingency of 400 kV Kolar-Hosur D/C Import of Punjab W3 zone (n-1-1) contingency of 400 kV Raipur-Bhadrawati D/C section and High loading of 400kV Raipur-W	NR-ER	(n-1) contingency of 400 kV Allahabad-Pusauli
ER-W3 (n-1) contingency of 400kV Raigarh-Jharsuguda-Rourkela 1. Commissioning of 765kV Raichur-Sholapur S/C 2. Based on the operational experience after the synchronization of SR grid with NEW grid and due to inadve variation of 765kV Raichur-Sholapur line flow, observation of Low Frequency Oscillations(LFO) 3. ER-SR TTC has been declared assuming more than 1100 MW generation at Talcher Stage-2. In ca Talcher Stage-2 generation goes below 1100 MW, then the ER-SR TTC would be revised downward constraints within ER would emerge. SR-WR Bhadrawati HVDC B/B link capacity SR-ER (n-1) and (n-1-1) contingencies of 400kV Talcher-Rourkela D/C (n-1) contingency of 400 kV Balipara – Bongaigaon D/C leading to thermal loading of 220kV BTPS-S/C NER-ER (n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa S1-S2 (n-1) contingency of 400 kV Kolar-Hosur D/C Import of Punjab W3 zone (n-1-1) contingency of 400 kV Raipur-Bhadrawati D/C section and High loading of 400kV Raipur-W	ER-NR	(n-1) contingency of 400kV Farakka –Malda D/C
WR-SR & ER-SR ER-SR SR-WR Bhadrawati HVDC B/B link capacity SR-ER-NER ER-NER NER-ER (n-1) contingency of 400 kV Balipara – Bongaigaon D/C leading to thermal loading of 220kV BTPS-S/C NER-ER NER-ER (n-1) contingency of 400 kV Kolar-Hosur D/C Import of Punjab W3 zone 1. Commissioning of 765kV Raichur-Sholapur Isine flow, observation of Low Frequency Oscillations(LFO) SR-grid with NEW grid and due to inadve variation of 58R grid with NEW grid and due to inadve variation of 765kV Raichur-Sholapur Isine flow, observation of Low Frequency Oscillations(LFO) SER-SR TTC has been declared assuming more than 1100 MW generation at Talcher Stage-2. In ca Talcher Stage-2 generation goes below 1100 MW, then the ER-SR TTC would be revised downward constraints within ER would emerge. SR-WR Bhadrawati HVDC B/B link capacity (n-1) and (n-1-1) contingencies of 400kV Talcher-Rourkela D/C (n-1) contingency of 400 kV Balipara – Bongaigaon D/C leading to thermal loading of 220kV BTPS-S/C (n-1) contingency of 400 kV Kolar-Hosur D/C Import of Punjab W3 zone (n-1) contingency of 400 kV Raipur-Bhadrawati D/C section and High loading of 400kV Raipur-W	W3-ER	(n-1) contingency of 400kV Sterlite-Rourkela S/C
2. Based on the operational experience after the synchronization of SR grid with NEW grid and due to inadve variation of 765kV Raichur-Sholapur line flow, observation of Low Frequency Oscillations(LFO) 3. ER-SR TTC has been declared assuming more than 1100 MW generation at Talcher Stage-2. In ca Talcher Stage-2 generation goes below 1100 MW, then the ER-SR TTC would be revised downward constraints within ER would emerge. SR-WR Bhadrawati HVDC B/B link capacity SR-ER (n-1) and (n-1-1) contingencies of 400kV Talcher-Rourkela D/C (n-1) contingency of 400 kV Balipara – Bongaigaon D/C leading to thermal loading of 220kV BTPS-S/C NER-ER NER-ER (n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa S1-S2 Import of Punjab W3 zone (n-1) contingency of 400 kV Raipur-Bhadrawati D/C section and High loading of 400kV Raipur-W	ER-W3	(n-1) contingency of 400kV Raigarh-Jharsuguda-Rourkela
SR-ER (n-1) and (n-1-1) contingencies of 400kV Talcher-Rourkela D/C (n-1) contingency of 400 kV Balipara – Bongaigaon D/C leading to thermal loading of 220kV BTPS S/C NER-ER (n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa S1-S2 (n-1) contingency of 400 kV Kolar-Hosur D/C Import of Punjab (n-1) contingency of ICT at Dhuri and (n-1) contingency of 220kV Moga(PG)-Moga(PSTCL) W3 zone (n-1-1) contingency of 400 kV Raipur-Bhadrawati D/C section and High loading of 400kV Raipur-W		2. Based on the operational experience after the synchronization of SR grid with NEW grid and due to inadvertent variation of 765kV Raichur-Sholapur line flow, observation of Low Frequency Oscillations(LFO) 3. ER-SR TTC has been declared assuming more than 1100 MW generation at Talcher Stage-2. In case Talcher Stage-2 generation goes below 1100 MW, then the ER-SR TTC would be revised downward as
(n-1) contingency of 400 kV Balipara – Bongaigaon D/C leading to thermal loading of 220kV BTPS-S/C	SR-WR	Bhadrawati HVDC B/B link capacity
NER-ER S/C	SR-ER	(n-1) and (n-1-1) contingencies of 400kV Talcher-Rourkela D/C
S1-S2 (n-1) contingency of 400 kV Kolar-Hosur D/C Import of Punjab (n-1) contingency of ICT at Dhuri and (n-1) contingency of 220kV Moga(PG)-Moga(PSTCL) W3 zone (n-1-1) contingency of 400 kV Raipur-Bhadrawati D/C section and High loading of 400kV Raipur-W	ER-NER	(n-1) contingency of 400 kV Balipara – Bongaigaon D/C leading to thermal loading of 220kV BTPS-Agia S/C
Import of Punjab (n-1) contingency of ICT at Dhuri and (n-1) contingnecy of 220kV Moga(PG)-Moga(PSTCL) W3 zone (n-1-1) contingency of 400 kV Raipur-Bhadrawati D/C section and High loading of 400kV Raipur-W	NER-ER	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa
Punjab (n-1) contingency of ICT at Dhuri and (n-1) contingnecy of 220kV Moga(PG)-Moga(PSTCL) W3 zone (n-1-1) contingency of 400 kV Raipur-Bhadrawati D/C section and High loading of 400kV Raipur-W	2 - 2 -	(n-1) contingency of 400 kV Kolar-Hosur D/C
(ii 1 1) contingency of 100 it. Tampar Billian and 11gh 10 and 1 fight 10 and 1 f	Punjab	(n-1) contingency of ICT at Dhuri and (n-1) contingnecy of 220kV Moga(PG)-Moga(PSTCL)
(600 M W 5F 5 Setting on each circuit of 400k V Raipur-Wardina)	W3 zone Injection	(n-1-1) contingency of 400 kV Raipur-Bhadrawati D/C section and High loading of 400kV Raipur-Wardha (800 MW SPS setting on each circuit of 400kV Raipur-Wardha)

^{*}Primary constraints

^{\$} As per Simulations, predominant direction of flow is on West to North Corridor. Hence, in case injection point is in Western Region (W1,W2,W3), STOA/PX transactions from West to North on West-East-North corridor shall not be allowed as such transaction increases congestion in the West to North Corridor.

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER									
	1st June 2014 to	00-17 23-24	8700	800	7900	6811	1089		
	6th June 2014	17-23	8700		7900		1089		
		00-07	9700		7900		1089		
	7th June 2014	00-07	8700	800	7900	6811	1009		
		07-24'	7000		6200		0		
	8th June 2014	00-24'	6250	800	5450	6811	0		
	9th June 2014	00-24'	6250	800	5450	6811	0		
	10th June 2014 to 11th June 2014	00-24'	7000	800	6200	6811	0		
	12th June 2014	00-07'	7000	800	6200	6811	0		
		07-24'	7000		6200		0		
	13th June 2014	00-07'	7000	800	6200	6811	0		
		07-24'	7000		6200		0		
NR	14th June 2014	00-07'	8700	800	7900	6811	1089		
		07-24'	7000		6200		0		
	15th June 2014 to 16th June 2014	00-17 23-24	8700	800	7900	6811	1089		
	100111001100 2011	17-23	8700	•	7900		1089		
	17th June 2014	00-07'	8700	800	7900	6811	1089		
		07-24'	7000		6200		0		
	18th June 2014	00-17 23-24	8700	800	7900	6811	1089		
		17-23	8700		7900		1089		
	19th June 2014	00-07'	8700	800	7900	6811	1089		
		07-24'	7000		6200		0		
	20th June 2014 to 21st June 2014	00-17 23-24 17-23	8700	800	7900	6811	1089		
		00-08	8700 8700		7900 8400		1089 1589		
	22nd June 2014	08-17'	8300	300	8000	6811	1189		
		17-24	8300		8000		1189		
	23rd June 2014 to 30th June 2014	00-17 23-24	8700	800	7900	6811	1089		
		17-23 00-06	8700 645		7900 595	205	1089 390		
	1st June 2014 to	06-17'	645		595	210	385		
NER	30th June 2014 to	17-18	580	50	530	210	320		
		18-23 23-24	580 645		530 595	205 205	325 390		
TUTO		25-24	0+3		575	203	370		
WR									-

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
	1st June 2014 to	00-06	3650		3650	3158	492		
	2nd June 2014	18-24 06-18'	3650	0	3650	3203	447		
		00-07	3650		3650	3158	492		
	2.11 2014	07-18'	3350	0	3350	3203	147		
	3rd June 2014	18-24'	3350	0	3350	3158	192		
	4th June 2014 to 6th June 2014	00-06 18-24	3650	0	3650	3158	492		
	our sunc 2014	06-18'				3203	447		
		00-05	3650		3650	3158	492		
	7th June 2014	05-06'	3350	0	3350	3158	192		
		06-24'	3350		3350	3203	147		
	8th June 2014 to 9th June 2014	00-06 18-24	3650	0	3650	3158	492		
	9th Julie 2014	06-18'				3203	447		
	10th June 2014 to 15th June 2014	00-06 18-24	3650	0	3650	2717	933		
	13th June 2014	06-18'				2762	888		
		00-06	3650		3650	2717	933		
	16th June 2014	06-07' 07'-18		0		2762 2762	588 588		
	10th 3th 2014	18'-24'	3350		3350	2717	633		
	17th June 2014	00-06 18-24	3650	0	3650	2717	933		
SR		06-18' 00-06				2762	888		
		06-07'	3650		3650	2717 2762	933 888		
	18th June 2014	07'-18		0		2762	738		
		18'-24'	3500		3500	2717	783		
	19th June 2014 to 20th June 2014	00-06 18-24	3650	0	3650	2717	933		
	2011 Julie 2014	06-18'				2762	888		
	21st June 2014	00-06 18-24	3500	0	3500	2317	1183		
		06-18'				2362	1138		
	22nd June 2014	00-06 18-24	3500	0	3500	2317	1183		
		06-18'				2362	1138		
	23rd June 2014	00-06 18-24	3500	0	3500	2317	1183		
		06-18'				2362	1138		
		00-06 18-24	2500		2500	2317	1183		
	24th June 2014	06-18'	3500	0	3500	2762	738		
	25th June 2014 to	00-06 18-24	3500	0	3500	2317	1183		
	27th June 2014	06-18'				2362	1138		
	28th June 2014 to 30th June 2014	00-06 18-24	3650	0	3650	2717	933		
	50th Julie 2014	06-18'				2762	888		

Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
		00-06	3500		2800	590	2210		
	1st June 2014 to	06-17'	3500		2800	720	2080		
NR*	30th June 2014	17-18	3600	700	2900	720	2180		
	30th June 2014	18-23	3600		2900	590	2310		
		23-24	3500		2800	590	2210		
NER	1st June 2014 to 30th June 2014	00-17 23-24	500	100	400	0	400		
	30th June 2014	17-23	450		350		350		
WR									
WK									
SR*	1st June 2014 to 30th June 2014	00-17 23-24	2100	0	2100	197	1903		
	30th Julie 2014	17-23	2100		2100		1903		

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Limiting Constraints

NR	Import	(n-1) contingency of one circuit of 400kV Farakka –Malda D/C High loading of 765 kV Agra-Gwalior (1250 MW SPS setting on each circuit of 765 kV Gwalior-Agra) and high loop flows on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda (power flowing from WR to NR on 765kV Gwalior-Agra D/C and from NR to WR on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda).
	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak. (n-1) contingency of 400 kV Allahabad-Pusauli
NER	Import	(n-1) contingency of 400 kV Balipara – Bongaigaon D/C leading to thermal loading of 220kV BTPS-Agia S/C
	Export	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa
SR	Import	 Commissioning of 765kV Raichur-Sholapur S/C Based on the operational experience after the synchronization of SR grid with NEW grid and due to inadvertent variation of 765kV Raichur-Sholapur line flow, observation of Low Frequency Oscillations(LFO). ER-SR TTC has been declared assuming more than 1100 MW generation at Talcher Stage-2. In case Talcher Stage-2 generation goes below 1100 MW, then the ER-SR TTC would be revised downward as constraints within ER would emerge.
	Export	(n-1) and (n-1-1) contingencies of 400kV Talcher-Rourkela D/C

^{*}Primary constraints

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor Affected
			Margin revised due to withdrawal/cancellation of 150 MW MTOA from Corporate Power Limited	ER-SR
1	25.03.2014	Whole Month	Re-Routing of transactions on West-East-North Corridor discontinued on account of Inter-Regional Loop flows leading to physical congestion on WR-NR.	WR-NR/ ER-NR
			Margin Revised due to correction in LTA/MTOA figure.	NR-WR
2	04-01-2014	Whole Month	Margin revised due to grant of 150 MW LTA towards SR from NEW grid and grant of 208 MW LTA to TANGEDCO	ER-SR / S1-S2
3	04-04-2014	Whole Month	Margin revised due to grant of 69 MW LTA to Jindal	W3/
			Power Limited Tamnar Margin revised due to correction of LTA. 69 MW LTA	ER-SR
4	04-11-2014	Whole Month	Quantum inadvertently added in the last revision. Quantum inadvertently added in the last revision	ER-SR
			Margin revised due to incorporation of existing Power Allocation.	NR-WR
			Margin revised due to Commissioning of Sasan Unit-4.	WR-NR
			Margin revised due to incorporation of existing Solar Power Allocation to SR, ER, NER constituents between 6 hrs -18 hrs in LTA figures and allocation data avialable on RPCs RTA/REA.	NR-ER
			Margin revised considering the LTA/MTOA allocation avialable in RPCs RTA/REA.	ER-NR/ ER- W3
5	05-01-2014	Whole Month	Margin revised due to incorporation of existing LTA/MTOA allocation avialable in RPCs RTA/REA and Re-routing of existing MTOA granted by CTU.	W3-ER
	03-01-2014	whole Worth	Margin revised due to incorporation of existing Solar Power Allocation to Karnataka between 6 hrs-18 hrs in LTA figures.	ER-SR
			Margin revised considering the LTA/MTOA allocation avialable in RPCs RTA/REA and due to incorporation of existing Solar Power Allocation to Assam.	ER-NER
			Revised due to Allocation of 150 MW TANGEDCO.	S1-S2
			Margin revised due to incorporation of existing LTA/MTOA allocation avialable in RPCs RTA/REA and existing MTOA granted by CTU.	W3 zone Injection
			Revised due to augmentation/ modifications in Punjab control area network.	Import of Punjab
6	23/5/2014	Whole Month	Refer to explanatory notes regarding the change in TTC representation given in the last page.	ER-SR/ S1-S2
			Revised due to change in Load Generation Balance and Commissioning of Sasan Unit-1.	WR-NR
7	31/5/2014	Whole Month	Revised due to change in Load Generation Balance	ER-NR/ ER- NER
			Revised due to change in Load Generation Balance.	W3 zone Injection

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor Affected
8	02-06-2014	03-06-2014	Revised due to shutdown of 400 kV Meramundali-Angul.	ER-SR
		07-06-2014	Revised due to shutdown of 400 kV GMR-Meramundali and 400 kV Talcher-Meramundali	ER-SR
9	06-06-2014	07-06-2014 to 11-06-2014	Revised due to shutdown of 400 kV Kahalgaon - Barh ckt 2	ER-NR
		12-06-2014	Revised due to shutdown of 400 kV Kahalgaon - Barh ckt 1	
10	07-06-2014	08-06-2014	Revised due to forced outage of HVDC Mundra- Mohindergarh Pole 2	WR-NR
11	08-06-2014	09-06-2014	Revised due to forced outage of HVDC Mundra- Mohindergarh Pole 2	WR-NR
12	09-06-2014	10/06/2014- 11/06/2014	Revised due to forced outage of 400 kV Raigarh-SEL-Rourkela Ckt 1	W3-ER
13	10-06-2014	10/06/2014- 30/06/2014	Revised due to outage of Talcher Stage 2 Unit 6	ER-SR / S1-S2
		12-06-2014	Revised due to extended shutdown of 400 kV Kahalgaon - Barh ckt 2	ER - NR
14	11-06-2014	13-06-2014	Revised due to shutdown of 400 kV Kahalgaon - Barh ckt 1	LIX - IVIX
		12/06/2014- 30/06/2014	Revised due to forced outage of 400 kV Raigarh-SEL-Rourkela Ckt 1	W3-ER
15	13-06-2014		Revised due to extended shutdown of 400 kV Kahalgaon - Barh ckt 2	ER-NR
13	12-00-2014	14-06-2014	Revised due to shutdown of 400 kV Kahalgaon - Barh ckt 1	LIV-IVIV
16	15-06-2014	16-06-2014	Revised due to shutdown of 400kV Bolangir - Angul	ER - SR
		16-06-2014	Revised due to shutdown of 400kV Raipur-Bhadrawati ckt 2	W3 zone
17	16-06-2014	17-06-2014	Revised due to shutdown of 400kV Raipur-Bhadrawati ckt 3	Injection
		17 00 2014	Revised due to shutdown of 400 kV Kahalgaon - Barh ckt 1	ER-NR
18	16-06-2014	17/06/2014- 30/06/2014	Revised due to deferment of Vallur Unit 1 planned shutdown	S1-S2
19	17-06-2014	18-06-2014	Revised due to shutdown of 400 kV Jeypore-Gazuwaka ckt 2 and HVDC Gazuwaka Block 2	ER-SR
20	18-06-2014	18/06/2014- 19/06/2014	Revised due to forced outage of Vallur Unit 1	S1-S2
20	18-00-2014	19-06-2014	Revised due shutdown of 400 kV Kahalgaon - Barh ckt 1	ER - NR
21	19-06-2014	19-06-2014	Revised due to extension of outage of Vallur unit 1	S1-S2
22	20-06-2014	20/06/2014 - 23/06/2014	Margin revised due to Outage of KSK Mahandi Unit	ER-SR/ WR- SR
23	21-06-2014	22-06-2014	Revised due to shutdown of 400KV Maithon-Koderma D/C	ER-NR
24	21-06-2014	22-06-2014	Revised due to non availability of HVDC Gazuwaka Block 1	ER-SR
25	22-06-2014	23-06-2014	Revised due to non availability of HVDC Gazuwaka Block 1	ER-SR

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor Affected
		24/06/2014 - 30/06/2014	Revised due to tripping Vallur Unit-1	S1-S2
26	23-06-2014	24/06/2014 - 27/06/2014	Margin revised due to Outage of KSK Mahandi Unit	ER-SR/WR- SR
		24-06-2014	Revised due to non availability of HVDC Gazuwaka Block 1 & Margin revised due to Outage of KSK Mahandi Unit	ER-SR
27	24-06-2014	25/06/2014 - 27/06/2014	Revised due to non availability of HVDC Gazuwaka Block 1	ER-SR
		26/06/2014 - 27/06/2014	Margin revised due to Annual Maintenance of Ramagundam Unit-3.	S1-S2
28	25-06-2014	28/06/2014 - 30/06/2014	Revised due to expected revival Vallur Unit-1 & Margin revised due to Annual Maintenance of Ramagundam Unit-3.	S1-S2
29	27-06-2014	27-06-2014	Revised due to revival of Vallur Unit-1	S1-S2

ASSUMPTIONS IN BASECASE

Month: June '14

				WOTHT . June 14	
	Name of State/Area	Load		Generation	
S.No.		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
I	NORTHERN REGION				
1	Punjab	4471	4200	1608	1515
2	Haryana	5334	4220	1056	1117
3	Rajasthan	7448	7777	5583	5384
4	Delhi	3961	3666	681	728
5	Uttar Pradesh	10552	10484	5594	5815
6	Jammu & Kashmir	1602	1380	566	564
7	Uttarakhand	1925	1690	843	534
8	Himachal Pradesh	1102	1151	574	623
9	Chandigarh	180	200	0	0
10	ISGS/IPPs			17025	15536
	Total NR	36575	34768	33530	31816
II	EASTERN REGION				
1	West Bengal	7127	6661	5396	4376
2	Jharkhand	696	851	275	350
3	Orissa	3177	2990	2315	2770
4	Bihar	2276	1775	110	110
5	Damodar Valley Corporation	2328	2162	2703	2889
6	Sikkim	59	41	0	0
7	Bhutan	108	108	300	295
8	ISGS/IPPs	410	410	7400	7352
	Total ER	16181	14998	18499	18142
III	WESTERN REGION				
1	Chattisgarh	3118	2566	2217	1790
2	Madhya Pradesh	6272	5975	3092	2909
3	Maharashtra	15542	16342	10886	11197
4	Gujarat	11193	11948	9820	10359
5	Goa	258	360	0	0
6	Daman and Diu	124	94	0	0
7	Dadra and Nagar Haveli	619	600	0	0
8	ISGS/IPPs	1239	1239	18000	18000
	Total WR	38365	39124	44015	44255

IV	SOUTHERN REGION				
1	Andhra Pradesh	10867	9465	6571	5881
2	Tamil Nadu	11286	10266	7776	7002
3	Karnataka	8112	7123	6100	4619
4	Kerala	3214	2389	1781	863
5	Pondy	285	249	0	0
6	Goa	83	83	0	0
7	ISGS/IPPs			9937	9560
	Total SR	33847	29575	32165	27925
٧	NORTH-EASTERN REGION				
1	Arunachal Pradesh	78	58	0	0
2	Assam	893	723	270	180
3	Manipur	84	48	0	0
4	Meghalaya	230	168	115	41
5	Mizoram	60	38	4	4
6	Nagaland	84	57	12	8
7	Tripura	158	115	95	99
8	ISGS/IPPs			561	274
	Total NER	1587	1207	1057	606
	Total All India	126555	119672	129266	122744