National Load Despatch Centre Total Transfer Capability for June 2015

Issue Date: 05/06/2015 Issue Time: 1300 hrs Revision No. 6

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR-WR *	1st Jun 2015 to 30th Jun 2015	00-24	2500	500	2000	706	1294		
	1st Jun 2015 to	00-17 23-24	5100	500	4600	5157	0		
	05th Jun 2015	17-23	5100		4600		0		
		00-05 14-17 23-24	5100		4600		0		
WR-NR*	06th June 2015	05-14'	4850	500	4350	5157	0	-250	Revised considering the shutdown of 400 kV HVDC Rihand Feeder 2
		17-23	5100		4600		0		
	07th Jun 2015 to	00-17 23-24	5100	500	4600	5157	0		
	30th Jun 2015	17-23	5100		4600		0		
	1st Jun 2015 to 30th	00-06	2000		1800	293	1507		
NR-ER*	Jun 2015 to 30th Jun 2015	06-18'	2000	200	1800	358	1442		
		18-24 00-17	2000		1800	293	1507		
ER-NR*#	1st Jun 2015 to 30th Jun 2015	23-24	4500	300	4200	2431	1769		
		17-23	4500		4200		1769		
W3-ER ^{\$}	1st Jun 2015 to	00-24					it is being specified		
	30th Jun 2015 1st Jun 2015 to				1		is allowed via W3-	ER-NR.	
ER-W3	30th Jun 2015	00-24	1000	300	700	874	0		
		00-05	2500		1750		200		
WR-SR	1st Jun 2015 to 5th Jun 2015	05-22'	2100	750	1350	1550	0		
		22-24 00-05	2500 2700		1750 1950		200 400		
WR-SR	6th Jun 2015 to 30th Jun 2015	05-22'	2300	750	1550	1550	0		
		22-24	2700		1950		400		
SR-WR *	1st Jun 2015 to 30th Jun 2015	00-24				No lim	it is being Specified		
	1	00-06	1		1				
	1st Jun 2015 to 5th		8-24	2450	2385	65			
ER-SR	Jun 2015	06-18'	2450	0	2450	2450	0		
	6th Jun 2015 to	00-06 18-24	2650	0	2650	1942	708		
	30th Jun 2015	06-18'	2030	Ů	2000	2007	643		
SR-ER *	1st Jun 2015 to 30th Jun 2015	00-24				No lim	it is being Specified		
	1	00-17							
ER-NER	1st Jun 2015 to 30th Jun 2015	23-24	1260	45	1215	210	1005		
		17-23 00-17	1160		1115		905		
NER-ER	1st Jun 2015 to 30th Jun 2015	23-24	1400	45	1355	0	1355		
	30th 3th 2013	17-23	1245	45	1200		1200		
	1st Jun 2015 to 5th	00-24	2610	305	2305	2790	0		
04.05	Jun 2015 6th Jun 2015 to								
S1-S2 (Rev-0)	14th Jun 2015	00-24	2910	305	2605	2898	0		
()	15th Jun 2015 to 30th Jun 2015	00-24	2910	305	2605	2819	0		
Import of Punjab	1st Jun 2015 to 30th Jun 2015	00-24	5700	300	5400	3790	1610		
Import TTC for DD & DNH	1st Jun 2015 to 30th Jun 2015	00-24	1200	0	1200		OA as per ex-pp edule		
W3 zone	1st Jun 2015 to	00-17	9400		9200		2106		
Injection	30th Jun 2015	23-24 17-23	9900	200	9700	7094	2606		
	(50 %) Countar flor			I TA/MTOA			2000	rad for advance	d transactions (Bilatoral & First Come

Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

National Load Despatch Centre **Total Transfer Capability for June 2015**

Issue Date: 05/06/2015 Issue Time: 1300 hrs Revision No. 6

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
----------	------	-------------------------	--	-----------------------	--	--	--	---	----------

S1-S2 Corridor: Any revision in S1-S2 TTC/ATC from Rev-0, would be uploaded under Intra-Regional Section on NLDC website.

\$ As per Simulations, predominant direction of flow is on West to North Corridor. Hence, in case injection point is in Western Region (W1,W2,W3), STOA/PX transactions from West to North on West-East-North corridor shall not be allowed as such transaction increases congestion in the West to North Corridor.

ER-NR TTC is independent of WR-NR corridor flow

- 1) S1 comprises of Telangana, AP and Karnataka: S2 comprises of Tamil Nadu, Kerala and Puducherry
 2) W3 comprises of the following regional entities:
 a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak
 f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCL, n)Vandana Vidyut

The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/Fuel shortage/New units being commissionned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

- In case of TTC Revision due to any shutdown:

 1) The TTC value will be revised to normal values after restoration of shutdown.
- 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

Limiting Constraints

Corridor	Constraint
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.
WR-NR	High Loading of 400kV Singrauli-Anpara & High loading of 765 kV Agra-Gwalior (1250 MW SPS setting on each circuit of 765 kV Gwalior-Agra) and Loop flows on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda (power flowing from WR to NR on 765kV Gwalior-Agra D/C and from NR to WR on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda).
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli
ER-NR	(n-1) contingnecy of 400 kV Farakka-Malda D/C
ER-W3	1. n-1 of 400 kV Wardha – Parli will lead to 30 degrees angular separation between Wardha and Parli. 2. (n-1) contingency of one circuit of 400kV Parli(PG)-Sholapur(PG) D/C
WR-SR &	1. n-1 of 400 kV Wardha – Parli will lead to 30 degrees angular separation between Wardha and Parli. 2. (n-1) contingency of one circuit of 400kV Parli(PG)-Sholapur(PG) D/C.
ER-SR	3. ER-SR TTC has been declared assuming more than 1100 MW generation at Talcher Stage-2. In case Talcher Stage-2 generation goes below 1100 MW, then the ER-SR TTC would be revised downward as constraints within ER would emerge.
ER-NER	N-1 contingency of 220/132 kV, 2x100 MVA ICTs at Dimapur.
NER-ER	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA ICT at Misa
S1-S2	(n-1) contingency of one circuit of 400 kV Kolar-Hosur D/C
Import of DD & DNH	(n-1) contingency of 400/220KV 315MVA ICT at VAPI
Import of Punjab	(n-1) contingency of ICT at Dhuri and (n-1) contingnecy of 220kV Moga(PG)-Moga(PSTCL)
W3 zone Injection	1. n-1 of 400 kV Wardha – Parli will lead to 30 degrees angular separation between Wardha and Parli. 2. (n-1) contingency of one circuit of 400kV Parli(PG)-Sholapur(PG) D/C

^{*}Primary constraints

Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER									
	1st Jun 2015 to	00-17 23-24	9600	800	8800	7588	1212		
	05th Jun 2015	17-23	9600	000	8800	/300	1212		
NR*	05th Jun 2015 to 30th Jun 2015	00-05 08-18 21-24	7100	800	6300	7588	0	-2500	Revised considering skewed sharing of flows on WR-NR
		05-08'	7900		7100		0	-1700	and ER-NR corridor ranging from 65:35 to 72:28
		18-21	7000		6200		0	-2600	110111 03.33 to 72.26
NER	1st Jun 2015 to	00-17 23-24	1260	45	1215	210	1005		
NEK	30th Jun 2015	17-23	1160		1115		905		
WR									
		00-05	4950		4200	3935	265		
		05-06'	4550		4200 3800	3935	265 0		
	1st Jun 2015 to	06-18'	4550	750	3800	4000	0		
	5th Jun 2015	18-22	4550	750	3800	3935	0		
		22-24	4950		4200	3935	265		
SR		00-05	5350		4600	3492	1108		
	6th Jun 2015 to	05-06'	4950		4200	3492	708		
	30th Jun 2015 to	06-18'	4950	750	4200	3557	643		
	30tii Juii 2013	18-22	4950		4200	3492	708		
		22-24	5350		4600	3492	1108		

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
	1st Jun 2015 to	00-06	4500		3800	999	2801			
NR*	30th Jun 2015	06-18'	4300	700	3800	1064	2736			
		18-24	4500		3800	999	2801			
NER	1st Jun 2015 to	00-17 23-24	1400	45	1355	0	1355			
NEK	30th Jun 2015	17-23	1245	45	1200	U	1200			
WR										

SR *	1st Jun 2015 to 30th Jun 2015	00-24		No limit is being Specified.						

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Limiting Constraints

n-1) contingnecy of 400 kV Farakka-Malda D/C
High loading of 765 kV Agra-Gwalior (1250 MW SPS setting on each circuit of 765 kV Gwalior-Agra) and high loop
lows on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda (power flowing from WR to NR on 765kV Gwalior-Agra
D/C and from NR to WR on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda).
n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.
n-1) contingency of 400 kV Saranath-Pusauli
N-1 contingency of 220/132 kV, 2x100 MVA ICTs at Dimapur.
n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other ICT at Misa
. (n-1) of 400 kV Wardha – Parli will lead to 30 degrees angular separation between Wardha and Parli.
n-1) contingency of one circuit of 400kV Parli(PG)-Sholapur(PG) D/C.
B. ER-SR TTC has been declared assuming more than 1100 MW generation at Talcher Stage-2. In case Talcher Stage-
generation goes below 1100 MW, then the ER-SR TTC would be revised downward as constraints within ER would
emerge.
3

^{*}Primary constraints

National Load Despatch Centre Total Transfer Capability for June 2015

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor Affected
1	02-03-2015	Whole	STOA Margins revised due to grant of MTOA from	W3 Zone/
1	02-03-2015	Month	Chattisgarh to KSEB by CTU.	W3-ER
			Revised due to commissioning of Sasan Unit-6 and	WR-NR
2	31-03-2015	Whole	reviewed HVDC set points.	VVIX-IVIX
2	31-03-2013	Month		WR-SR
			Revised due to commissioning of 765kV Pune-Sholapur S/C.	WW SW
		Whole	Fifty Percent (50 %) Counter flow benefit on account of	Import of NR
		Month	LTA/MTOA transactions in the reverse direction.	Import or Nik
		01-06-15 to	Revised considering the present Maharashtra Demand	WR-SR
3	22-05-2015	05-06-15	pattern.	WIN SIN
		01-06-15 to 05-06-15	Revised considering the present Maharashtra Demand pattern and due to Shutdown of Talcher Stage-2 Unit-2.	WR-SR/ ER- SR
4	20.05.2045	Whole	Revised on account of addition of new elements in NER	ER-NER/ NER-
4	29-05-2015	Month	Grid and change in load-generation balance.	ER
5	31-05-2015	1-06-2015 to 05-06-2015	Revised considering tripping events of Talcher-Kolar HVDC Bipole and high ambient Temperature.	ER-SR / WR-SR
		06-06-2015		
		to	Revised considering skewed sharing of flows on WR-NR and	Import of NR
6	05-06-2015	30-06-2015	ER-NR corridor ranging from 65:35 to 72:28	
			Revised considering the shutdown of 400 kV HVDC Rihand	M/D N/D
		06-06-2015	Feeder 2	WR-NR

ASSUMPTIONS IN BASECASE

Month: June '15

				Month June 13			
		Lo	ad	Generation			
S.No.	Name of State/Area	Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)		
ı	NORTHERN REGION						
1	Punjab	9585	9795	4766	4766		
2	Haryana	7802	6896	3352	3352		
3	Rajasthan	7493	7935	4303	4303		
4	Delhi	5388	4734	1337	1337		
5	Uttar Pradesh	12093	12670	6549	6546		
6	Uttarakhand	1598	1367	754	666		
7	Himachal Pradesh	1248	1034	880	867		
8	Jammu & Kashmir	2188	1715	531	441		
9	Chandigarh	296	253	0	0		
10	ISGS/IPPs			19551	18408		
	Total NR	47691	46399	42023	40686		
II	EASTERN REGION						
1	Bihar	2500	1850	180	110		
2	Jharkhand	1100	678	400	360		
3	Damodar Valley Corporation	2750	2200	4512	3337		
4	Orissa	3803	3285	3508	2688		
5	West Bengal	7536	6049	4966	4542		
6	Sikkim	90	65	0	0		
7	Bhutan	107	106	1000	900		
8	ISGS/IPPs	675	664	10789	9319		
	Total ER	18561	14897	25355	21256		
III	WESTERN REGION						
1	Maharashtra	19358	15390	14146	9781		
2	Gujarat	13470	10976	10381	7092		
3	Madhya Pradesh	7020	5477	3837	1927		
4	Chattisgarh	3472	2268	2147	1462		
5	Daman and Diu	288	270	0	0		
6	Dadra and Nagar Haveli	677	665	0	0		
7	Goa-WR	475	299	0	0		
8	ISGS/IPPs	1136	1120	23133	23134		
	Total WR	45896	36465	53644	43396		

ASSUMPTIONS IN BASECASE

Month: June '15

	World Surie 15									
		Lo	ad	Gener	ation					
S.No.	Name of State/Area	Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)					
IV	SOUTHERN REGION									
1	Andhra Pradesh	5271	4582	5048	4666					
2	Telangana	5667	5464	2230	1951					
3	Karnataka	7755	7025	7076	5624					
4	Tamil Nadu	11352	10421	7157	6587					
5	Kerala	2827	1928	1567	617					
6	Pondy	312	288	0	0					
7	Goa-SR	83	89	0	0					
8	ISGS/IPPs	79	71	7622	7622					
	Total SR	33346	29868	30700	27067					
٧	NORTH-EASTERN REGION									
1	Arunachal Pradesh	70	39	0	0					
2	Assam	772	627	215	200					
3	Manipur	72	43	0	0					
4	Meghalaya	280	208	232	154					
5	Mizoram	61	39	4	3					
6	Nagaland	83	69	21	16					
7	Tripura	249	169	110	110					
8	ISGS/IPPs	48	27	1055	720					
	Total NER	1635	1221	1637	1203					
	Total All India	147129	128850	153359	133608					