# National Load Despatch Centre Total Transfer Capability for June 2016

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR-WR *	1st June 2016 to 30th June 2016	00-24	2500	500	2000	149	1851		
	1st June 2016 to 15th June 2016	00-24	5850	500	5350	6170	0		
WR-NR*	16th June 2016 to 30th June 2016	00-24	6700	500	6200	6170	30		
	1st June 2016 to	00-06	2000		1800	293	1507		
NR-ER*	30th June 2016	06-18'	2000	200	1800	358	1442		
		18-24	2000		1800	293	1507		
ER-NR*	1st June 2016 to 30th June 2016	00-24	3800	300	3500	2431	1069		
	1st June 2016 to					No limit i	s being specified.		
W3-ER <sup>\$</sup>	30th June 2016	00-24					allowed via W3-EI	R-NR	
	1st June 2016 to						anowed via wy El	X 111X.	
ER-W3	30th June 2016	00-24			No limit is	s being specified.			
	1st June 2016 to 9th June 2016	00-24	4000	750	3250	3250	0		
	9th June 2016	00-08	4000		3250		0		Revised due to shutdown of 765kV
WR-SR	10th June 2016	08-24	2200	750	1450	3250	0	-1800	Sholapur-raichur Ckt-2.
WK-SK		00-24	2200		1430		0	-1000	Shorapar rateriar CRt 2.
	11th June 2016 to 30th June 2016	00-24	4000	750	3250	3250	0		
SR-WR *	1st June 2016 to 30th June 2016	00-24				No limit i	s being Specified.	l	
	Sour suite 2010								
	1st June 2016 to	00-06				2585	65		
	2nd June 2016	18-24	2650	0	2650				
		06-18'				2650	0		
	217 2015	00-05	2650		2650	2585	65		
ER-SR	3rd June 2016 to 4th June 2016	05-06'	2000	0	2000	2585	0		
	4th Julie 2016	06-18' 18'-24	2000 2000		2000 2000	2650 2585	0		
		00-06	2000		2000	2383	0		
	5th June 2016 to	18-24	2650	2650 0	2650	2585	65		
	30th June 2016	06-18'				2650	0		
an me	1st June 2016 to					Į.			
SR-ER *	30th June 2016	00-24				No limit i	s being Specified.		
		00.17							
ER-NER	1st June 2016 to	00-17 23-24	1350	45	1305	210	1095		
TAIN-14TAIN	30th June 2016	17-23	1160	43	1115	210	905		
		00-17							
NER-ER	1st June 2016 to	23-24	1250	45	1205	0	1205		
	30th June 2016	17-23	1340		1295		1295		
W3 zone Injection	1st June 2016 to 30th June 2016	00-24					nal flows or any correvised accordingl		

<sup>\*</sup> Fifty Percent (50 % ) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

#### **National Load Despatch Centre Total Transfer Capability for June 2016**

Issue Date: 9/6/2016 Issue Time: 1115 hrs Revision No. 5

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
----------	------	-------------------------	--	-----------------------	--	--	--	---	----------

- \$ As per Simulations, predominant direction of flow is on West to North Corridor. Hence, in case injection point is in Western Region (W1,W2,W3), STOA/PX transactions from West to North on West-East-North corridor shall not be allowed as such transaction increases congestion in the West to North Corridor.
- 1) S1 comprises of Telangana, AP and Karnataka: S2 comprises of Tamil Nadu, Kerala and Puducherry
- 2) W3 comprises of the following regional entities:
- a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak
- f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCL, n) Vandana Vidyut
- # The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/Fuel shortage/New units being commissionned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown:

- 1) The TTC value will be revised to normal values after restoration of shutdown.
- 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

#### **Limiting Constraints**

Corridor	Constraint
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak
WR-NR	1. (n-1) Contingnecy of 765kV Gwalior-Agra one ckt leads to 2750 MW loading on second circuit. 2.High Loading of 400kV Singrauli-Anpara S/C.
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli
ER-NR	n-1 contingency of one cicuit of 400 kV Biharshariff- Lakhisarai leads to high loading on the other cicuit
WR-SR & ER-SR	(n-1) contingency of one circuit of 765 kV Raichur - Sholapur will lead to 2500 MW loading on the other circuit  Under S/D of one ckt of 765kV Raichur-Sholapur, the constraint would be (n-1) of remaining 765kV Sholapur-raichur would lead to Low voltage at Kolhapur, Mapusa  Low Voltage at Gazuwaka (East) Bus.
ER-NER	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA ICT at Misa. n-1 contingency of 400/132 kV, 2 x 200 MVA ICTs at Silchar
NER-ER	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA ICT at Misa
W3 zone Injection	

### **Simultaneous Import Capability**

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER									
	4 . 7 . 2016	00-05	7800	v	7000		0		
	1st June 2016 to	05-08'	7800	800	7000	8601	0		
NR <sup>*</sup>	15th June 2016	08-19'	7800	į.	7000		0		
		19-24	7800		7000		0		
	16th June 2016	00-05	8950	ı	8150		0		
	to 30th June	05-08'	8950	800	8150	8601	0		
	2016	08-19'	8950		8150		0		
		19-24	8950		8150		0		
NER	1st June 2016 to 30th June 2016	00-17 23-24	1350	45	1305	210	1095		
		17-23	1160		1115		905		
WR									
WK									
	1st June 2016 to	00-06	6650	i,	5900	5835	65		
	2nd June 2016	06-18'	6650	750	5900	5900	0		
	Zila Julie 2010	18-24	6650		5900	5835	65		
		00-05	6650		5900	5835	65		
	3rd June 2016 to	05-06'	6000	750	5250	5835	0		
	4th June 2016	06-18'	6000	730	5250	5900	0		
		18-24	6000		5250	5835	0		
	5th June 2016 to	00-06	6650		5900	5835	65		
SR	9th June 2016	06-18'	6650	750	5900	5900	0		
	7th June 2010	18-24	6650		5900	5835	65		
		00-06	6650		5900	5835	65		Revised due to shutdown
	10th June 2016	06-08'	6650	750	5900	5900	0		of 765kV Sholapur-
	1001100110 2010	08-18'	4850	,30	4100	5900	0	-1800	Raichur Ckt-2.
		18-24	4850		4100	5835	0	1000	1
	11th June 2016	00-06	6650	·	5900	5835	65		
	to 30th June	06-18'	6650	750	5900	5900	0		
	2016	18-24	6650		5900	5835	65		

<sup>\*</sup> Fifty Percent (50%) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

\* For approving STOA Bilateral transactions, margin available in Simultaneous Import of NR would be apportioned on WR-NR Corridor & ER-NR Corridor in the following ratio:

Margin in Simultaneous import of NR = A

WR-NR ATC =B

ER-NR ATC = C

Margin for WR-NR applicants = A \* B/(B+C)

Margin for ER-NR Applicants = A \* C/(B+C)

# **Simultaneous Export Capability**

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
	1 . 1 . 2016 .	00-06	4500	700	3800	442	3358		
NR*	1st June 2016 to 30th June 2016	06-18'	4300		3800	507	3293		
		18-24	4500		3800	442	3358		
NER	1st June 2016 to 30th June 2016	00-17 23-24	1250	45	1205	0	1205		
	30th Julie 2010	17-23	1340		1295		1295		
WR									
****									
SR *	1st June 2016 to 30th June 2016	00-24				No limit is be	ing Specified.		

<sup>\*</sup> Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

### **Limiting Constraints**

	3 Constraints							
		(n-1) contingency of one circuit of 400 kV Biharshariff- Lakhisarai leads to high loading on the other circuit						
NR _	Import	1. (n-1) Contingnecy of 765kV Gwalior-Agra one ckt leads to 2750 MW loading on second circuit.						
		2.High Loading of 400kV Singrauli-Anpara S/C.						
	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.						
		(n-1) contingency of 400 kV Saranath-Pusauli						
	T .	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA						
NER	Import	ICT at Misa. n-1 entingency of 400/132 kV, 2 x 200 MVA ICTs at Silchar						
NEK	Export	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA						
NER -		ICT at Misa.						
		(n-1) contingency of one circuit of 765 kV Raichur - Sholapur will lead to 2500 MW loading on the other circuit						
NER	Tunan a sut	Under S/D of one ckt of 765kV Raichur-Sholapur, the constraint would be (n-1) of remaining 765kV Sholapur-						
	Import	raichur would lead to Low voltage at Kolhapur, Mapusa						
		Low Voltage at Gazuwaka (East) Bus.						

# National Load Despatch Centre Total Transfer Capability for June 2016

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor Affected
4	24 Mar 46		STOA Margin revised considering the grnat of of MTOA.	WR-NR
1	31-Mar-16	Whole Month	STOA Margin revised considering the completion of ISGS Allocation towards SR.	NR-WR
2	2 5-Mar-16	Revised considering the present high generation trend in Rajasthan state  Whole month		WR- NR/import of NR
2		whole month	STOA margin revised due to change in LTA/MTOA allocation	NR-WR / Export of NR
3	31-May-16 1/6/2016 to 15/6/2016		Revised due to forced outage of 765kV Phagi-Bhiwani S/C	WR- NR/import of NR
4	4 2-Jun-16 3/6/2016 to 4/6/2016		Revised due to shutdown of 400 kV Jeypore-Gajuwaka ckt 1 & ckt 2	ER-SR / Import of SR
5	9-Jun-16	10/6/2016	Revised due to shutdown of 765kV Sholapur-Raichur Ckt-2.	WR-SR / Import of SR

	l				1
				Month : June '16	
S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
l	NORTHERN REGION		•	Ì	
1	Punjab	8037	9187	2694	2870
2	Haryana	7136	6607	2089	2090
3	Rajasthan	8262	7934	4898	4898
4	Delhi	4980	4853	938	938
5	Uttar Pradesh	12958	12026	6191	6330
6	Uttarakhand	1695	1469	976	843
7	Himachal Pradesh	1201	1299	879	913
8	Jammu & Kashmir	2209	1820	648	642
9	Chandigarh	291	259	0	0
10	ISGS/IPPs	0	0	20961	19557
	Total NR	46769	45453	40274	39080
II	EASTERN REGION				
1	Bihar	3085	2462	210	100
2	Jharkhand	1148	886	470	300
3	Damodar Valley Corporation	2769	2412	4082	3235
4	Orissa	3974	3053	3143	1978
5	West Bengal	7367	5327	5006	3600
6	Sikkim	99	64	0	0
7	Bhutan	215	215	1227	637
8	ISGS/IPPs	628	625	10953	10245
	Total ER	19285	15044	25090	20096
Ш	WESTERN REGION				
	Maharashtra	19699	13672	14568	9815
	Gujarat	12968	10139	10079	7008
3	Madhya Pradesh	7786	5193	3889	2717
4	Chattisgarh	3455	2596	2116	1220
5	Daman and Diu	313	247	0	0
6	Dadra and Nagar Haveli	740	660	0	0
7	Goa-WR	463	247	0	0
8	ISGS/IPPs	1078	1076	27268	23455
	Total WR	46502	33830	57919	44214

V	SOUTHERN REGION				
1	Andhra Pradesh	6568	5901	5570	5024
2	Telangana	6982	6490	1686	1501
3	Karnataka	9040	7448	7353	5628
4	Tamil Nadu	15329	13542	8515	6715
5	Kerala	3503	2195	1590	657
6	Pondy	391	348	0	0
7	Goa-SR	89	89	0	0
8	ISGS/IPPs	0	0	13047	11948
	Total SR	41902	36013	37761	31472
/	NORTH-EASTERN REGION				
1	Arunachal Pradesh	122	89	0	0
2	Assam	1057	846	308	170
3	Manipur	126	80	0	0
4	Meghalaya	261	181	173	123
5	Mizoram	81	65	8	8
6	Nagaland	103	100	24	21
7	Tripura	256	158	90	90
8	ISGS/IPPs	0	0	1503	1283
	Total NER	2006	1519	2106	1695
	Total All India	156464	131859	163150	136557