Issue Date: 11th June 2017

Issue Time: 1500 hrs

Revision No. 10

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR-WR*	1st June 2017 to 30th June 2017	00-06 06-18 18-24	2500	500	2000	55 65 55	1945 1935 1945		
	1st June 2017	00-24	8300	500	7800	7951	0		
	2nd June 2017 3rd June 2017 to 6th June 2017	00-12	9050	500	8550	7951	1945		
		12-24	7550	500	7050	7951	0		
		00-24	9050	500	8550	7951	599		
WR-NR*	7th June 2017	00-11:30	9050	500	8550	7951	599		
		11:30-24	8050	500	7550	7951	0		
	8th June 2017	00-08	9050	500	8550	7951	599		
		24-Aug	8050	500	7550	7951	0		
	9th June 2017 to 30th June 2017	00-24	9050	500	8550	7951	599		
		00-06	2000		1800	193	1607		
NR-ER*	1st June 2017 to	06-18'	2000	200	1800	303	1497		
	30th June 2017	18-24	2000	200	1800	193	1607		
ER-NR*	1st June 2017 to 30th June 2017	00-24	4200	300	3900	2983	917		
W3-ER	1st June 2017 to 30th June 2017	00-24	No limit is being specified.						
ER-W3	1st June 2017 to 30th June 2017	00-24	No limit is being specified.						
WR-SR	1st June 2017 to 30th June 2017	00-05 05-22 22-24	4350 4350 4350	500	3850 3850 3850	3938	0 0 0		
SR-WR *	1st June 2017 to 30th June 2017	00-24		4350 0 No limit is being Specified.					

Issue Date: 11th June 2017

Issue Time: 1500 hrs

Revision No. 10

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
	1st June 2017 to	00-06				3211	0		
	11th June 2017	06-18'	3450	250	3200	3296	0		
		18-24				3211	0		
		00-06	3450	250	3200	3211	0		Revised due to day-time shutdown
	12th June 2017	06-08'	5450	230	3200	3296	0		of 765 kV Angul-Srikakulam circuit I
	12ui Julie 2017	08-18	3300	250	3050	3296	0	-150	
ER-SR		18-24	3300	230	5050	3211	0	-150	
EK-SK		00-06	3450	250	3200	3211	0		Revised due to day-time shutdown
	13th June 2017	06-08'	5450	230	3200	3296	0		of 765 kV Angul-Srikakulam circuit
	13th June 2017	08-18	3300	250	3050	3296	0	-150	II
		18-24	3300	230	3030	3211	0	-150	11
	14th June 2017 00-0	00-06		250		3211	0		
	to 30th June	06-18'	6-18' 3450		3200	3296	0		
	2017	18-24				3211	0		

Issue Date: 11th June 2017 Issue Time: 1500 hrs Revision No. 10 Long Term Margin Changes Available Total Access (LTA)/ Time Available for in TTC Transfer Reliability Transfer Corridor Date Period Medium Term Short Term Comments w.r.t. Capability Margin Capability **Open Access Open Access** (hrs) Last (TTC) (ATC) (MTOA) # (STOA) Revision 1st June 2017 to SR-ER * 00-24 No limit is being Specified. 30th June 2017 1105 880 00-17 1150 1st June 2017 to ER-NER 1030 985 225 17-23 45 760 30th June 2017 23-24 1150 1105 880 00-17 1240 1195 1195 1st June 2017 to NER-ER 17-23 1050 45 1005 0 1005 30th June 2017 23-24 1195 1240 1195 W3 zone 1st June 2017 to 00-24 No limit is being specified (In case of any constraints appearing in the system, W3 zone export would be revised accordingly) 30th June 2017 Injection Note: TTC/ATC of S1-(S2&S3) corridor, Import of S3(Kerala), Import of Punjab and Import of DD & DNH is uploaded on NLDC website under Intra-**Regional Section in Monthly ATC.**

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Issue Date: 11th June 2017

Issue Time: 1500 hrs

Revision No. 10

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
----------	------	-------------------------	--	-----------------------	--	--	--	---	----------

1) S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala

2) W3 comprises of the following regional entities :

a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCL, n)Vandana Vidyut o)RKM, p)GMR Raikheda, q)Ind Barath and any other regional entity generator in Chhattisgarh

The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissionned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown :

1) The TTC value will be revised to normal values after restoration of shutdown.

2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

Limiting Constraints

Corridor	Constraint
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak
WR-NR	1. (n-1) Contingnecy of 765kV Gwalior-Agra one ckt leads to 2750 MW loading on second circuit.
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli
ER-NR	(n-1) contingencies of N.Ranchi - Chandawa S/c & (n-1) contingencies of 400kV MPL- Maithon S/c
	(n-1) contingency of 400 kV Dichipalli-Ramagundam or one ckt of 765 kV Aurangabad-Solapur D/C will lead to 874 MW loading on 400kV Vemagiri(PG)-Gazuwaka (With Opening of 400kV Vemagiri(PG)- Nunna S/C)
	Low Voltage at Gazuwaka (East) Bus.
ER-NER	a. (n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa
NER-ER	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA ICT at Misa
W3 zone Injection	

Simultaneous Import Capability

	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER									
		00.05	11050		11050		116		
		00-05	11850 11850		11050 11050		116 116		
	1st June 2017	03-08	11850	800	11050	10934	116		
	1st Julie 2017	18-23	10650	800	9850	10934	0		
		23-24	11850		11050		116		
		00-05	12900		12100		1166		
		05-08	12900		12100		1166		
		08-12	12900		12100		1166		
	2nd June 2017	12-18	12900	800	10000	10934	0		
		18-23	9700		8900	+	0		
		23-24	10800		10000		0		
		00-05	12900		12100	-	1166		
		05.08	12900		12100		1166		
	3rd June 2017 to	08-18	12900	800	12100	10934	1166		
	6th June 2017	18-23	11600		10800		0		
NR		23-24	12900		12100	1	1166		
		00-05	12900		12100		1166		
		05-11:30	12900	800	12100	10934	1166		
	7th June 2017	11:30-18	11450		10650		0		
		18-23	10150		9350		0		
		23-24	11450		10650		0		
		00-05	12900		12100		1166		
		05-08	12900		12100		1166		
	8th June 2017	08-18	11450	800	10650	10934	0		
		18-23	10150		9350		0		
		23-24	11450		10650		0		
		00-05	12900		12100		1166		
	9th June 2017 to	05-08	12900		12100		1166		
	30th June 2017	08-18	12900	800	12100	10934	1166		
		18-23	11600		10800		0		
		23-24	12900		12100		1166		
NED	1st June 2017 to	00-17	1150	45	1105	225	880		
NER	30th June 2017	17-23	1030	45	985	225	760		
		23-24	1150		1105		880		
WR									

		00-05	7800		7050	7149	0		
	1st June 2017 to	05-06	7800		7050	7149	0		
	11th June 2017	06-18	7800	750	7050	7234	0		
	11ui Julie 2017	18-22	7800		7050	7149	0		
		22-24	7800		7050	7149	0		
		00-05	7800		7050	7149	0		
		05-06	7800		7050	7149	0		Revised due to day-time
	12th June 2017	06-08	7800	750	7050	7234	0		shutdown of 765 kV Angul-
	12th June 2017	08-18	7650	750	6900	7234	0	-150	Srikakulam circuit I
		18-22	7650		6900	7149	0		
SR		22-24	7650		6900	7149	0		
SK		00-05	7800		7050	7149	0		Revised due to day-time shutdown of 765 kV Angul-
		05-06	7800		7050	7149	0		
	13th June 2017	06-08	7800	750	7050	7234	0		
	15th Julie 2017	08-18	7650	750	6900	7234	0		Srikakulam circuit II
		18-22	7650		6900	7149	0	-150	Sirkakulum eneurem
		22-24	7650		6900	7149	0		
		00-05	7800		7050	7149	0	_	
	14th June 2017 to 30th June 2017	05-06	7800	750	7050	7149	0	_	
		06-18	7800		7050	7234	0	1	
		18-22	7800		7050	7149	0	1	
		22-24	7800		7050	7149	0		

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

* For approving STOA Bilateral transactions, margin available in Simultaneous Import of NR would be apportioned on WR-NR Corridor & ER-NR Corridor in the following ratio:
Margin in Simultaneous import of NR = A
WR-NR ATC = B
ER-NR ATC = C
Margin for WR-NR applicants = A * B/(B+C)
Margin for ER-NR Applicants = A * C/(B+C)

Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR*	* 1st June 2017 to 30th June 2017	00-06 06-18'	4500	700	3800 3800	248 368	3552 3432		
		18-24	4500		3800	248	3552		
	1st June 2017 to	00-17	1240		1195	0	1195		
NER	30th June 2017 to	17-23	1050	45	1005		1005		
	50th Julie 2017	23-24	1240		1195		1195		
WR									
W K									
SR *	1st June 2017 to 30th June 2017	00-24		No limit is being Specified.					

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Limiting Constraints

		(n-1) contingencies of N.Ranchi - Chandawa S/c & (n-1) contingencies of 400kV MPL- Maithon S/c.
	Import	1. (n-1) Contingnecy of 765kV Gwalior-Agra one ckt leads to 2750 MW loading on second circuit.
NR		2.High Loading of 400kV Singrauli-Anpara S/C.
	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.
	Export	(n-1) contingency of 400 kV Saranath-Pusauli
	Import	a. (n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa
NER	Import	b. High loading of 220 kV Balipara-Sonabil line(200 MW)
	F 4	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA
	Export	ICT at Misa.
		(n-1) contingency of 400 kV Dichipalli-Ramagundam or one ckt of 765 kV Aurangabad-Solapur D/C will lead to 874
SR	Import	MW loading on 400kV Vemagiri(PG)-Gazuwaka (With Opening of 400kV Vemagiri(PG)-Nunna S/C)
		Low Voltage at Gazuwaka (East) Bus.

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor Affected
1	2/28/2017	Whole month	Revised due to change in LTA/MTOA	ER-SR/Import of SR
2	25th April		Revised considering commissioning of one pole of HVDC Champa - Kurukshetra,the present load generation balance and change in LTA/MTOA approved by CTU	WR-NR/ER- NR/Import of NR
2	2017	Whole month	Revised considering the commissioning of 765 kV Durg - Wardha D/C, second ICT at Vemagiri, 765 kV Wardha - Nizamabad D/C, two ICTs at Nizamabad, and 400 kV Nizamabad-Dichipally D/C.	WR-SR/ ER-SR/ Import of SR
3	26th April 2017	Whole month	STOA margin revised considring change in LTA / MTOA approved by CTU	ER-NR/Import of NR
4	05th May 2017	Whole month	STOA margin revised considering the latest LTA/MTOA granted by CTU	WR-SR/ ER-SR/ Import of SR
5	09th May 2017	Whole month	Revised considering the latest LTA/MTOA granted by CTU	WR-SR/ Import of SR
6	16th May 2017	Whole month	Revised considering present Inter-regional flow pattern	Import of NR
7	30th May 2017	1-Jun-17	Revised due to shutdown of Rihand-Dadri pole-2	WR-NR/ Import of NR
8	1st June 2017	2-Jun-17	Revised due to Shutdown of HVDC Champa-Kurukshetra pole 1	WR-NR/ Import of NR
9	7th June 2017	7th June 2017 to 8th June 2017	Revised due to day-time Shutdown of 765 kV Meerut Greater Noida	WR-NR/ Import of NR
10	11th June 2017	12th June 2017 to 13th June 2017	Revised due to day-time shutdown of 765 kV Angul- Srikakulam circuit I and II	ER-SR/ Import of SR

ASSUN	IPTIONS IN BASECASE				
				Month : June'17	
S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
I	NORTHERN REGION				
1	Punjab	7405	8197	3228	4350
	Haryana	7041	6980	1415	2163
3	Rajasthan	8526	9434	6592	7660
	Delhi	5326	5273	508	632
5	Uttar Pradesh	14831	15505	8612	9240
6	Uttarakhand	1855	1492	926	868
7	Himachal Pradesh	1196	1144	779	864
8	Jammu & Kashmir	2083	2372	1014	1029
9	Chandigarh	328	257	0	0
10	ISGS/IPPs	27	27	19320	19189
	Total NR	48619	50680	42393	45995
II	EASTERN REGION				
1	Bihar	3798	2692	208	204
2	Jharkhand	1162	879	397	348
3	Damodar Valley Corporation	2905	2290	4228	3682
4	Orissa	4159	3016	3342	2013
5	West Bengal	8350	5270	5608	3713
6	Sikkim	89	83	0	0
7	Bhutan	245	245	632	451
8	ISGS/IPPs	568	565	11194	9063
	Total ER	21246	15010	25579	19445
	WESTERN REGION				
1	Maharashtra	19011	14933	12314	9849
	Gujarat	14865	12942	11690	8510
	Madhya Pradesh	7064	6558	3089	2307
	Chattisgarh	3033	3058	1915	2461
	Daman and Diu	298	289	0	0
6	Dadra and Nagar Haveli	719	738	0	0
	Goa-WR	469	323	0	0
8	ISGS/IPPs	2889	3044	32224	29087
	Total WR	48348	41887	61231	52214

	ΙΙΙ				
IV	SOUTHERN REGION				
1	Andhra Pradesh	7748	7698	6636	6146
2	? Telangana	6298	5734	3849	3578
	Karnataka	8598	8446	6342	4886
4	Tamil Nadu	15000	12600	7580	6380
5	Kerala	3570	2150	1414	100
6	Pondy	395	395	0	0
7	Goa-SR	89	89	0	0
8	ISGS/IPPs			10824	10966
	Total SR	41306	36757	36645	32056
/	NORTH-EASTERN REGION				
1	Arunachal Pradesh	138	90	0	0
2	Assam	1199	1028	240	200
3	Manipur	152	75	0	0
4	Meghalaya	277	195	193	66
5	Mizoram	95	69	8	8
6	Nagaland	117	80	22	12
	Tripura	255	166	78	77
8	ISGS/IPPs	100	60	1915	1538
	Total NER	2333	1763	2456	1901
	Total All India	162096	146343	168937	152063