# National Load Despatch Centre Total Transfer Capability for June 2018

Issue Date: 05th June 2018 Issue Time: 1300 hrs Revision No. 12

NR-WR* 30  1s  WR-NR* 2r  06  7t  tr  NR-ER* 1st 30  ER-NR* 1st 30  FR-W3 1st	st June 2018 to 30th June 2018  2nd June 2018 to 5th June 2018  20th June 2018 to 5th June 2018  7th June 2018 to 30th June 2018	00-06 06-18 18-24 00-08 08-24 00-24	2500 9000 8050** 10000 9050** 10000	500 500	2000 8500 7550** 9500	100 110 100 9127 8177**	1900 1890 1900 0		
NR-WR* 30  1s  WR-NR* 2r  06  7t  tr  NR-ER* 1st 30  ER-NR* 1st 30  FR-W3 1st	2nd June 2018 2nd June 2018 to 5th June 2018 206th June 2018 7th June 2018 to 30th June	18-24 00-08 08-24 00-24	9000 8050** 10000 9050** 10000 9050**	500	8500 7550**	100 9127 8177**	1900		
1st   30     30	1st June 2018 2nd June 2018 to 5th June 2018 06th June 2018 7th June 2018 to 30th June	00-08 08-24 00-24	8050** 10000 9050** 10000 9050**		7550**	9127 8177**			
VR-NR*	2nd June 2018 to 5th June 2018 O6th June 2018 7th June 2018 to 30th June	08-24	8050** 10000 9050** 10000 9050**		7550**	8177**	0		
VR-NR*	2nd June 2018 to 5th June 2018 O6th June 2018 7th June 2018 to 30th June	00-24	10000 9050** 10000 9050**	500					
WR-NR*   1	to 5th June 2018  O6th June 2018  7th June 2018 to 30th June	00-24	9050** 10000 9050**	500	9500		0**		
WR-NR*   1	to 5th June 2018  O6th June 2018  7th June 2018 to 30th June	00-24	10000 9050**	500		9127	373		
WR-NR*   1	to 5th June 2018  O6th June 2018  7th June 2018 to 30th June		10000 9050**		8550**	8177**	373**		
WR-NR*   1	to 5th June 2018  O6th June 2018  7th June 2018 to 30th June		9050**		9500	9127	373		
7t to  7t to  7t to  7t to  1st 30  ER-NR* 1st 30  W3-ER 1st 30  FR-W3 1st	O6th June 2018 7th June 2018 to 30th June	00-24		500	7500	) 1 <b>2</b> ,	3.73		
7t to  7t to  7t to  7t to  1st 30  ER-NR* 1st 30  W3-ER 1st 30  FR-W3 1st	7th June 2018 to 30th June	00-24			8550**	8177**	373**		
7t to  7t to  7t to  7t to  1st 30  ER-NR* 1st 30  W3-ER 1st 30  FR-W3 1st	7th June 2018 to 30th June	00-24	9000		8500	9127	0		Due to Continuous forced outage of HVDC
NR-ER* 1st 30  ER-NR* 2st 30  W3-ER 1st 30  FR-W3 1st	to 30th June		00 <b>5</b> 0 data	500	5550 tub	04.55 (b)	Ostate	-1000	Champa-Kurukshetra Pole-2
NR-ER* 1st 30  ER-NR* 1st 30  W3-ER 1st 30	to 30th June		8050**		7550**	8177**	0**		1
NR-ER* 1st 30  ER-NR* 2st 30  W3-ER 1st 30  ER-W3 1st		00-24	10000	500	9500	9127	373		
NR-ER* 30  ER-NR* 1st 30  W3-ER 1st 30  FR-W3 1st		00-24	9050**	300	8550**	8177**	373**		
NR-ER* 30  ER-NR* 1st 30  W3-ER 1st 30  FR-W3 1st	-								
W3-ER 1st 30  FR-W3 1st	st June 2018 to	00-06	2000	200	1800	193	1607	-	
W3-ER 1st 30  FR-W3 1st	30th June 2018	06-18 18-24	2000	200	1800 1800	303 193	1497 1607	-	
W3-ER 30  FR-W3 1st	st June 2018 to 30th June 2018	00-24	5250	300	4950	3407	1543		
30	st June 2018 to 30th June 2018 st June 2018 to	00-24	No limit is being specified.  No limit is being specified.						
	30th June 2018								
		00-07	5150		4650		135		
15	1st June 2018	07-22	4150	500	3650	4515	0		
		22-24	4150		3650		0		
		00-930	4150		3650		0		
2r	2nd June 2018	930-18	3950	500	3450	4515	0		
21	zna june 2010			300		7,313			
WR-SR		18-24	4150		3650		0		
	3rd June 2018	00-05	4150	700	3650	12.2	0		
t	to 09th June	05-22	4150	500	3650	4515	0		
	2018	22-24	4150		3650		0		
10	0th June 2018	00-05	5150		4650		135		
	to 30th June	05-22	5150	500	4650	4515	135		
	2018	22-24	5150		4650		135		
SR-WR *	st June 2018 to 30th June 2018	00-24				No l	imit is being Speci	fied.	
		00.06				2262	927		
ED CD 1st	1st June 2019 to	00-06	1250	250	4100	3263	837		
I HIR-SR I	st June 2018 to	06-18	4350	250	4100	3348	752		
SR-ER * 1st 30	st June 2018 to 30th June 2018	18-24 00-24	No limit is being Specified.						

### National Load Despatch Centre Total Transfer Capability for June 2018

Issue Date: 05th June 2018 Issue Time: 1300 hrs Revision No. 12

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
	1.1. 2010	00-09	1200		1155		930			
		09-17	980	45	935	225	710			
	1st June 2018	17-23	950	45	905	225	680			
		23-24	980		935		710			
		00-17	1200		1155		930			
ER-NER	2nd June 2018	17-23	1100	45	1055	225	830			
		23-24	1200		1155		930			
EK-NEK		00-08 08-17	1200 980		935		930 710			
	3rd June 2018	17-23	950	45	905	225	680			
		23-24	980		935		710			
	4th June 2018	00-17	980		935		710			
	to 9th June	17-23	950	45	905	225	680			
	2018	23-24	980		935		710			
	10th June 2018 to 30th June	00-17 17-23	1200 1100	45	1155 1055	225	930 830			
	2018	23-24	1200	40	1155		930			
	1st June 2018	00-09	1710		1665		1665			
		09-17	1600	45	1555	0	1555			
		17-23	1570	43	1525	0	1525			
		23-24	1600		1555		1555			
		00-17	1710		1665	0	1665			
	2nd June 2018	17-23	1760	45	1715		1715			
		23-24	1710		1665		1665			
NER-ER		00-08	1710		1665		1665			
TUEN EN	3rd June 2018	08-17	1600	45	1555	0	1555			
		17-23	1570		1525		1525			
		23-24	1600		1555		1555			
	4th June 2018	00-17	1600		1555		1555			
	to 9th June	17-23	1570	45	1525	0	1525			
	2018	23-24	1600		1555		1555			
	10th June 2018	00-17	1710		1665		1665			
	to 30th June	17-23	1760	45	1715	0	1715			
	2018	23-24	1710		1665		1665			
Injection	1st June 2018 to 30th June 2018	00-24		No limit is being specified (In case of any constraints appearing in the system, W3 zone export would be revised accordingly)						

Note: TTC/ATC of S1-(S2&S3) corridor, Import of S3(Kerala), Import of Punjab and Import of DD & DNH is uploaded on NLDC website under Intra-Regional Section in Monthly ATC.

#### In case of TTC Revision due to any shutdown :

- 1) The TTC value will be revised to normal values after restoration of shutdown.
- 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

<sup>\*</sup> Fifty Percent (50 % ) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

<sup>\*\*</sup>Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.

<sup>1)</sup> S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala

<sup>2)</sup> W3 comprises of the following regional entities:

a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak

f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCL, n)Vandana Vidyut o)RKM, p)GMR Raikheda, q)Ind Barath and any other regional entity generator in Chhattisgarh

<sup>#</sup> The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/Fuel shortage/New units being commissionned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

#### **Simultaneous Import Capability**

Corrido r	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER									
			12850		12050		0		
		00-08	11900**		11100**		0**		
			14300		13500		908		
	1st June 2018	08-18 13350**	800	12550**	12592	908**			
		10.22	12800		12000	11642**	0		
		18-23	11850**		11050**	11042***	0**		
			14300		13500		908		
		23-24	13350**		12550**		908**		
	2nd June 2018 to 5th June 2018	00-18	14300	800	13500		908		
			13350**		12550**	12592	908**		
		18-23	12800		12000		0		
			11850**		11050**	11642**	0**		
NR		23-24	14300		13500 12550**		908 908**		
		00-18	12850		12050		0		+
			11900**		11100**	12502	0**	-1450	
			11550		10750	12592	0		Due to Continuous forced
	06th June 2018	18-23	10600**	800	9800**	11642**	0**	-1250	outage of HVDC Champa- Kurukshetra Pole-2
			12850		12050	11012	0		
		23-24	11900**		11100**		0**	-1450	
		00.10	14300		13500		908		
		00-18	13350**		12550**	12592	908**		
	07th June 2018		12800		12000	12372	0		
	to 30th June 2018	18-23	11850**	800	11050**	11642**	0**		
	2010	22.21	14300		13500	-	908		
		23-24	13350**		12550**		908**		

Corrido r	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
		00-09	1200	45	1155		930		
	1st June 2018	09-17	980		935	225	710		
	13t June 2010	17-23	950		905	223	680		
		23-24	980		935		710		
	2nd June 2018	00-17	1200	45	1155	225	930 830		
	Ziid Julie 2018	17-23 23-24	1100 1200	43	1055 1155	223	930		
		00-08	1200		1155		930		
NER	2.11. 2010	08-17	980	4.5	935	225	710		
	3rd June 2018	17-23	950	45	905	225	680		
		23-24	980		935		710		
	4th June 2018	00-17	980		935		710		
	to 9th June	17-23	950	45	905	225	680		
	2018	23-24	980		935		710		
	10th June 2018 to 30th June	00-17 17-23	1200 1100	45	1155 1055	225	930 830		
	2018	23-24	1200	43	1155	223	930		
	2010	23-2 <del>4</del>	1200		1133		730		
WR									
	1st June 2018	00-05	9500	750	8750	7778	972		
		05-06	9500		8750	7778	972		
		06-07	9500		8750	7863	887		
SR		07-18	8500		7750	7863	0		
		18-22	8500		7750	7778	0		
		22-24	8500		7750	7778	0		
		00-05	8500		7750	7778	0		
		05-06	8500		7750	7778	0		
	2 11 2010	06-930	8500	750	7750	7863	0		
	2nd June 2018	930-18	8300	750	7550	7863	0		
		18-22	8500		7750	7778	0		
		22-24	8500		7750	7778	0		
		00-05	8500		7750	7778	0		
SR	3rd June 2018	05-06	8500		7750	7778	0		
SK	to 09th June	06-18	8500	750	7750	7863	0		
	2018	18-22	8500		7750	7778	0		
		22-24	8500		7750	7778	0		
		00-05	9500		8750	7778	972		
	10th June 2018	05-06	9500		8750	7778	972		
	to 30th June	06-18	9500	750	8750	7863	887		
	2018	18-22	9500		8750	7778	972		
		22-24	9500		8750	7778	972		

<sup>\*</sup> Fifty Percent (50 % ) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Margin in Simultaneous import of NR = A

WR-NR ATC =B

ER-NR ATC = C

Margin for WR-NR applicants = A \* B/(B+C)Margin for ER-NR Applicants = A \* C/(B+C)

<sup>\*\*</sup>Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.

<sup>\*</sup> For approving STOA Bilateral transactions, margin available in Simultaneous Import of NR would be apportioned on WR-NR Corridor & ER-NR Corridor in the following ratio:

#### **Simultaneous Export Capability**

Corrido r	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
	1st June 2018 to	00-06	4500		3800	248	3552		
NR*	30th June 2018	06-18	4300	700	3800	368	3432		
	30th June 2018	18-24	4500		3800	248	3552		
		00-09	1710		1665		1665		
	1st June 2018	09-17	1600	45	1555	0	1555		
	1st Julie 2018	17-23	1570	43	1525		1525		
		23-24	1600		1555		1555		
		00-17	1710	45	1665	0	1665		
	2nd June 2018	17-23	1760		1715		1715		
		23-24	1710		1665		1665		
	3rd June 2018	00-08	1710	45	1665	0	1665		
NER		08-17	1600		1555		1555		
	31d Julie 2018	17-23	1570		1525		1525		
		23-24	1600		1555		1555		
	4th June 2018 to	00-17	1600	ı	1555		1555		
	9th June 2018	17-23	1570	45	1525	0	1525		
		23-24	1600		1555		1555		
	10th June 2018	00-17	1710	ı.	1665		1665		
	to 30th June	17-23	1760	45	1715	0	1715		
	2018	23-24	1710		1665		1665		
WR									
SR *	1st June 2018 to 30th June 2018	00-24	No limit is being Specified.						

<sup>\*</sup> Fifty Percent (50 % ) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

## **Limiting Constraints (Corridor wise)**

		<b>Applicable Revisions</b>
Corridor	Constraint	
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak	Rev-0 to 12
	(n-1) Contingnecy of 765kV Gwalior-Agra one ckt leads to 2750 MW loading on second circuit.	Rev-0 to 3
WR-NR	(n-1) Contingnecy of 765kV Aligarh-Jhatikara leads to 2500 MW loading on 765kV Aligarh-Greater Noida.	Rev- 4 to 6
<b>*** IX-14IX</b>	(n-1) contingency of 765/400 kV Agra ICT leads to high loading on other ICT	Rev-6 to 12
	Restriction on Mundra Mahindragarh power flow due to high loading on 765/400 kV Vadodara ICTs	Rev-6 to 12
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli	Rev-0 to 12
ER-NR	<ol> <li>N-1 contingencies of 400 kV Mejia-Maithon A S/c</li> <li>N-1 contingencies of 400 kv Kahalgaon-Banka S/c</li> <li>N-1 contingencies of 400kV MPL- Maithon S/C</li> </ol>	Rev-0 to 12
	a. (n-1) contingency of one ckt of 765 kV Wardha-Nizamabad D/C will lead to 874 MW loading on 400kV Vemagiri(PG)-Gazuwaka (When 400kV Vemagiri(PG)-Nunna S/C is not in service) b. (n-1) contingency of 400 kV Vemagiri - Vijaywada S/C will lead to high loading (874 MW) on 400 kV Vemagiri - Gazuwaka S/C (When 400 kV Vemagiri(PG) - Nunna S/C in kept in service)	Rev-0
	Low Voltage at Gazuwaka (East) Bus.	Rev-0 to 12
	n-1 contingency of 2x1500 MVA, 765/400 kV ICTs at Vemagiri (PG) will lead to overloading of the second ICT	Rev-1 to 12
ER-NER	a. (n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa b. High loading of 220 kV Balipara-Sonabil line(200 MW)	Rev-0 to 10
EK-IVEK	a. (n-1) contingency of 400kV Azara-Bonagaigaon S/c b. High loading of 220 kV Balipara-Sonabil line(200 MW)	Rev-11-12
	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other ICT at Misa	Rev-0 to 10
	a. (n-1) contingency of 400kV Azara-Bonagaigaon S/c b. High loading of 220 kV Balipara-Sonabil line(200 MW)	Rev-11-12
W3 zone Injection		Rev-0 to 11

### **Limiting Constraints (Simultaneous)**

			<b>Applicable Revisions</b>
		<ol> <li>N-1 contingencies of 400 kV Mejia-Maithon A S/c</li> <li>N-1 contingencies of 400 kV Kahalgaon-Banka S/c</li> <li>N-1 contingencies of 400 kV MPL- Maithon S/c</li> </ol>	Rev-0 to 12
NR	Import	(n-1) Contingnecy of 765kV Gwalior-Agra one ckt leads to 2750 MW loading on second circuit. (n-1) Contingnecy of 765kV Aligarh-Jhatikara leads to 2500 MW loading on 765kV Aligarh-Greater Noida.	Rev-0 to 3 Rev-4 to 6
		(n-1) contingency of 765/400 kV Agra ICT leads to high loading on other ICT	Rev-6 to 12 Rev-6 to 12
	Export	Restriction on Mundra Mahindragarh power flow due to high loading on 765/400 kV Vadodara ICTs (n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak. (n-1) contingency of 400 kV Saranath-Pusauli	Rev-0 to 12
NER	Import	<ul><li>a. (n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa</li><li>b. High loading of 220 kV Balipara-Sonabil line(200 MW)</li></ul>	Rev-0 to 12
	Export	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other ICT at Misa	Rev-0 to 12
SR	Import	a. (n-1) contingency of one ckt of 765 kV Wardha-Nizamabad D/C will lead to 874 MW loading on 400kV Vemagiri(PG)-Gazuwaka (When 400kV Vemagiri(PG)-Nunna S/C is not in service) b. (n-1) contingency of 400 kV Vemagiri - Vijaywada S/C will lead to high loading (874 MW) on 400 kV Vemagiri - Gazuwaka S/C (When 400 kV Vemagiri(PG) - Nunna S/C in kept in service)	Rev-0
		Low Voltage at Gazuwaka (East) Bus.	Rev-0 to 12
		n-1 contingency of 2x1500 MVA, 765/400 kV ICTs at Vemagiri (PG) will lead to overloading of the second ICT	Rev-1 to 12

### National Load Despatch Centre Total Transfer Capability for June 2018

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor Affected
1	23rd March 2018	Whole Month	1. Revised due to commissioning/ reconfugration of following lines: (a) Commissioning of 400kV Vijaywada(PG)-Vemagiri (PG) Ckt 2 & 3 (b) Commissioning of 400kV Vemagiri (PG)-Vemagiri (AP) 1 & 2 (c) Vemagiri (AP) end of 400 kV Simhadri II - Vemagiri (AP)- ckt 1 & 2 moved to 400 kV Vemagiri (PG) 2. With the commissioning/ reconfugration of above lines, TTC/ATC for Import of SR remains unchanged however the relative sensitivity of ER-SR and WR-SR to net import of SR has changed. The limiting constraint which was earlier (n-1) contingency of one ckt of 765 kV Wardha-Nizamabad D/C and (n-1) contingency of 400 kV Vemagiri - Vijaywada S/C has also shifted to n-1 contingency of 2x1500 MVA, 765/400 kV ICTs at Vemagiri (PG).	ER-SR/WR-SR
2	27th Mar 2018	Whole month	Revised STOA margin due to 200 MW LTA from Bokaro TPS-A of DVC to PSPCL	ER-NR/Import of NR
3	2nd April 2018	Whole month	Revised STOA margins due to change in allocation from WR-ISGS to J&K, to WR ISGS to Gujarat	WR-NR/Import of NR
4	26th April 2018	Whole month	Revised considering (a) newly commisioned 765kV Jabalpur-Orai D/C, Orai-Aliagarh D/C ,LILO 765kV Satna-Gwalior-1 S/C at Orai , 2*1000MVA 765/400kV Orai ICTs, 400kV Orai PG- Orai UP D/C , LILO of 765kV Kanpur- Jhatikara S/C at Aligarh, LILO of 765kV Agra-Greater Noida at Aligarh and (b) due to restriction on power order of HVDC Mundra - Mahindragarh bipole due to low generation at APL Mundra	WR-NR/Import of NR
5	11th May 2018	Whole Month	Revised STOA margins due to operationalization of 174 MW LTA from Teesta-III HEP to UP discoms w.e.f. 12th May 2018	ER-NR/Import of NR

6	28th May 2018	Whole Month	Revised due to: (a) Forced outage of (i) 765 kV Agra-Gwalior-S/C (ii) 765 kV Agra Aligarh S/C. (iii) 765 kV Agra-Jhatikara S/C (b) Restriction on Mundra Mohindragarh power flow due to high loading on 765/400 kV Vadodara ICTs (c) Frequent outage of HVDC Champa Kurukshetra Pole (d) Change in STOA margin due to relinquishment of 52 MW MTOA	WR-NR/Import of NR
			Revised STOA margins due to change in LTA	ER-NR/Import of NR
			Revised STOA margins due to change in LTA	ER-SR/Import of SR
			Revised STOA margins due to change in LTA	NR-WR
7	30th May 2018	01st June 18 to 09th June 18	Revised due to Continuous shutdown of 400kV Ramagundam- Chandrapur-1 and 2	WR-SR/Import of SR
8	31st May	01st June 18	Revised due to daytime shutdown of 400 kV Bongaigaon-Azara S/C	ER-NER/NER- ER/Import/Expor t of NER
8	2018	Whole Month	Revised due to change in load - generation pattern of NER and addition of Pare HEP (2*55 MW)	ER-NER/NER- ER/Import/Expor t of NER
9	31st May 2018	01st June 18	Revised due to Emergency outage of 1 Pole of HVDC Champa - Kuruksheta due to leakage in voltage divider at Kurukshetra	WR-NR/Import of NR
10	01st June 18	02nd June 18	Revised due to shutdown of 765/400kV ICT-1 at Maheshwaram	WR-SR/Import of SR
11	03rd June 18	09th June 18	Revision due to S/D of 400kV Bongaigaon-Byrnihat S/C	ER-NER/NER- ER/Import/Expor t of NER
12	05th June 18	06th June 18	Due to Continuous forced outage of HVDC Champa-Kurukshetra Pole- 2	WR-NR/Import of NR

ASSUN	MPTIONS IN BASECASE					
					Month : June'18	
S.No.	Name of State/Area	Load			Generation	
		Peak Load (MW)	Off Peak Load	(MW)	Peak (MW)	Off Peak (MW)
I	NORTHERN REGION					
1	Punjab	9707	9255		5080	5139
2	Haryana	7845	7675		2070	2070
3	Rajasthan	10903	10986		6590	6590
4	Delhi	6209	6317		979	979
5	Uttar Pradesh	17071	16516		9906	9869
6	Uttarakhand	2141	1443		1086	970
7	Himachal Pradesh	1467	785		671	477
8	Jammu & Kashmir	2576	2095		927	919
9	Chandigarh	318	220		0	0
10	ISGS/IPPs	25	25		20852	18422
	Total NR	58263	55317		48161	45435
II	EASTERN REGION					
1	Bihar	4191	2611		310	220
2	Jharkhand	1141	864		364	280
3	Damodar Valley Corporation	2804	2491		5264	3725
4	Orissa	3987	3155		3015	2450
5	West Bengal	8786	5468		5340	3720
6	Sikkim	85	85		0	0
7	Bhutan	214	220		784	582
8	ISGS/IPPs	264	258		11528	9399
	Total ER	21472	15151		26605	20377
Ш	WESTERN REGION					
1	Maharashtra	15689	15068		10238	9681
2	Gujarat	13522	13370		8045	9316
3	Madhya Pradesh	7995	6892		2889	3127
4	Chattisgarh	3509	3177		2230	2230
5	Daman and Diu	237	300		0	0
6	Dadra and Nagar Haveli	674	764		0	0
7	Goa-WR	474	326		0	0
8	ISGS/IPPs	3553	3411		39400	34704
	Total WR	45653	43308		62801	59058

S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
IV	SOUTHERN REGION				
1	Andhra Pradesh	8636	8691	6402	3978
2	Telangana	7593	5803	3899	2983
3	Karnataka	9129	6068	6560	5033
4	Tamil Nadu	14945	13659	7857	7451
5	Kerala	3635	2109	1482	129
6	Pondy	376	374	0	0
7	Goa-SR	85	84	0	0
8	ISGS/IPPs	0	0	11925	10693
	Total SR	44398	36788	38125	30267
V	NORTH-EASTERN REGION				
1	Arunachal Pradesh	137	74	0	0
2	Assam	1278	1084	228	116
3	Manipur	171	87	0	0
4	Meghalaya	281	196	192	66
5	Mizoram	102	69	8	8
6	Nagaland	122	83	22	12
7	Tripura	242	149	78	78
8	ISGS/IPPs	141	100	1995	1773
	Total NER	2475	1844	2523	2053
	Total All India	172704	152805	170054	157811
	Total All India	172704	152605	179054	13/011