

**National Load Despatch Centre  
Total Transfer Capability for June 2020**

Issue Date: 4th June 2020

Issue Time: 1800 hrs

Revision No. 9

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR-WR*	1st June 2020 to 30th June 2020	00-06	2500	500	2000	195	1805		
		06-18				1223	777		
		18-24				195	1805		
WR-NR*	1st June 2020 to 2nd June 2020	00-06	17200	500	16700	10219	6481		
			16250**		15750**	9269**			
		06-18	17200	500	16700	10608	6092		
			16250**		15750**	9658**			
		18-24	17200	500	16700	10219	6481		
			16250**		15750**	9269**			
	3rd June 2020	00-06	17200	500	16700	10219	6481		
			16250**		15750**	9269**			
		06-08	17200	500	16700	10608	6092		
			16250**		15750**	9658**			
		08-18	17100	500	16600	10608	5992		
			16150**		15650**	9658**			
	4th June 2020	18-24	17100	500	16600	10219	6381		
			16150**		15650**	9269**			
		00-06	17200	500	16700	10219	6481		
			16250**		15750**	9269**			
		06-08	17200	500	16700	10608	6092		
			16250**		15750**	9658**			
	5th June 2020	08-18	17150	500	16650	10608	6042		
			16200**		15700**	9658**			
		18-24	17150	500	16650	10219	6431		
			16200**		15700**	9269**			
		00-06	17150	500	16650	10219	6431		
			16200**		15700**	9269**			
6th June 2020 to 13th June 2020	06-08	17150	500	16650	10608	6042			
		16200**		15700**	9658**				
	08-18	17000	500	16500	10608	5892			
		16050**		15550**	9658**				
	18-24	17000	500	16500	10219	6281			
		16050**		15550**	9269**				
6th June 2020 to 13th June 2020	00-06	17200	500	16700	10219	6481			
		16250**		15750**	9269**				
	06-08	17200	500	16700	10608	6092			
		16250**		15750**	9658**				
	08-18	17000	500	16500	10608	5892	-150		
		16050**		15550**	9658**				
6th June 2020 to 13th June 2020	18-24	17000	500	16500	10219	6281	-150	Revision in TTC/ATC due to outage of 765 kV Agra - Jhatikara line along with ongoing continuous outage of 765 kV Gaya - Varanasi - I	
		16050**		15550**	9269**				

**National Load Despatch Centre  
Total Transfer Capability for June 2020**

Issue Date: 4th June 2020

Issue Time: 1800 hrs

Revision No. 9

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
	14th June 2020 to 15th June 2020	00-06	17200	500	16700	10219	6481			
			16250**		15750**	9269**				
		06-08	17200	500	16700	10608	6092			
			16250**		15750**	9658**				
	08-18	17150	500	16650	10608	6042				
		16200**		15700**	9658**					
	18-24	17150	500	16650	10219	6431				
		16200**		15700**	9269**					
	16th June 2020 to 30th June 2020	00-06	17200	500	16700	10219	6481			
			16250**		15750**	9269**				
		06-18	17200	500	16700	10608	6092			
			16250**		15750**	9658**				
18-24	17200	500	16700	10219	6481					
	16250**		15750**	9269**						
<b>NR-ER*</b>	1st June 2020 to 30th June 2020	00-06	2000	200	1800	193	1607			
		06-18	2000		1800	303	1497			
		18-24	2000		1800	193	1607			
<b>ER-NR*</b>	1st June 2020 to 2nd June 2020	00-24	5250	300	4950	4050	900			
	3rd June 2020	00-08	5250	300	4950	4050	900			
		08-24	5050	300	4750	4050	700			
	4th June 2020	00-08	5250	300	4950	4050	900			
		08-24	5050	300	4750	4050	700			
	5th June 2020	00-08	5050	300	4750	4050	700			
		08-24	5050	300	4750	4050	700			
	6th June 2020 to 13th June 2020	00-08	5250	300	4950	4050	900			
		08-24	5050	300	4750	4050	700			
	14th June 2020 to 15th June 2020	00-08	5250	300	4950	4050	900			
		08-24	5050	300	4750	4050	700			
	16th June 2020 to 30th June 2020	00-24	5250	300	4950	4050	900			
<b>W3-ER</b>	1st June 2020 to 30th June 2020	00-24	No limit is being specified.							
<b>ER-W3</b>	1st June 2020 to 30th June 2020	00-24	No limit is being specified.							

**National Load Despatch Centre  
Total Transfer Capability for June 2020**

Issue Date: 4th June 2020

Issue Time: 1800 hrs

Revision No. 9

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
WR-SR	1st June 2020 to 3rd June 2020	00-08	6950	500	6450	4035	2415			
		08-22	6950		6450		2415			
		22-24	6950		6450		2415			
	4th June 2020	00-0730	6950	500	6450	4035	2415			
		0730-22	6950		6450		2415			
		22-24	6950		6450		2415			
	5th June 2020 to 30th June 2020	00-05	6950	500	6450	4035	2415			
		05-22	6950		6450		2415			
		22-24	6950		6450		2415			
SR-WR *	1st June 2020 to 30th June 2020	00-24	4600	400	4200	550	3650			
ER-SR	1st June 2020 to 3rd June 2020	00-06	5650	250	5400	2663	2737			
		06-18	5650		5400	2748	2652			
		18-24	5650		5400	2663	2737			
	4th June 2020	00-06	5650	250	5400	2663	2737			
		06-0730	5650		5400	2748	2652			
		0730-18	4550		4300	2748	1552			
	5th June 2020 to 15th June 2020	18-24	4550	250	4300	2663	1637			
		00-06	5650		5400	2663	2737			
		06-18	5650		5400	2748	2652			
	16th June 2020 to 30th June 2020	18-24	5650	250	5400	2663	2737			
		00-06	5950		5700	2663	3037			
		06-18			5700	2748	2952			
	18-24	5700		2663	3037					
	SR-ER *	1st June 2020 to 30th June 2020	00-24	No limit is being Specified.						
	ER-NER	1st June 2020	00-02	1320	45	1275	289	986		
02-07			1320	1275		289	986			
07-12			1320	1275		334	941			
12-17			1320	1275		334	941			
17-18			1320	1275		289	986			
18-22			1050	1005		289	716			
22-23			1320	1275		289	986			
23-24			1320	1275		289	986			
ER-NER			2nd June 2020 to 3rd June 2020	00-02		1320	45	1275	289	986
	02-07	1320		1275	289	986				
	07-0730	1320		1275	334	941				
	0730-12	1050		1005	334	671				
	12-17	1050		1005	334	671				
	17-18	1050		1005	289	716				
	18-22	750		705	289	416				
	22-23	1050		1005	289	716				
	23-24	1050		1005	289	716				
ER-NER	4th June 2020 to 30th June 2020	00-02	1320	45	1275	289	986			
		02-07	1320		1275	289	986			
		07-12	1320		1275	334	941			
		12-17	1320		1275	334	941			
		17-18	1320		1275	289	986			
		18-22	1050		1005	289	716			
		22-23	1320		1275	289	986			
		23-24	1320		1275	289	986			

**National Load Despatch Centre  
Total Transfer Capability for June 2020**

Issue Date: 4th June 2020

Issue Time: 1800 hrs

Revision No. 9

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NER-ER	1st June 2020	00-02	1870	45	1825	0	1825		
		02-07	1870		1825		1825		
		07-12	1870		1825		1825		
		12-17	1870		1825		1825		
		17-18	1870		1825		1825		
		18-22	2040		1995		1995		
		22-23	1870		1825		1825		
		23-24	1870		1825		1825		
	2nd June 2020 to 3rd June 2020	00-02	1870	45	1825	0	1825		
		02-07	1870		1825		1825		
		07-0730	1870		1825		1825		
		0730-12	1700		1655		1655		
		12-17	1700		1655		1655		
		17-18	1700		1655		1655		
		18-22	1780		1735		1735		
		22-23	1700		1655		1655		
	23-24	1700	1655	1655					
	4th June 2020 to 30th June 2020	00-02	1870	45	1825	0	1825		
		02-07	1870		1825		1825		
		07-12	1870		1825		1825		
		12-17	1870		1825		1825		
		17-18	1870		1825		1825		
		18-22	2040		1995		1995		
		22-23	1870		1825		1825		
23-24		1870	1825		1825				

<b>W3 zone Injection</b>	1st June 2020 to 30th June 2020	00-24	No limit is being specified (In case of any constraints appearing in the system, W3 zone export would be revised accordingly)						
--------------------------	---------------------------------	-------	---	--	--	--	--	--	--

**Note: TTC/ATC of S1-(S2&S3) corridor, Import of S3(Kerala), Import of Punjab and Import of DD & DNH is uploaded on NLDC website under Intra-Regional Section in Monthly ATC.**

\* Fifty Percent (50 % ) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

\*\*Considering 400 kV Rihand stage-III - Vindhychal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.

1) S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala

2) W3 comprises of the following regional entities :

a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak  
f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCCL, n)Vandana Vidut o)RKM, p)GMR Raikheda, q)Ind Barath and any other regional entity generator in Chhattisgarh

# The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown :

- 1) The TTC value will be revised to normal values after restoration of shutdown.
- 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section

Though 2X315 MVA, 400/220 kV ICTs at Maradam are N-1 non-compliant, the TTC of WR-SR and ER-SR corridor has not been restricted due to the same considering that this aspect will be managed by AP SLDC through appropriate measures like SPS implemetation.

In case of drawl of Karnataka beyond 3800 MW, the voltages in Bengaluru area are observed to be critically low. This issue may be taken care of by Karnataka SLDC by taking appropriate measures.

WR-NR/Import of NR TTC has been calculated considering generation at Pariccha TPS as 350 MW. TTC figures are subject to change with significant change in generation at Pariccha TPS.

Simultaneous Import Capability									
Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR	1st June 2020 to 2nd June 2020	00-06	22450	800	21650	14269	7381		
			21500**		20700**	13319**			
		06-09	22450		21650	14658	6992		
			21500**		20700**	13708**			
		09-17	22450		21650	14658	6992		
			21500**		20700**	13708**			
		17-18	22450		21650	14658	6992		
			21500**		20700**	13708**			
		18-24	22450		21650	14269	7381		
			21500**		20700**	13319**			
NR	3rd June 2020	00-06	22450	800	21650	14269	7381		
			21500**		20700**	13319**			
		06-08	22450		21650	14658	6992		
			21500**		20700**	13708**			
		08-09	22150		21350	14658	6692		
			21200**		20400**	13708**			
		09-17	22150		21350	14658	6692		
			21200**		20400**	13708**			
		17-18	22150		21350	14658	6692		
			21200**		20400**	13708**			
18-24	22150	21350	14269	7081					
	21200**	20400**	13319**						
NR	4th June 2020	00-06	22450	800	21650	14269	7381		
			21500**		20700**	13319**			
		06-08	22450		21650	14658	6992		
			21500**		20700**	13708**			
		08-09	22200		21400	14658	6742		
			21250**		20450**	13708**			
		09-17	22200		21400	14658	6742		
			21250**		20450**	13708**			
		17-18	22200		21400	14658	6742		
			21250**		20450**	13708**			
18-24	22200	21400	14269	7131					
	21250**	20450**	13319**						

NR	5th June 2020	00-06	22200	800	21400	14269	7131		
			21250**		20450**	13319**			
		06-08	22200		21400	14658	6742		
			21250**		20450**	13708**			
		08-09	22050		21250	14658	6592		
			21100**		20300**	13708**			
		09-17	22050		21250	14658	6592		
21100**	20300**		13708**						
17-18	22050	21250	14658	6592					
	21100**	20300**	13708**						
18-24	22050	21250	14269	6981					
	21100**	20300**	13319**						
NR	6th June 2020 to 13th June 2020	00-06	22450	800	21650	14269	7381	Revision in TTC/ATC due to outage of 765 kV Agra - Jhatikara line along with ongoing continuous outage of 765 kV Gaya - Varanasi - I	
			21500**		20700**	13319**			
		06-08	22450		21650	14658	6992		
			21500**		20700**	13708**			
		08-09	22050		21250	14658	6592		-150
			21100**		20300**	13708**			
		09-17	22050		21250	14658	6592		-150
21100**	20300**		13708**						
17-18	22050	21250	14658	6592	-150				
	21100**	20300**	13708**						
18-24	22050	21250	14269	6981	-150				
	21100**	20300**	13319**						
NR	14th June 2020 to 15th June 2020	00-06	22450	800	21650	14269	7381		
			21500**		20700**	13319**			
		06-08	22450		21650	14658	6992		
			21500**		20700**	13708**			
		08-09	22200		21400	14658	6742		
			21250**		20700**	13708**			
		09-17	22200		21400	14658	6742		
21250**	20700**		13708**						
17-18	22200	21400	14658	6742					
	21250**	20700**	13708**						
18-24	22200	21400	14269	7131					
	21250**	20700**	13319**						

<b>NR</b>	16th June 2020 to 30th June 2020	00-06	22450 21500**	800	21650 20700**	14269 13319**	7381	
		06-09	22450 21500**		21650 20700**	14658 13708**	6992	
		09-17	22450 21500**		21650 20700**	14658 13708**	6992	
		17-18	22450 21500**		21650 20700**	14658 13708**	6992	
		18-24	22450 21500**		21650 20700**	14269 13319**	7381	
<b>NER</b>	1st June 2020	00-02	1320	45	1275	289	986	
		02-07	1320		1275	289	986	
		07-12	1320		1275	334	941	
		12-17	1320		1275	334	941	
		17-18	1320		1275	289	986	
		18-22	1050		1005	289	716	
		22-23	1320		1275	289	986	
		23-24	1320		1275	289	986	
<b>NER</b>	2nd June 2020 to 3rd June 2020	00-02	1320	45	1275	289	986	
		02-07	1320		1275	289	986	
		07-0730	1320		1275	334	941	
		0730-12	1050		1005	334	671	
		12-17	1050		1005	334	671	
		17-18	1050		1005	289	716	
		18-22	750		705	289	416	
		22-23	1050		1005	289	716	
		23-24	1050		1005	289	716	
<b>NER</b>	4th June 2020 to 30th June 2020	00-02	1320	45	1275	289	986	
		02-07	1320		1275	289	986	
		07-12	1320		1275	334	941	
		12-17	1320		1275	334	941	
		17-18	1320		1275	289	986	
		18-22	1050		1005	289	716	
		22-23	1320		1275	289	986	
		23-24	1320		1275	289	986	
<b>WR</b>								
<b>SR</b>	1st June 2020 to 3rd June 2020	00-06	12600	750	11850	6698	5152	
		06-18	12600		11850	6783	5067	
		18-24	12600		11850	6698	5152	
	4th June 2020	00-06	12600	750	11850	6698	5152	
		06-0730	12600		11850	6783	5067	
		0730-18	11500		10750	6783	3967	
		18-24	11500		10750	6698	4052	
	5th June 2020 to 15th June 2020	00-06	12600	750	11850	6698	5152	
		06-18	12600		11850	6783	5067	
		18-24	12600		11850	6698	5152	
	16th June 2020 to 30th June 2020	00-06	12900	750	12150	6698	5452	
		06-18	12900		12150	6783	5367	
18-24		12900	12150		6698	5452		

\* Fifty Percent (50 % ) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

\*\*Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.

\* For approving STOA Bilateral transactions, margin available in Simultaneous Import of NR would be apportioned on WR-NR Corridor & ER-NR Corridor in the following ratio:

Margin in Simultaneous import of NR = A

WR-NR ATC =B

ER-NR ATC = C

Margin for WR-NR applicants =  $A * B/(B+C)$

Margin for ER-NR Applicants =  $A * C/(B+C)$

Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section.

Though 2X315 MVA, 400/220 kV ICTs at Maradam are N-1 non-compliant, the TTC of SR Import has not been restricted due to the same considering that this aspect will be managed by AP SLDC through appropriate measures like SPS implementation.

In case of drawl of Karnataka beyond 3800 MW, the voltages in Bengaluru area are observed to be critically low. This issue may be taken care of by Karnataka by taking appropriate measures.

WR-NR/Import of NR TTC has been calculated considering generation at Pariccha TPS as 350 MW. TTC figures are subject to change with significant change in generation at Pariccha TPS.



Simultaneous Export Capability									
Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR*	1st June 2020 to 30th June 2020	00-06	4500	700	3800	388	3412		
		06-18			3800	1526	2274		
		18-24	4500		3800	388	3412		
NER	1st June 2020	00-02	1870	45	1825	0	1825		
		02-07	1870		1825		1825		
		07-12	1870		1825		1825		
		12-17	1870		1825		1825		
		17-18	1870		1825		1825		
		18-22	2040		1995		1995		
		22-23	1870		1825		1825		
		23-24	1870		1825		1825		
NER	2nd June 2020 to 3rd June 2020	00-02	1870	45	1825	0	1825		
		02-07	1870		1825		1825		
		07-0730	1870		1825		1825		
		0730-12	1700		1655		1655		
		12-17	1700		1655		1655		
		17-18	1700		1655		1655		
		18-22	1780		1735		1735		
		22-23	1700		1655		1655		
23-24	1700	1655	1655						
NER	4th June 2020 to 30th June 2020	00-02	1870	45	1825	0	1825		
		02-07	1870		1825		1825		
		07-12	1870		1825		1825		
		12-17	1870		1825		1825		
		17-18	1870		1825		1825		
		18-22	2040		1995		1995		
		22-23	1870		1825		1825		
		23-24	1870		1825		1825		
WR									
SR *	1st June 2020 to 30th June 2020	00-24	3700	400	3300	1150	2150		

\* Fifty Percent (50 % ) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section

<b>Limiting Constraints (Corridor wise)</b>			<b>Applicable Revisions</b>
<b>Corridor</b>	<b>Constraint</b>		
<b>WR-NR</b>	n-1 contingency of 765 kV Aligarh - Jhatikara Line will lead to overloading of 765 kV Aligarh - Gr. Noida Line		Rev- 0 to 1
	N-1 contingency of 1000 MVA, 765/400 kV ICT at Orai will overload the other ICT		Rev- 2 to 9
<b>NR-ER</b>	(n-1) contingency of 400 kV Saranath-Pusauli		Rev- 0 to 9
<b>ER-NR</b>	1. N-1 contingency of 400 kV Mejia-Maithon A line will overload the other ckt. 2. N-1 contingency of 400 kV Kahalgaon-Banka line will overload the other ckt. 3. N-1 contingency of 400kV MPL- Maithon line will overload the other ckt.		Rev- 0 to 9
<b>WR-SR and ER-SR</b>	n-1 contingency of one ckt of 765 kV Wardha - Nizamabad D/C will overload of the other ckt		Rev- 0 to 9
	n-1 contingency of one ckt of 765 kV Angul - Srikakulam D/C will overload of the other ckt		
	Low Voltage at Gazuwaka (East) Bus.		
<b>ER-NER</b>	a) N-1 contingency of 400 kV Bongaigaon - Azara line b) High Loading of 220 kV Salakati-BTPS Double circuit (200 MW)		Rev- 0 to 3, 5 to 9
	a) N-1 contingency of 400 kV Bongaigaon - Byrnihat line b) High Loading of 220 kV Salakati-BTPS Double circuit (200 MW)		Rev- 4
<b>NER-ER</b>	a) N-1 contingency of 400 kV Silchar- Azara line b) High Loading in Meghalya Internal Power System		Rev- 0 to 2, 4
	a) N-1 contingency of 400 kV Silchar- Azara line b) High Loading of 400 kV Silchar - Killing line		Rev- 3, 5 to 9
<b>W3 zone Injection</b>	---		Rev- 0 to 9
<b>Limiting Constraints (Simultaneous)</b>			
			<b>Applicable Revisions</b>
<b>NR</b>	<b>Import</b>	1. N-1 contingency of 400 kV Mejia-Maithon A line will overload the other ckt. 2. N-1 contingency of 400 kV Kahalgaon-Banka line will overload the other ckt. 3. N-1 contingency of 400kV MPL- Maithon line will overload the other ckt.	Rev- 0 to 9
		n-1 contingency of 765 kV Aligarh - Jhatikara Line will lead to overloading of 765 kV Aligarh - Gr. Noida Line	Rev- 0 to 1
		N-1 contingency of 1000 MVA, 765/400 kV ICT at Orai will overload the other ICT	Rev- 2 to 9
	<b>Export</b>	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak. (n-1) contingency of 400 kV Saranath-Pusauli	Rev- 0 to 9
	<b>Import</b>	a) N-1 contingency of 400 kV Bongaigaon - Azara line b) High Loading of 220 kV Salakati-BTPS Double circuit (200 MW)	Rev- 0 to 3, 5 to 9
<b>NER</b>	<b>Import</b>	a) N-1 contingency of 400 kV Bongaigaon - Byrnihat line b) High Loading of 220 kV Salakati-BTPS Double circuit (200 MW)	Rev- 4
	<b>Export</b>	a) N-1 contingency of 400 kV Silchar- Azara line b) High Loading in Meghalya Internal Power System	Rev- 0 to 2, 4
		a) N-1 contingency of 400 kV Silchar- Azara line b) High Loading of 400 kV Silchar - Killing line	Rev- 3, 5 to 9
<b>SR</b>	<b>Import</b>	n-1 contingency of one ckt of 765 kV Wardha - Nizamabad D/C will overload of the other ckt n-1 contingency of one ckt of 765 kV Angul - Srikakulam D/C will overload of the other ckt Low Voltage at Gazuwaka (East) Bus	Rev- 0 to 9

**National Load Despatch Centre  
Total Transfer Capability for June 2020**

Revision No	Date of Revision	Period of Revision	Reason for Revision/Comment	Corridor Affected
1	29th March 2020	Whole Month	1) Revision in STOA margin due to the following:- a) Operationalization of 50 MW LTA from AGEMPL (Wind, Bhuj) to Punjab b) Completion of 108 MW MTOA from SKS to NPCL (UP)  2) Revision in TTC/ATC due to change in inter-regional flow pattern towards NR.	WR-NR/NR Import
2	29th April 2020	Whole Month	Revision in TTC/ATC after after commissioning of 400 kV Aligarh (PG) - Prithala - Kadarapur - Sohna Road link and 765 kV Bikaner - Moga D/C	WR-NR/Import of NR
3	29th May 2020	Whole Month	Revision in STOA margin due to operationalization of MTOA from Rajasthan Solar to Maharashtra and MP	NR-WR/Export of NR
			a) Change in Load-Generation of NER b) Reconfiguration of 132 kV Pavoi- Sonabil S/C and 132 kV Sonabil - Gohpur S/C as 132 kV Pavoi - Gohpur 2nd line	ER-NER/NER-ER/Import and Export of NER
		1st June 2020 - 15th June 2020	Revision in TTC/ATC due to forced outage of 400/220 kV ICT-II at Jeypore	ER-SR/Import of SR
4	31st May 2020	2nd June 2020 to 3rd June 2020	Revision in TTC/ATC due to planned outage of 400 kV Bongaigaon - Azara line	ER-NER/NER-ER/Import and Export of NER
5	1st June 2020	3rd June 2020	Revised TTC due to shutdown of 765 kV Gaya Varanasi-I & 765 kV Ajmer Chittorhgarh	ER-NR/WR-NR/Import of NR
		4th June 2020 to 15th June 2020	Revised TTC due to shutdown of 765 kV Gaya Varanasi-I	ER-NR/WR-NR/Import of NR
6	2nd June 2020	4th June 2020	Revised TTC due to shutdown of 765 kV Ajmer Chittorhgarh-I	ER-NR/WR-NR/Import of NR
			Revised TTC due to shutdown of 765 kV Bus - I at Srikakulam and Parli-PG	ER-SR/WR-SR/Import of SR
7	3rd June 2020	4th June 2020	Revised TTC due to not availing shutdown of 765 kV Ajmer Chittorhgarh-I	WR-NR/Import of NR
8	3rd June 2020	5th June 2020	Revised TTC due to shutdown of 765 kV Agra-Jhatikara and 400 kV Biharshariff Varanasi D/C	WR-NR/ER-NR/Import of NR
9	4th June 2020	6th June 2020 to 13th June 2020	Revision in TTC/ATC due to outage of 765 kV Agra - Jhatikara line along with ongoing continuous outage of 765 kV Gaya - Varanasi - I	WR-NR/ER-NR/Import of NR

ASSUMPTIONS IN BASECASE					
				Month : June'2020	
S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
I	<b>NORTHERN REGION</b>				
1	Punjab	10067	9726	5031	5107
2	Haryana	8695	8519	2953	2953
3	Rajasthan	11103	11509	7197	7197
4	Delhi	5675	6190	675	675
5	Uttar Pradesh	17079	15541	9239	9284
6	Uttarakhand	2148	1875	1185	1164
7	Himachal Pradesh	1519	1293	709	627
8	Jammu & Kashmir	2948	2295	1114	1113
9	Chandigarh	328	304	0	0
10	ISGS/IPPs	25	25	21665	19179
	<b>Total NR</b>	<b>59587</b>	<b>57276</b>	<b>49768</b>	<b>47299</b>
II	<b>EASTERN REGION</b>				
1	Bihar	5009	4587	110	110
2	Jharkhand	1278	1057	425	421
3	Damodar Valley Corporation	3015	2593	5201	4318
4	Orissa	4039	4140	3508	2655
5	West Bengal	8514	7270	5621	5053
6	Sikkim	114	45	0	0
7	Bhutan	171	164	766	621
8	ISGS/IPPs	-171	-164	12531	11066
	<b>Total ER</b>	<b>21969</b>	<b>19691</b>	<b>28162</b>	<b>24243</b>
III	<b>WESTERN REGION</b>				
1	Maharashtra	18737	16633	12295	11747
2	Gujarat	15902	12455	10497	8468
3	Madhya Pradesh	9628	7772	5051	3670
4	Chattisgarh	4024	3560	1908	2133
5	Daman and Diu	311	282	0	0
6	Dadra and Nagar Haveli	761	709	0	0
7	Goa-WR	524	498	0	0
8	ISGS/IPPs	4774	3644	37337	31485
	<b>Total WR</b>	<b>54661</b>	<b>45553</b>	<b>67088</b>	<b>57504</b>

S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
IV	SOUTHERN REGION				
1	Andhra Pradesh	9605	6730	8327	6053
2	Telangana	7763	7848	4598	4644
3	Karnataka	9884	8330	7755	5857
4	Tamil Nadu	15780	13783	9577	8276
5	Kerala	3667	2269	1637	235
6	Pondy	314	265	0	0
7	Goa-SR	61	52	0	0
8	ISGS/PPs	0	0	12710	12179
	Total SR	47074	39278	44605	37244
V	NORTH-EASTERN REGION				
1	Arunachal Pradesh	121	76	8	8
2	Assam	1774	1188	284	244
3	Manipur	179	82	0	0
4	Meghalaya	276	208	215	154
5	Mizoram	100	66	8	8
6	Nagaland	126	91	16	8
7	Tripura	245	149	75	75
8	ISGS/PPs	153	82	2392	2083
	Total NER	2975	1943	2998	2580
	Total All India	186264	163742	192620	168870