Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR-WR *	1st March 2014 to 31st March 2014	00-24	2500	500	2000	361	1639		
	1st March 2014 to 4th March 2014	00-17 23-24	4200	500	3700	3656	44		
		17-23 00-08	4200		3700		44		
WR-NR <sup>1</sup>	5th March 2014	17-23 23-24	4200	500	3700	3656	44		
		08-17'	3100		2600		0		
	6th March 2014 to	00-17 23-24	4200	500	3700	3656	44		
	31st March 2014	17-23	4200	200	3700		44		
NR-ER*	1st March 2014 to 31st March 2014	00-17 23-24	1000	200	800	200	600		
	31st March 2014	17-23	1100		900		700		
	1st March 2014 to 5th March 2014	00-17 23-24 17-23	3600 3100	300	3300 2800	2789	511		
		00-08					11		
	6th March 2014	23-24	3600	300	3300	2789	511		
		17-23 08-17'	3100 3200		2800 2900	2,0,	11 111		
		00-08							
ED ND	7th March 2014	18-24	3800	300	3500	2789	711		
ER-NR	01.14 1.2014	08-18' 00-17	3200		2900		111		
	8th March 2014 to 9th March 2014	23-24	3800	300	3500	2789	711		
	yur March 2011	17-23 00-10					711		
	10th March 2014 8th March 2014 to 31st March 2014	13-24	3800	300	3500	2789	711		
		10-13'	2600		2300		0		
		00-17 23-24	3800		3500	2789	711		
		17-23					711		
		00-09	1800	300	1500	0	1500		
	1st March 2014  2nd March 2014 to	17-24 09-17'	1500	300	1200	0	1200		
		00-24	1800	300	1500	0	1500		
	8th March 2014		1000	300	1300	· ·	1300		
	9th March 2014 to	00-09 18-24	1800	300	1500	0	1500		
W3-ER	11th March 2014	09-18'	1500		1200		1200		
	124 14 1 201	00-07 19-24	1800	300	1500	0	1500		Crossing work of upcoming 765KV S/C Ranchi-Sipat line. Also for the
	13th March 2014	07'-19	1300	300	1000	0	1000	200	construction work & stringing of 400 kV Ranchi-Ranchi-II
	13th March 2014 to 31st March 2014	00-24	1800	300	1500	0	1500		
ER-W3	1st March 2014 to 31st March 2014	00-24	1000	300	700	700	0		
WR-SR	1st March 2014 to 31st March 2014	00-24	1000	0	1000	1000	0		
SR-WR *	1st March 2014 to 31st March 2014	00-24	1000	0	1000	0	1000		
		00-05	750		750		93		
ER-SR	1st March 2014 to 31st March 2014	10-19 05-10	730	0	730	657			
	313t Water 2014	19-24	750		750		93		
OD ED +	1st March 2014 to	00-17	1100	0	1100	107	903		
SR-ER *	31st March 2014 to	23-24 17-23		0	1100	197	903		
		17-23	1100		1100		903		I .

Issue Date: 1	10/03/2014	Issue Time	: 1100 nrs			Revision No. 11			
Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
	1st March 2014 to	00-17	650		600		370		
	05th March 2014	23-24		50		230			
	0041111411112011	17-23	590		540		310		
	061.36 1.0014	00-17	650		600		370		
	06th March 2014	17-23	590	50	540	230	310		
		23-24	650		600		370		
ER-NER <sup>2</sup>	7th March 2014	23-24	650	50	600	230	370		
	7 til With Cil 2014	17-23	590	30	540	250	310		
		00-09	370		210		310		
		16-17	650		600		370		
	8th March 2014	23-24		50		230			
		09-16'	350		300		70		
		17-23	590		540		310		
		00-09							
	9th March 2014 to	16-17	650		600		370		
	11th March 2014	23-24		50		230			
	111111111111111111111111111111111111111	09-16'	350		300		70		
		17-23	590		540		310		
	12th March 2014 to	00-17	650	50	600	230	370		
ER-NER <sup>2</sup>	14th March 2014	23-24	500		540				
		17-23	590		540		310		
	15th March 2014	00-17 17-23	650 720		600 670		370 440		
		23-24	720		670		440		
	16th March 2014 to 31st March 2014	00-17	720	50	070		440		
		23-24	720		670	230	440		
		17-23	720		670		440		
	1st March 2014 to 05th March 2014	00-17		100	420	0	420		
		23-24	520		420		420		
		17-23	450		350		350		
		00-17	520	100	420	0	420		
	06th March 2014	17-23	450		350		350		
		23-24	520		420		420		
MED ED	7th March 2014 to	00-17	520	100	420	0	420		
NER-ER	14th March 2014	23-24	450		250		250		
		17-23 00-17	450 520		350 420		350 420		
	15th March 2014	17-23	590	100	490	0	420		
	2011 1111011 2014	23-24	630	130	530	Ĭ	530		
	161 14 1 2017	00-17							
	16th March 2014 to	23-24	630	100	530	0	530		
	31st March 2014	17-23	590		490		490		
	1st March 2014	00-24	5650	400	5250	4900	350		
	2nd March 2014	00-06	5650	400	5250	4900	350		
S1-S2		06-24'	5350	400	4950	4900	50		
	3rd March 2014 to	00.24	5650	400	5250	4900	250		
	31st March 2014	00-24	5650	400	5250	4900	350		
Import of	1st March 2014 to								
Punjab	31st March 2014	00-24	5600	300	5300	3800	1500		
Import TTC						ITA - 134TO	A		
for DD &	1st March 2014 to	00-24	980	0	980	LTA and MTO sched			
DNH	31st March 2014					sched	iuie		
W3 zone	1st March 2014 to	00-17	9000		8800		1633		
Injection	31st March 2014	23-24		200		7167			
_		17-23	9500	TTA/MTO A	9300	the reverse directi	2133	sidered for	advanced transactions (Bilateral &

<sup>\*</sup> Fifty Percent (50 % ) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Issue Date: 10/03/2014 Issue Time: 1100 hrs Revision No. 11

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
----------	------	-------------------------	--	-----------------------	--	--	--	---	----------

- 1) ER-SR TTC declared at Talcher Interconnector and Gazuwaka HVDC B/B seam
- 2) S1 comprises of AP and Karnataka: S2 comprises of Tamil Nadu, Kerala and Pondicherry
- 3) W3 comprises of the following regional entities :
- a) Chattisgarh, b) Jindal Power Limited (JPL), c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak
- f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCL
- # The figure is based on LTA/MTOA approved by CTU. In actual Operation, due to Units being on Maintenance/ Fuel shortage the LTA/MTOA utilized would be les. RLDC/ 
  NLDC would factor this situation while issuing STOA approvals

1. WR-NR Total Transfer capability will be reduced to 3100 MW in case of outage of any one of the following sections:

• 765 kV Gwalior-Agra one circuit

2. ER-NER Total Transfer capability will be reduced to 450 MW in case of outage of any one of the 400kV Purnea-Biharshariff circuit.

#### **Limiting Constraints**

Corridor	Constraint
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.
WR-NR	High loading of 765 kV Agra-Gwalior (1000 MW SPS setting on each circuit of 765 kV Gwalior-Agra)
NR-ER	(n-1) contingency of 400 kV Allahabad-Pusauli
ER-NR	(n-1) contingency of 400 kV Kahalgaon-Biharshariff
W3-ER	(n-1) contingency of 400kV Sterilte-Rourkela S/C
ER-W3	High loading of 400 kV Raipur-Bhadrawati T/C, Bhilai-Bhadrawati S/C, Bhilai-Koradi and Bhilai-Seoni* (n-1) contingency of 400kV Raigarh-Sterlite
WR-SR &	1. Commissioning of 765kV Raichur-Sholapur S/C
ER-SR	2. Based on the operational experience after the synchronization of SR grid with NEW grid and due to inadvertent
EK-SK	3. Considering transfer capability assessment by CTU on NEW-SR corridor.
SR-WR	Bhadrawati HVDC B/B link capacity
SR-ER	
ER-NER	(n-1) contingency of 400 kV Kahalgaon-Biharshariff
NER-ER	(n-1) contingency of 315 MVA ICT at Misa
S1-S2	(n-1) contingency of 400 kV Kolar-Hosur D/C line, 400kV Hosur-Salem S/C
	and 400kV Somanahalli-Salem S/C line.
Import of Punjab	(n-1) contingency of ICT at Patiala/Moga
W3 zone Injection	(n-1) contingency of 400 kV Raipur-Wardha-Parli Section

<sup>\*</sup>Primary constraints

Simultaneous Import Capability

Simultaneous Import Capability											
Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments		
ER											
		00-17									
	1st March 2014 to	23-24	7800	800	7000	6445	555				
	4th March 2014	17-23	7300		6500		55				
		00-08	7800		7000		555				
	5th March 2014	23-24 08-17'	5800	800	5000	6445	0				
		17-23	7300		6500		55				
		00-18	7800		7000		555				
	6th March 2014	23-24		800		6445					
		08-17' 17-23	7400 7300		6600		155 55				
$NR^1$		00-08			6500						
NK	7th March 2014	18-24	8000	800	7200	6445	755				
		08-18'	7400		6600		155				
	8th March 2014	00-17	8000		7200		755				
	to 9th March 2014	23-24		800		6445					
	2014	17-23 00-10	8000		7200		755				
	10th March 2014	13-24	8000	800	7200	6445	755				
		10-13'	6800		6000	31.0	0				
	11h March 2014	00-17	8000		7200		755				
	to 31st March	23-24		800		6445					
	2014 1st March 2014	17-23	8000		7200		755				
	to 05th March	00-17 23-24	650	50	600	230	370				
		17-23	590		540		310				
	06th March 2014	00-17	650	50	600		370				
		17-23 23-24	590 650		540 600	230	310 370				
	7th March 2014	00-17		50		230					
		23-24	650		600		370				
		17-23	590		540		310				
		00-09 16-17	650	50	600	230	370				
	8th March 2014	23-24	030		000		370				
		09-16'	350		300		70				
NER <sup>2</sup>		17-23	590		540		310				
TIER	9th March 2014	00-09	(50)		600		270				
	to 11th March	16-17 23-24	650	50	600	230	370				
	2014	09-16'	350		300		70				
		17-23	590		540		310				
	12th March 2014 to 14th March	00-17	650	50	600	230	370				
	2014	23-24 17-23	590	30	540	230	310				
		00-17	650		600		370				
	15th March 2014	17-23	720	50	670	230	440				
	16th Mag-1-2014	23-24	720		670		440				
			720	50	670	230	440				
	2014	17-23	720		670	230	440				
WR											
		00-05	1750		1750		93				
SR	1st March 2014 to	1017	1150	0	1750	1657	)3				
==	518t Maich 2014		1750		1750		93				
	16th March 2014 to 31st March 2014	23-24 00-17 23-24 17-23 00-05	720 720 720 720	50	670 670 670 1750	230	440 440 440 93				

- WR-NR Total Transfer capability will be reduced to 3100 MW in case of outage of any one of the following sections:
   765 kV Gwalior-Agra one circuit

  - 765 kV Bina-Gwalior one circuit

## 2. ER-NER Total Transfer capability will be reduced to 450 MW in case of outage of any one of the 400kV Purnea-Biharshariff circuit.

### Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR*	1st March 2014 to 31st March 2014	00-17 23-24	3500	700	2800	561	2239		
		17-23	3600		2900		2339		
	1st March 2014 to 05th March	00-17 23-24	520	100	420	0	420		
	2014	17-23	450		350		350		
	06th March 2014	00-17	520	100	420	0	420		
		17-23	450		350		350		
		23-24	520		420		420		
NER	7th March 2014 to 14th March	00-17 23-24	520		420		420		
	2014	17-23	450		350		350		
		00-17	520		420		420		
	15th March 2014	17-23	590	100	490	0	490		
		23-24	630		530		530		
	16th March 2014 to 31st March	00-17 23-24	630	100	530	0	530		
	2014	17-23	590		490		490		
WR									
SR*	1st March 2014 to 31st March 2014	00-17 23-24 17-23	2100 2100	0	2100	197	1903 1903		

## **Limiting Constraints**

NR	Import	(n-1) contingency of 400 kV Kahalgaon-Biharshariff High loading of 765 kV Agra-Gwalior (1000 MW SPS setting on each circuit of 765 kV Gwalior-Agra)
	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak. (n-1) contingency of 400 kV Allahabad-Pusauli
NER	Import	(n-1) contingency of 400 kV Kahalgaon-Biharshariff
NEK	Export	(n-1) contingency of 315 MVA ICT at Misa
SR	Import	<ol> <li>Commissioning of 765kV Raichur-Sholapur S/C</li> <li>Based on the operational experience after the synchronization of SR grid with NEW grid and due to inadvertent variation of 765kV Raichur-Sholapur line flow, observation of Low Frequency Oscillations (LFO)</li> <li>Considering transfer capability assessment by CTU on NEW-SR corridor.</li> </ol>
	Export	

<sup>\*</sup>Primary constraints

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor Affected			
1	22-01-2014	Whole Month	Revised due to commissioning of 765kV Raichur-Sholapur S/C	ER-SR/ WR-SR			
		Whole	1. Revised due to shutdown of TEESTA Power Station. 2. Revised due to change in Inter-regional flow pattern & COD of Sasan UMPP Unit-2	ER-NR/ WR-NR			
2	19-02-2014	Month	Revised considering operational experience and margins on HVDC	ER-SR/ WR-SR			
			Review of flow pattern due to network topology change and Load Generation Balance.	W3 Zone Injection			
3	26-02-2014	Whole Month	,				
3	20-02-2014	01.03.14 - 06.03.14	Revised due to shutdown of 220kV Balipara - Samaguri S/C	ER-NER / NER-ER			
4	28-02-2014	01.03.14	Revised due to shutdown of 400 kV SEL-Rourkela Ckt 1	W3-ER			
5	01-03-2014	02.03.14	Revised due to shutdown of 400 kV Raichur-Gooty D/C	S1-S2			
	04-03-2014	06.03.14 - 15.03.14	Revised due to extension of 220 kV Balipara-Samaguri shutdown	ER-NER / NER-ER			
6	04-03-2014	05.03.14	Revised due to emergency shutdown of 765 kV Gwalior Bus 1	WR-NR / NR Import			
7	05-03-2014	06.03.14- 07.03.14	Revised due to shutdown of 400KV Biharshariff - Muzaffarpur D/C	ER-NR			
8	07-03-2014	08.03.14	Revised due to shutdown of 400kV Purnea-Binaguri Ckt-3 &4	ER-NER			
9	08-03-2014	09.03.14 -	Revised due to shutdown of 400kV Purnea-Binaguri Ckt-3 &4	ER-NER			
3	9 08-03-2014		Revised due to sutdown of 400 kV Rourkela - Sundergarh - 1	W3-ER			
10	09-03-2014	10.03.14	Revised due to Emergency shutdown of 400 kV Maithon-Koderma D/C	ER-NR			
11	10-03-2014	11.03.14	Crossing work of upcoming 765KV S/C Ranchi-Sipat line. Also for the construction work & stringing of 400 kV Ranchi-Ranchi-II	W3-ER			