

**National Load Despatch Centre  
Total Transfer Capability for March 2014**

Issue Date: 19/02/2014

Issue Time: 1100 hrs

Revision No. 2

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
NR-WR *	1st March 2014 to 31st March 2014	00-24	2500	500	2000	361	1639			
WR-NR <sup>1</sup>	1st March 2014 to 31st March 2014	00-17	4200	500	3700	3656	44	300	Revised due to change in Inter-regional flow pattern & COD of Sasan UMPP Unit-2	
		23-24	4200		3700		44			
NR-ER*	1st March 2014 to 31st March 2014	00-17	1000	200	800	200	600			
		23-24	1100		900		700			
ER-NR	1st March 2014 to 6th March 2014	00-17	3600	300	3300	2789	511	-200	Revised due to shutdown of TEESTA Power Station	
		23-24	3100		2800		11			-700
	7th March 2014 to 31st March 2014	00-17	3800	300	3500	2789	711			
		23-24	3800		3500		711			
W3-ER	1st March 2014 to 31st March 2014	00-24	1800	300	1500	0	1500			
ER-W3	1st March 2014 to 31st March 2014	00-24	1000	300	700	700	0			
WR-SR	1st March 2014 to 31st March 2014	00-24	1000	0	1000	1000	0	150	Revised considering operational experience and margins on HVDC	
SR-WR *	1st March 2014 to 31st March 2014	00-24	1000	0	1000	0	1000			
ER-SR	1st March 2014 to 31st March 2014	00-05	750	0	750	657	93	50	Revised considering operational experience and margins on HVDC	
		10-19	750		750		93			50
		19-24	750		750		93			50
SR-ER *	1st March 2014 to 31st March 2014	00-17	1100	0	1100	197	903			
		23-24	1100		1100		903			
ER-NER <sup>2</sup>	1st March 2014 to 31st March 2014	00-17	720	50	670	230	440			
		23-24	720		670		440			
NER-ER	1st March 2014 to 31st March 2014	00-17	630	100	530	0	530			
		23-24	590		490		490			
S1-S2	1st March 2014 to 31st March 2014	00-24	6200	400	5800	5500	300			
Import of Punjab	1st March 2014 to 31st March 2014	00-24	5600	300	5300	3800	1500			
Import TTC for DD & DNH	1st March 2014 to 31st March 2014	00-24	980	0	980	LTA and MTOA as per ex-pp schedule				
W3 zone Injection	1st March 2014 to 31st March 2014	00-17	9000	200	8800	7167	1633	500	Review of flow pattern due to network topology change and Load Generation Balance.	
		23-24	9500		9300		2133			

\* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

- 1) ER-SR TTC declared at Talcher Interconnector and Gazuwaka HVDC B/B seam
- 2) S1 comprises of AP and Karnataka; S2 comprises of Tamil Nadu, Kerala and Pondicherry
- 3) W3 comprises of the following regional entities :
  - a) Chattisgarh, b) Jindal Power Limited (JPL) , c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak
  - f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCCL

# The figure is based on LTA/MTOA approved by CTU. In actual Operation, due to Units being on Maintenance/ Fuel shortage the LTA/MTOA utilized would be less. RLDC/ NLDC would factor this situation while issuing STOA approvals

**National Load Despatch Centre  
Total Transfer Capability for March 2014**

Issue Date: 19/02/2014

Issue Time: 1100 hrs

Revision No. 2

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
----------	------	-------------------	---------------------------------	--------------------	-------------------------------------	--	--	-------------------------------------	----------

**1. WR-NR Total Transfer capability will be reduced to 3100 MW in case of outage of any one of the following sections:**

- 765 kV Gwalior-Agra one circuit
- 765 kV Bina-Gwalior one circuit

**2. ER-NER Total Transfer capability will be reduced to 450 MW in case of outage of any one of the 400kV Purnea-Biharshariff circuit.**

**Limiting Constraints**

Corridor	Constraint
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.
WR-NR	High loading of 765 kV Agra-Gwalior (1000 MW SPS setting on each circuit of 765 kV Gwalior-Agra)
NR-ER	(n-1) contingency of 400 kV Allahabad-Pusaali
ER-NR	(n-1) contingency of 400 kV Kahalgaon-Biharshariff
W3-ER	(n-1) contingency of 400kV Sterilte-Rourkela S/C
ER-W3	High loading of 400 kV Raipur-Bhadrawati T/C, Bhilai-Bhadrawati S/C, Bhilai-Koradi and Bhilai-Seoni* (n-1) contingency of 400kV Raigarh-Sterlite
WR-SR & ER-SR	1. Commissioning of 765kV Raichur-Sholapur S/C 2. Based on the operational experience after the synchronization of SR grid with NEW grid and due to inadvertent variation of 765kV Raichur-Sholapur line flow, observation of Low Frequency Oscillations (LFO) 3. Considering transfer capability assessment by CTU on NEW-SR corridor.
SR-WR	Bhadrawati HVDC B/B link capacity
SR-ER	
ER-NER	(n-1) contingency of 400 kV Kahalgaon-Biharshariff
NER-ER	(n-1) contingency of 315 MVA ICT at Misa
S1-S2	(n-1) contingency of 400 kV Kolar-Hosur D/C line, 400kV Hosur-Salem S/C and 400kV Somanahalli-Salem S/C line.
Import of Punjab	(n-1) contingency of ICT at Patiala/Moga
W3 zone Injection	(n-1) contingency of 400 kV Raipur-Wardha-Parli Section

\*Primary constraints

### Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER									
NR <sup>1</sup>	1st March 2014 to 6th March 2014	00-17 23-24	7800	800	7000	6445	555	100	1. Revised due to shutdown of TEESTA Power Station. 2. Revised due to change in Inter-regional flow pattern & COD of Sasan UMPP Unit-2
		17-23	7300		6500		55	-400	
	7th March 2014 to 31st March 2014	00-17 23-24 17-23	8000 8000	800	7200 7200	6445	755 755	300	
NER <sup>2</sup>	1st March 2014 to 31st March 2014	00-17 23-24	720	50	670	230	440		
		17-23	720		670		440		
WR									
SR	1st March 2014 to 31st March 2014	00-05 10-19	1750	0	1750	1657	93	200	Revised considering operational experience and margins on HVDC
		05-10 19-24	1750		1750		93	200	

**1. WR-NR Total Transfer capability will be reduced to 3100 MW in case of outage of any one of the following sections:**

- 765 kV Gwalior-Agra one circuit
- 765 kV Bina-Gwalior one circuit

**2. ER-NER Total Transfer capability will be reduced to 450 MW in case of outage of any one of the 400kV Purnea-Biharshariff circuit.**

### Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR*	1st March 2014 to 31st March 2014	00-17 23-24	3500	700	2800	561	2239		
		17-23	3600		2900		2339		
NER	1st March 2014 to 31st March 2014	00-17 23-24	630	100	530	0	530		
		17-23	590		490		490		
WR									
SR*	1st March 2014 to 31st March 2014	00-17 23-24	2100	0	2100	197	1903		
		17-23	2100		2100		1903		

\* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

### Limiting Constraints

NR	<b>Import</b>	(n-1) contingency of 400 kV Kahalgaon-Biharshariff High loading of 765 kV Agra-Gwalior (1000 MW SPS setting on each circuit of 765 kV Gwalior-Agra)
	<b>Export</b>	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak. (n-1) contingency of 400 kV Allahabad-Pusauli
NER	<b>Import</b>	(n-1) contingency of 400 kV Kahalgaon-Biharshariff
	<b>Export</b>	(n-1) contingency of 315 MVA ICT at Misa
SR	<b>Import</b>	1. Commissioning of 765kV Raichur-Sholapur S/C 2. Based on the operational experience after the synchronization of SR grid with NEW grid and due to inadvertent variation of 765kV Raichur-Sholapur line flow, observation of Low Frequency Oscillations (LFO) 3. Considering transfer capability assessment by CTU on NEW-SR corridor.
	<b>Export</b>	

\*Primary constraints



## ASSUMPTIONS IN BASECASE

Month : March '14

S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
<b>I</b>	<b>NORTHERN REGION</b>				
1	Punjab	5571	4510	2524	2495
2	Haryana	5755	4779	3482	3482
3	Rajasthan	8215	8320	4940	4892
4	Delhi	4102	2950	1101	1101
5	Uttar Pradesh	11500	10154	5957	5867
6	Jammu & Kashmir	2249	1725	343	567
7	Uttarakhand	1582	1397	649	580
8	Himachal Pradesh	1353	1194	367	253
9	Chandigarh	238	138	0	0
10	ISGS/IPPs			17573	11543
	<b>Total NR</b>	<b>40564</b>	<b>35167</b>	<b>36936</b>	<b>30780</b>
<b>II</b>	<b>EASTERN REGION</b>				
1	West Bengal	6600	5100	4797	4000
2	Jharkhand	1000	800	450	450
3	Orissa	3400	2600	2405	1600
4	Bihar	2000	1600	0	0
5	Damodar Valley Corporation	2600	2350	3600	3397
6	Sikkim	90	50		0
7	Bhutan	110	110	200	200
8	ISGS/IPPs	270	270	6849	6490
	<b>Total ER</b>	<b>16070</b>	<b>12880</b>	<b>18301</b>	<b>16137</b>
<b>III</b>	<b>WESTERN REGION</b>				
1	Chattisgarh	3236	2968	1629	1629
2	Madhya Pradesh	6961	5643	3847	3003
3	Maharashtra	16185	14018	11275	10527
4	Gujarat	11063	10565	10649	9002
5	Goa	422	283	0	0
6	Daman and Diu	239	240	0	0
7	Dadra and Nagar Haveli	588	552	0	0
8	ISGS/IPPs	1291	1111	18555	16029
	<b>Total WR</b>	<b>39985</b>	<b>35380</b>	<b>45955</b>	<b>40190</b>

<b>IV</b>	<b>SOUTHERN REGION</b>				
1	Andhra Pradesh	12233	9818	8014	6538
2	Tamil Nadu	11677	9714	7485	5425
3	Karnataka	8822	6821	6694	5453
4	Kerala	3378	2583	1844	916
5	Pondy	312	247		
6	Goa	80	80		
7	ISGS/IPPs			10790	9643
	<b>Total SR</b>	<b>36502</b>	<b>29263</b>	<b>34827</b>	<b>27975</b>
<b>V</b>	<b>NORTH-EASTERN REGION</b>				
1	Manipur	120	84	0	0
2	Meghalaya	300	210	90	70
3	Mizoram	70	49	4	0
4	Nagaland	110	77	12	6
5	Assam	1280	940	190	190
6	Tripura	220	130	105	100
7	Arunachal Pradesh	120	84	0	0
8	ISGS/IPPs			921	603
	<b>Total NER</b>	<b>2220</b>	<b>1574</b>	<b>1322</b>	<b>969</b>
	<b>Total All India</b>	<b>135341</b>	<b>114264</b>	<b>137341</b>	<b>116051</b>