National Load Despatch Centre Total Transfer Capability for March 2015

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR-WR *	1st March 2015 to 31st March 2015	00-24	2500	500	2000	706	1294		Margin revised due to cancellation of LTA/MTOA.
WR-NR	1st March 2015 to 31st March 2015	00-17 23-24	4900	500	4400	4768	0		
		17-23	4900		4400		0		
NR-ER*	1st March 2015 to 31st March 2015	00-06 18-24	2000	200	1800	293	1507		
	31st March 2013	06-18'	2000		1800	358	1442		
ER-NR	1st March 2015 to 31st March 2015	00-17 23-24	3100	300	2800	2431	369		
		17-23	3200		2900		469		
W3-ER ^{\$}	1st March 2015 to 31st March 2015	00-24	1800	300	1500	351	1149		
ER-W3	1st March 2015 to 31st March 2015	00-24	1000	300	700	874	0		Margin revised due to cancellation of LTA/MTOA.
WR-SR	1st March 2015 to 31st March 2015	00-24	2100	750	1350	1350	0		
SR-WR *	1st March 2015 to 31st March 2015	00-24				No limit i	s being Specified.		
		00-06						1	
ER-SR	1st March 2015 to 31st March 2015	18-24 06-18'	2650	0	2650	2585 2650	65		
SR-ER*	1st March 2015 to 31st March 2015	00-24					s being Specified.	l	
ER-NER	1st March 2015 to 31st March 2015	00-17 23-24	650	40	610	210	400		
NER-ER	1st March 2015 to	17-23 00-17 23-24	560 530	30	520 500	0	310 500		
NEK-EK	31st March 2015	17-23	560	40	520	1	520		
		1. 23			520				
S1-S2	1st March 2015 to 31st March 2015	00-24	3065	300	2765	2775	0		
Import of Punjab	1st March 2015 to 31st March 2015	00-24	5700	300	5400	3790	1610		
Import TTC for DD & DNH	1st March 2015 to 31st March 2015	00-24	1200	0	1200		OA as per ex-pp edule		
W3 zone Injection	1st March 2015 to 31st March 2015	00-17 23-24	9400	200	9200	6862	2338		
injection	51st Water 2015	17-23	9900		9700		2838		

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

National Load Despatch Centre Total Transfer Capability for March 2015

Issue Date: 12/02/2015 Issue Time: 1630 hrs Revision No. 2

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
----------	------	-------------------------	------------------------------------------	-----------------------	----------------------------------------------	----------------------------------------------------------------------	----------------------------------------------------------------	-------------------------------------------------	----------

^{\$} As per Simulations, predominant direction of flow is on West to North Corridor. Hence, in case injection point is in Western Region (W1,W2,W3), STOA/PX transactions from West to North on West-East-North corridor shall not be allowed as such transaction increases congestion in the West to North Corridor.

- 1) ER-SR TTC declared at Talcher Interconnector and Gazuwaka HVDC B/B seam
- 2) S1 comprises of AP and Karnataka: S2 comprises of Tamil Nadu, Kerala and Pondicherry
- 3) W3 comprises of the following regional entities:
- a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak
- f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCL, n) Vandana Vidyut

The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/Fuel shortage/New units being commissionned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown :

- 1) The TTC value will be revised to normal values after restoration of shutdown.
- 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

Limiting Constraints

Corridor	Constraint							
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.							
WR-NR	High Loading of 400kV Singrauli-Anpara & High loading of 765 kV Agra-Gwalior (1250 MW SPS setting on each circuit of 765 kV Gwalior-Agra) and Loop flows on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda (power flowing from WR to NR on 765kV Gwalior-Agra D/C and from NR to WR on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda).							
NR-ER	()							
ER-NR	(n-1) contingnecy of Kahalgaon-Banka S/C							
W3-ER	i. (n-1) Contingency of 400 kV MPL-Maithon S/Cii. (n-1) contingency of 400kV Sterlite-Rourkela S/C							
ER-W3	(n-1) contingency of 400kV Raigarh-Jharsuguda-Rourkela							
WR-SR & ER-SR	(n-1) contingency of one circuit of 400kV Parli(PG)-Sholapur(PG) ER-SR TTC has been declared assuming more than 1100 MW generation at Talcher Stage-2. In case Talcher Stage-2 generation goes below 1100 MW, then the ER-SR TTC would be revised downward as constraints within ER would emerge.							
ER-NER	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA ICT at Misa							
NER-ER	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA ICT at Misa							
S1-S2	(n-1) contingency of one circuit of 400 kV Kolar-Hosur							
Import of DD & DNH	(n-1) contingency of 400/220KV 315MVA ICT at VAPI							
Import of Punjab	(n-1) contingency of ICT at Dhuri and (n-1) contingnecy of 220kV Moga(PG)-Moga(PSTCL)							
W3 zone Injection	(n-1-1) contingency of 400 kV Raipur-Bhadrawati D/C section and High loading of 400kV Raipur-Wardha (850 MW SPS setting on each circuit of 400kV Raipur-Wardha)							
	*Primary constraints							

^{*}Primary constraints

Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER									
NR	1st March 2015 to 31st March 2015	00-17 23-24 17-23	8000 8100	800	7200 7300	6811	389 489		
NER	1st March 2015 to 31st March 2015	00-17 23-24 17-23	650	40	610	210	400		
WR									
SR	1st March 2015 to 31st March 2015	00-06 18-24	4750	750	4000	3935	65		
	518t March 2015	06-18'	4750		4000	4000	0		

Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
NR*	1st March 2015 to 31st March 2015	00-06 18-24	4500	700	3800	999	2801		Margin revised due to cancellation of LTA/MTOA.	
	518t Watell 2015	06-18'			3800	1064	2736		concension of ETA, WITOA.	
NER	1st March 2015 to 31st March 2015	00-17 23-24	530	30	500	0	500			
		17-23	560	40	520		520			
WR										
WK										
SR *	1st March 2015 to 31st March 2015	00-24		No limit is being Specified.						

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Limiting Constraints

	,	
		(n-1) contingnecy of Kahalgaon-Banka S/C
		High loading of 765 kV Agra-Gwalior (1250 MW SPS setting on each circuit of 765 kV Gwalior-Agra) and high loop
NR	Import	flows on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda (power flowing from WR to NR on 765kV Gwalior-Agra
INK		D/C and from NR to WR on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda).
	T .	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.
	Export	(n-1) contingency of 400 kV Saranath-Pusauli
NER	Import	(n-1) contingnecy of Kahalgaon-Banka S/C
NEK	Export	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other ICT at Misa
	-	1. (n-1) contingency of one circuit of 400kV Parli(PG)-Sholapur(PG)
SR	.	2. ER-SR TTC has been declared assuming more than 1100 MW generation at Talcher Stage-2. In case Talcher Stage-
SK	Import	2 generation goes below 1100 MW, then the ER-SR TTC would be revised downward as constraints within ER would
		emerge.

^{*}Primary constraints

National Load Despatch Centre Total Transfer Capability for March 2015

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor Affected
1	29-12-2014	Whole Month	Margin revised due to change in LTA/MTOA.	NR-WR/ER- W3/W3-ER
		MOHUH	Margin revised due to COD of Sasan Unit-5.	WR-NR
2	12-02-2015	Whole Month	Margin revised due to cancellation of LTA/MTOA	NR-WR/ER- W3

ASSUMPTIONS IN BASECASE

Month: Mar '15

	Widhth: Wai 13								
		Lo	ad	Generation					
S.No.	Name of State/Area	Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)				
I	NORTHERN REGION								
1	Punjab	4960	3131	2800	2520				
2	Haryana	5400	3758	1864	1677				
3	Rajasthan	9200	8267	4974	4974				
4	Delhi	3600	1700	935	935				
5	Uttar Pradesh	10650	11162	5443	5443				
6	Jammu & Kashmir	1850	1994	244	244				
7	Uttarakhand	1650	1115	507	190				
8	Himachal Pradesh	1186	812	177	64				
9	Chandigarh	189	97	0	0				
10	ISGS/IPPs			15776	10793				
	Total NR	38685	32036	32720	26840				
II	EASTERN REGION								
1	West Bengal	5218	5202	3734	3802				
2	Jharkhand	985	749	427	435				
3	Orissa	3677	2354	1597	1625				
4	Bihar	2216	1605	104	106				
5	Damodar Valley Corporation	2561	2354	3211	3269				
6	Sikkim	79	43						
7	Bhutan	107	107	110	110				
8	ISGS/IPPs	513	511	8144	8100				
	Total ER	15356	12925	17327	17447				
III	WESTERN REGION								
1	Chattisgarh	3117	2765	1915	2062				
2	Madhya Pradesh	10300	5308	5801	1000				
3	Maharashtra	20963	13907	16531	8763				
4	Gujarat	11198	10475	8946	7757				
5	Goa	425	339						
6	Daman and Diu	262	252						
7	Dadra and Nagar Haveli	608	596						
8	ISGS/IPPs	1070	1070	22377	21836				
	Total WR	47943	34712	55570	41418				

ASSUMPTIONS IN BASECASE

Month: Mar '15

	Month. Mar 13								
		Lo	ad	Generation					
S.No.	Name of State/Area	Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)				
IV	SOUTHERN REGION								
1	Telangana	6171	5323	3075	2367				
2	Andhra Pradesh	5675	4894	5324	4762				
3	Tamil Nadu	11093	9415	6869	5865				
4	Karnataka	7684	6791	6896	4852				
5	Kerala	3532	2358	2331	873				
6	Pondy	335	266						
7	Goa	89	87						
8	ISGS/IPPs			7730	7730				
	Total SR	34579	29134	32225	26449				
V	NORTH-EASTERN REGION								
1	Arunachal Pradesh	66	33	0	0				
2	Assam	713	609	220	190				
3	Manipur	74	49	0	0				
4	Meghalaya	166	84	77	17				
5	Mizoram	51	34	6	4				
6	Nagaland	57	52	7	3				
7	Tripura	227	153	103	100				
8	ISGS/IPPs			1089	680				
	Total NER	1354	1015	1502	994				
	Total All India	407047	400004	100011	440440				
	Total All India	137917	109821	139344	113148				