Issue Date:	28th January 2	2020	Issu	e Time: 180	0 hrs		R	Revision No	. 2
Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
	1st March 2021	00-06				195	1805		
NR-WR*	to 31st March	06-18	2500	500	2000	1281	719		
	2021	18-24				195	1805		
		00-06	17850 16900**	500	17350 16400**	10800 9850**	6550		a) Revision in STOA margin of WR-NR/Import of NR due to change in LTA quantum from RWE_APL2_SECI-III (Ghadsisa, Wind) to Haryana from earlier 160 MW to 212.19 MW.
WR-NR*	1st March 2021 to 31st March 2021	06-18	17850 16900**	500	17350 16400**	11189 10239**	6161		 b) Revision in STOA margin of WR-NR/Import of NR due to change in LTA quantum from ALFANAR_SECI-III to BYPL & BRPL from earlier 39.1 MW to 41.9
		18-24	17850 16900**	500	17350 16400**	10800 9850**	6550		MW respctively.
			1						
NR-ER*	1st March 2021 to 31st March 2021	00-06 06-18 18-24	2000 2000 2000	200	1800 1800 1800	193 303 193	1607 1497 1607	-	
ER-NR*	1st March 2021 to 31st March 2021	00-24	5500	300	5200	4066	1134		
W3-ER	1st March 2021 to 31st March 2021	00-24				No limit i	s being specified.		
ER-W3	1st March 2021 to 31st March 2021	00-24				No limit i	s being specified.		
	1st March 2021	00-05	8000		7500		3427		
WR-SR [^]	to 31st March	05-22	8000	500	7500	4073	3427		
SR-WR *	2021 1st March 2021 to 31st March 2021	22-24 00-24	8000 4600	400	7500 4200	550	3427 3650		
	1.34	00-06				2673	2977		
ER-SR [▲]	1st March 2021 to 31st March	06-18	5900	250	5650	2758	2892		-
LINDA	2021	18-24			2 30 0	2673	2977		
SR-ER *	1st March 2021 to 31st March 2021	00-24					s being Specified.		
		00-02	1120		1075	474	601		
	1st March 2021	02-07	1120		1075	474	601]	
ER-NER*	to 31st March	07-12 12-17	1150 1200	45	1105 1155	474 474	631 681	+	
	2021	12-17	870		825	474	351	+	
		23-24	1120		1075	474	601	1	
		00-02	2700		2655	83	2572		• LTA figure revised by 41.5
	1st March 2021	02-07 07-12	2700 2820		2655 2775	83 83	2572 2692	+	MW after declaration of
	15t march 2021	07-12	2820		2115	0.5	2092	1	

Issue Date:	Issue Date: 28th January 2020			Issue Time: 1800 hrs			Revision No. 2			
Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
NER-ER*	to 31st March 2021	12-17	2800	45	2755	83	2672		commercial operation of Kameng HEP (4x150MW) unit	
		17-23	2850		2805	83	2722		3 w.e.f 00:00Hrs of 22.01.2021	
		23-24	2700		2655	83	2572		5 men 00.001115 01 22.01.2021	
								1	1	

	Total Transfer Capability for March 2021										
Issue Date:	28th January 2	2020	Issu	e Time: 180	0 hrs		R	Revision No.	. 2		
Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments		
W3 zone Injection	1st March 2021 to 31st March 2021	00-24		No limit is being specified (In case of any constraints appearing in the system, W3 zone export would be revised accordingly)							
	ATC of S1-(S2& Ionthly ATC.	S3) corrid	or, Import of	S3(Kerala), Iı	nport of Punj	ab and Import of	DD & DNH is up	loaded on NI	LDC website under Intra-Regional		
* Fifty Perce First Come F		er flow ben	efit on account	of LTA/MTO	A transactions	in the reverse direc	ction would be con	sidered for ad	vanced transactions (Bilateral &		
	ng 400 kV Rihand Rihand stage-III						e of scheduling, me	etering and acc	counting and 950 MW ex-bus		
2) W3 compra) Chattisgarff) BALCO, g)and any other# The figureFuel shortage	 1) S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala 2) W3 comprises of the following regional entities : a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCL, n)Vandana Vidyut o)RKM, p)GMR Raikheda, q)Ind Barath and any other regional entity generator in Chhattisgarh # The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissionned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. 										
In case of TT 1) The TTC 2) The TTC	C Revision due t value will be revi value will be revi rC/ATC revision	o any shutc sed to norr sed to norr	down : nal values afte nal values if th	r restoration of e shutdown is	shutdown. not being avai						
	315 MVA, 400/2 ect will be manage						ER-SR corridor ha	s not been res	tricted due to the same considering		
	^In case of drawl of Karnataka beyond 3800 MW, the voltages in Bengaluru area are observed to be critically low. This issue may be taken care of by Karnataka SLDC by taking appropriate measures.										
SR-WR TTC Kudgi TPS.	SR-WR TTC/ATC figures have been calculated considering 01 unit (800 MW) at Kudgi TPS in service. The figures are subject to change with change in generation at Kudgi TPS.										
WR-NR/Import of NR TTC has been calculated considering generation at Pariccha TPS as 350 MW. TTC figures are subject to change with significant change in generation at Pariccha TPS.											

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
		00-06	23350		22550	14866	7684			
		00-00	22400**		21600**	13916**	/084			
		06-09	23350 22400**		22550 21600**	15255 14305**	7295		a) Revision in STOA margi of WR-NR/Import of NR due t change in LTA quantum from RWE_APL2_SECI-III (Ghadsisa, Wind) to Haryana from earlier 160 MW to 212.19 MW.	
NR [*]	1st March 2021 to 31st March 2021	09-17	23350 22400**	800	22550 21600**	15255 14305**	7295		b) Revision in STOA margi of WR-NR/Import of NR due t change in LTA quantum from ALFANAR_SECI-III to BYPL & BRPL from earlier 39.1 MW to 41.9 MW respctively.	
		17-18	23350 22400**		22550 21600**	15255 14305**	7295			
		18-24	23350 22400**		22550 21600**	14866 13916**	7684			
		00-02	1120		1075	474	601			
	1 at Manah 2021	02-07	1120		1075	474	601			
NED*	1st March 2021	07-12	1150	45	1105	474	631			
NER [*]	to 31st March	12-17	1200	45	1155	474	681	1		
	2021	2021	17-23	870		825	474	351		
		23-24	1120		1075	474	601			
WR [*]									-	
	Lat March 2021	00.04	12000		12150	6716	6101			
SR ^{*#}	1st March 2021 to 31st March	00-06	13900 13900	750	13150 13150	6746 6831	6404 6319		4	
эк	2021	06-18 18-24	13900	750	13150	6746	6404		4	
Bilateral &	cent (50 %) Coun z First Come First	ter flow b Serve).	enefit on acco		/ITOA transac	tions in the revers	e direction woul		red for advanced transactions	

in the following ratio: Margin in Simultaneous import of NR = A WR-NR ATC =B ER-NR ATC = C

Margin for WR-NR applicants = A * B/(B+C) Margin for ER-NR Applicants = A * C/(B+C)

Past Time TTC/ATC revisions are unloaded on POSOCO/NI DC "News Undate" (Flacher) Section

Kear Time TTC/ATC revisions are uploaded on FOSOCO/INEDC TNEWS Opdate (Fiasher) Section

#Though 2X315 MVA, 400/220 kV ICTs at Maradam are N-1 non-compliant, the TTC of SR Import has not been restricted due to the same considering that this aspect will be managed by AP SLDC through appropriate measures like SPS implementation.

In case of drawl of Karnataka beyond 3800 MW, the voltages in Bengaluru area are observed to be critically low. This issue may be taken care of by Karnataka by taking appropriate measures.

WR-NR/Import of NR TTC has been calculated considering generation at Pariccha TPS as 350 MW. TTC figures are subject to change with significant change in generation at Pariccha TPS.

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
	1st March 2021	00-06	4500		3800	388	3412		
NR*	to 31st March	06-18	4300	700	3800	1584	2216		
	2021	18-24	4500		3800	388	3412		
		00-02	2700		2655	83	2572		 LTA figure revised by
	1st March 2021	02-07	2700	45	2655	83	2572		41.5 MW after declaration
NER*	to 31st March	07-12	2820		2775	83	2692		of commercial operation of
INER -	2021	12-17	2800		2755	83	2672		Kameng HEP (4x150MW)
	2021	17-23	2850		2805	83	2722		unit-3 w.e.f 00:00Hrs of
		23-24	2700		2655	83	2572		22.01.2021
WR*									
,,									
SR*^	1st March 2021 to 31st March 2021	00-24	3700	400	3300	1150	2150		

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section

^SR Export TTC/ATC figures have been calculated considering 01 unit (800 MW) at Kudgi TPS in service. The figures are subject to change with change in generation at Kudgi TPS.

Limiting	Constraints (Corridor wise)	
		Applicable Revisions
Corridor	Constraint	
WR-NR	N-1 contingency of 1000 MVA, 765/400 kV ICT at Orai will overload the other ICT	Rev- 0 to 2
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli	Rev- 0 to 2
ER-NR	 N-1 contingency of 400 kV Mejia-Maithon A line will overload the other ckt. Inter-regional flow pattern towards NR 	Rev- 0 to 2
WR-SR and ER-	N-1 of one ICT of 765/400 kV, 1500 MVA ICT at Nizamabad will overload the other ICT	Rev-0 to 2
	Low Voltage at Gazuwaka (East) Bus.	- Kev- 0 to 2
	a) N-1 contingency of one ckt of 400 kV Kolhapur-PG - Kolhapur-MS D/C will overload of the other ckt b) N-1 contingency of 500 MVA ICT at 400 kV Kolhapur-MS will overload the other 2x315 MVA ICTs	Rev- 0 to 2
ER-NER	 a) N-1 contingency of 400 kV Bongaigaon - Azara line b) High Loading of 220 kV Salakati - BTPS D/C 	Rev- 0 to 2
NER-ER	 a) N-1 contingency of 400 kV Silchar- Azara line b) High Loading of Internal System of Meghalaya 	Rev- 0 to 2
W3 zone Injection		Rev- 0 to 2

Limiting Constraints (Simultaneous)

			Applicable Revisions
	Import	 N-1 contingency of 400 kV Mejia-Maithon A line will overload the other ckt. Inter-regional flow pattern towards NR 	Rev- 0 to 2
NR		N-1 contingency of 1000 MVA, 765/400 kV ICT at Orai will overload the other ICT	Rev- 0 to 2
	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak. (n-1) contingency of 400 kV Saranath-Pusauli	Rev- 0 to 2
NER	Import	 a) N-1 contingency of 400 kV Bongaigaon - Azara line b) High Loading of 220 kV Salakati - BTPS D/C 	Rev- 0 to 2
NEK	Export	a) N-1 contingency of 400 kV Silchar- Azara lineb) High Loading of Internal System of Meghalaya	Rev- 0 to 2
SR	Import	N-1 of one ICT of 765/400 kV, 1500 MVA ICT at Nizamabad will overload the other ICT Low Voltage at Gazuwaka (East) Bus	Rev- 0 to 2
эк	Export	N-1 contingency of one ckt of 400 kV Kolhapur-PG - Kolhapur-MS D/C will overload of the other ckt N-1 contingency of 500 MVA ICT at 400 kV Kolhapur-MS will overload the other 2x315 MVA ICTs	Rev- 0 to 2

Revision No	Date of Revision	Period of Revision	Reason for Revision/Comment	Corridor Affected
1	28th Dec 2020		 a) Revision in STOA margin due to change in LTA Quantum from RWE_APL2_SECI-III (Ghadsisa, Wind) to Haryana from earlier 95 MW to 160 MW. b) Revision in TTC/ATC due to change in direction of HVDC BNC-AGRA as per grid requirement 	WR-NR/Import of NR
2	28th Jan 2021	Whole Month	• LTA figure revised by 41.5 MW after declaration of commercial operation of Kameng HEP (4x150MW) unit-3 w.e.f 00:00Hrs of 22.01.2021	NER-ER/NER Export

ASSUN	IPTIONS IN BASECASE				
				Month : March 2021	
S.No.	Name of State/Area		Load	Genera	tion
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
Ι	NORTHERN REGION				
1	Punjab	7082	5944	3303	3219
2	Haryana	6885	6321	1819	1819
3	Rajasthan	11247	11020	7767	7739
4	Delhi	5022	3487	672	672
5	Uttar Pradesh	14329	15067	8642	8612
6	Uttarakhand	1773	1733	886	604
7	Himachal Pradesh	1015	861	190	139
8	Jammu & Kashmir	1494	1461	109	109
9	Chandigarh	251	159	0	0
10	ISGS/IPPs	19	19	14286	11153
	Total NR	49117	46071	37675	34067
П	EASTERN REGION				
1	Bihar	4849	3097	352	344
2	Jharkhand	1502	1034	378	353
3	Damodar Valley Corporation	2755	2556	4353	3476
4	Orissa	3582	2895	2946	2400
5	West Bengal	6439	4457	4879	3510
6	Sikkim	112	45	0	0
7	Bhutan	162	168	270	214
8	ISGS/IPPs	-162	-168	12566	8973
	Total ER	19239	14083	25743	19269
	WESTERN REGION				
1	Maharashtra	18778	13739	12230	9486
2	Gujarat	15979	11721	11083	7999
3	Madhya Pradesh	15354	7101	7911	4031
4	Chattisgarh	4046	2689	2384	1953
5	Daman and Diu	339	292	0	0
6	Dadra and Nagar Haveli	814	774	0	0
7	Goa-WR	625	390	0	0
8	ISGS/IPPs	4017	3424	41810	30230
-	Total WR	59952	40130	75417	53699

S.No.	Name of State/Area		Load	Gener	ation
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
IV	SOUTHERN REGION				
1	Andhra Pradesh	9090	5024	6476	5986
2	Telangana	9542	10582	4884	4648
3	Karnataka	10315	5023	8110	3639
4	Tamil Nadu	14023	10332	6537	5162
5	Kerala	3838	2287	1665	95
6	Pondy	303	309	0	0
7	Goa-SR	47	48	0	0
8	ISGS/IPPs	0	0	13941	10412
	Total SR	47158	33605	41613	29942
V	NORTH-EASTERN REGION				
1	Arunachal Pradesh	105	66	12	8
2	Assam	1192	861	288	243
3	Manipur	224	109	0	0
4	Meghalaya	322	266	230	189
5	Mizoram	117	67	48	28
6	Nagaland	121	94	8	8
7	Tripura	225	135	75	75
8	ISGS/IPPs	139	85	2580	2126
	Total NER	2444	1683	3241	2676
	Total All India	177771	135487	183689	139653