National Load Despatch Centre Total Transfer Capability for March 2022

Issue Date: 4th January 2022 Issue Time: 1700 hrs Revision No. 2

Library Date.	. 4111 January 2		1550	e Time. 170	J 111 5		IX.	evision ivo.	· -
Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
		00-06				628	1372		
NR-WR*	1st March 2022 to 31st March 2022	06-18	2500	500	2000	1856	144		
		18-24				628	1372		
			10500		18500	11433			
		00-06	19500 18550**	1000	17550**	10483**	7067		
	1st March 2022		19500		18500	11822			
WR-NR*	to 31st March 2022	06-18	18550**	1000	17550**	10872*	6678		
			19500		18500	11433			
		18-24	18550**	1000	17550**	10483**	7067		
		00-06	2000	Ι	1800	93	1707		
NR-ER*	1st March 2022 to 31st March	06-18	2000	200	1800	1308	492		
	2022	18-24	2000	200	1800	93	1707		
ER-NR*	1st March 2022 to 31st March 2022	00-24	5900	400	5500	4356	1144		
W3-ER	1st March 2022 to 31st March 2022	00-24						No limit is	being specified.
ER-W3	1st March 2022 to 31st March 2022	00-24						No limit is	being specified.
	1st March 2022	00-05	11600		10950		6832	1250	
WR-SR	to 31st March 2022	05-22	11600	650	10950	4118	6832	1250	TTC/ATC Revised after commissioning of HVDC Raigarh - Pugalur Pole - IV
SR-WR *	1st March 2022 to 31st March 2022	22-24 00-24	7400	400	10950 7000	983	6832 6017	1250 2800	TTC/ATC Revised after commissioning of HVDC Raigarh - Pugalur Pole - IV
	2022								
ED CD ⁴	1st March 2022 to 31st March	00-06	5700	350	5350	2675	2675	-100	TTC/ATC Revised after commissioning of HVDC Raigarh - Pugalur Pole - IV
ER-SR [*]	2022	06-18 18-24	3700	330	3330	2760	2590	-100	110/A10 Revised after commissioning of TVDC Raigain - rugalur Pole - IV
SR-ER *	1st March 2022 to 31st March	00-24				2675 2675 -100 No limit is being Specified.			
	2022								
		00-02 02-07	930 930		885 885	455 455	430 430		
ER-NER*	1st March 2022 to 31st March	07-12	910	45	865	455	410		
	2022	12-18 18-22	915 680	15	870 635	455 455	415 180		
		22-24	930		885	455	430		
		00-02	3375		3330 3330	81	3249 3249	-	
	1st March 2022	02-07 07-12	3375 3350	,-	3330	81 81	3249 3224		
NER-ER*	to 31st March 2022	12-18	3320	45	3275	81	3194		
	LVLL	18-22 22-24	3270 3375		3225 3330	81 81	3144 3249		
		22-24	3313		3330	01	3247		

National Load Despatch Centre Total Transfer Capability for March 2022

Issue Date: 4th January 2022 Issue Time: 1700 hrs Revision No. 2

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
W3 zone Injection	1st March 2022 to 31st March 2022		No limit is be	ing specified (In case of any	constraints appear	ing in the system,	W3 zone exp	oort would be revised accordingly)

Note: TTC/ATC of S1-(S2&S3) corridor, Import of S3(Kerala), Import of Punjab and Import of DD & DNH is uploaded on NLDC website under Intra-Regional Section in Monthly ATC.

Fifty Percent (50%) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

**Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.

- 1) S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala
- 2) W3 comprises of the following regional entities :
- a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak
- f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCL, n)Vandana Vidyut o)RKM, p)GMR Raikheda, q)Ind Barath and any other regional entity generator in Chbattis part
- # The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/Fuel shortage/New units being commissionned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis.

 In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.
- In case of TTC Revision due to any shutdown:
- 1) The TTC value will be revised to normal values after restoration of shutdown.
- 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section

^Though 2X315 MVA, 400/220 kV ICTs at Maradam are N-1 non-compliant, the TTC of WR-SR and ER-SR corridor has not been restricted due to the same considering that this aspect will be managed by AP SLDC through appropriate measures like SPS implementation.

'In case of drawl of Karnataka beyond 3800 MW, the voltages in Bengaluru area are observed to be critically low. This issue may be taken care of by Karnataka SLDC by taking appropriate measures.

SR-WR TTC/ATC figures have been calculated considering 01 unit (800 MW) at Kudgi TPS in service. The figures are subject to change with change in generation at Kudgi TPS.

WR-NR/Import of NR TTC has been calculated considering generation at Pariccha TPS as 350 MW. TTC figures are subject to change with significant change in generation at Pariccha TPS.

Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
		00-06	25400 24450**		24000 23050**	15789 14839**	8211		
		06-09	25400		24000	16178	7822		
	1-4 M 2022		24450**		23050**	15228**			
NR	1st March 2022 to 31st March 2022	09-17	25400	1400	24000	16178	7822		
			24450**		23050**	15228**			
		17-18	25400		24000	16178	7822		
			24450**		23050**	15228**			
		18-24	25400		24000	15789	8211		
			24450**		23050**	14839**			
		00-02	930		885	455	430		
	1st March 2022	02-07	930		885	455	430		
NER*	to 31st March	07.12	910	45	865	455	410		
NEK	2022	12-18	915	15	870	455	415		
		18-22	680		635	455	180		
		22-24	930		885	455	430		
WR*									
	1st March 2022	00-06	17300		16300	6793	9507	1150	
SR*#	to 31st March	06-18	17300	1000	16300	6878	9422	1150	TTC/ATC Revised after commissioning of HVDC Raigarh - Pugalur Pole - IV
	2022	18-24	17300		16300	6793	9507	1150	

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Margin in Simultaneous import of NR = A

WR-NR ATC =B

ER-NR ATC = C

Margin for WR-NR applicants = A * B/(B+C)

Margin for ER-NR Applicants = A * C/(B+C)

Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section

#Though 2X315 MVA, 400/220 kV ICTs at Maradam are N-1 non-compliant, the TTC of SR Import has not been restricted due to the same considering that this aspect will be managed by AP SLDC through appropriate measures like SPS implementation.

In case of drawl of Karnataka beyond 3800 MW, the voltages in Bengaluru area are observed to be critically low. This issue may be taken care of by Karnataka by taking appropriate measures.

WR-NR/Import of NR TTC has been calculated considering generation at Pariccha TPS as 350 MW. TTC figures are subject to change with significant change in generation at Pariccha TPS.

^{**}Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW exbus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.

^{*} For approving STOA Bilateral transactions, margin available in Simultaneous Import of NR would be apportioned on WR-NR Corridor & ER-NR Corridor in the following ratio:

Simultane	imultaneous Export Capability									
Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
NR*	1st March 2022 to 31st March 2022	00-06	4500	700	3800	721 3164	3079 636			
	2022	18-24				721	3079			
		00-02	3375		3330	81	3249			
		02-07	3375	- 45	3330	81	3249			
NER*	1st March 2022 to 31st March	07-12	3350		3305	81	3224			
NEK.	2022	12-18	3320		3275	81	3194			
		18-22	3270		3225	81	3144			
		22-24	3375		3330	81	3249			
WR*										
SR*^	1st March 2022 to 31st March 2022	00-24	6350	400	5950	1804	4146	2650	TTC/ATC Revised after commissioning of HVDC Raigarh - Pugalur Pole - IV	

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section

^SR Export TTC/ATC figures have been calculated considering 01 unit (800 MW) at Kudgi TPS in service. The figures are subject to change with change in generation at Kudgi TPS.

		Applicable Revisions
Corridor	Constraint	
WR-NR	N-1 contingency of one ckt of 765 kV Vindhyachal-Varanasi will overload the other circuit	Rev- 0 to 2
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli	Rev- 0 to 2
ER-NR	Inter-regional flow pattern towards NR	Rev- 0 to 2
WR-SR	N-1 of one ICT of 765/400 kV, 1500 MVA ICT at Nizamabad will overload the other ICT	Rev- 0 to 2
and ER-	Low Voltage at Gazuwaka (East) Bus.	Rev- 0 to 2
SR-WR	a) N-1 contingency of one ckt of 400 kV Kolhapur-PG - Kolhapur-MS D/C will overload of the other ckt	Rev- 0 to 2
	a) N-1 contingency of 400 kV Bongaigaon - Azara line b) High Loading of 220 kV Salakati - BTPS D/C	Rev- 0 to 2
NER-ER	a) N-1 contingency of 220 kV Salakati - Alipurduar I or II b) High Loading of 220 kV Salakati - Alipurduar II or I	Rev- 0 to 2
W3 zone Injection		Rev- 0 to 2

Limiting Constraints (Simultaneous)

			Applicable Revisions	
	Import	Inter-regional flow pattern towards NR	Rev- 0 to 2	
NR	Import	N-1 contingency of one ckt of 765 kV Vindhyachal-Varanasi will overload the other circuit	Rev- 0 to 2	
1117	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.	Rev- 0 to 2	
	Export	(n-1) contingency of 400 kV Saranath-Pusauli	Rev- 0 to 2	
	Import	a) N-1 contingency of 400 kV Bongaigaon - Azara line.	Rev- 0 to 2	
NER		b) High Loading of 220 kV Salakati - BTPS D/C		
	Export	a) N-1 contingency of 220 kV Salakati - Alipurduar I or II b) High Loading of 220 kV Salakati - Alipurduar II or I	Rev- 0 to 2	
SR	Import	N-1 of one ICT of 765/400 kV, 1500 MVA ICT at Nizamabad will overload the other ICT Low Voltage at Gazuwaka (East) Bus	Rev- 0 to 2	
	Export	N-1 contingency of one ckt of 400 kV Kolhapur-PG - Kolhapur-MS D/C will overload of the other ckt	Rev- 0 to 2	

National Load Despatch Centre Total Transfer Capability for March 2022

Revision No	Date of Revision	Period of Revision	Reason for Revision/Comment	Corridor Affected
	28th December		Revised STOA margin due to a) Discontinuation of MTOA of 300 MW from AP43PL_BKN(SECI) to Odisha b) Increase in LTA of 50 MW from RSWPL3_FTG2 to BSHPCL c) Increase in LTA of 33 MW from AP41PL_BHDL to Odisha	NR-ER/NR-WR/NR Export
1	1 2021 2021	Whole Month	Revised STOA margin due to increase in LTA of 23 MW from BRBCL (Railways)	ER-NR/NR Import
			Revised STOA margin due to operationalization of LTA of 100 MW from Rajasthan (ABC Solar private limited) to Pondicherry	WR-SR/SR Import
			Revised STOA margin due to increase in LTA by 20 MW from HIRIYUR_OSTROKANNADA to Bihar	SR Export
2	04th January 2022	Whole Month	TTC/ATC Revised after commissioning of HVDC Raigarh - Pugalur Pole - IV	WR-SR/ER-SR/SR Import/SR-WR/SR- EXPORT

	MPTIONS IN BASECASE		Lood	Month: March2022	lian.	
S.No.	Name of State/Area		Load	Genera		
I	NORTHERN REGION	Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)	
1	Punjab	10744	10867	3971	3971	
2	Haryana	9492	9088	2701	2701	
3	Rajasthan	10485	9635	8259	8259	
4	Delhi	5321	5152	796	795	
5	Uttar Pradesh	20631	20099	10623	10689	
6	Uttarakhand	2124	1886	928	939	
7	Himachal Pradesh	1354	1114	783	769	
8	Jammu & Kashmir	2363	1962	884	883	
9	Chandigarh	313	249	0	0	
10	ISGS/IPPs	48	48	21958	20013	
	Total NR	62875	60100	50903	49019	
II	EASTERN REGION					
1	Bihar	6537	5617	356	349	
2	Jharkhand	1958	1503	511	501	
3	Damodar Valley Corporation	2985	2723	5856	4190	
4	Orissa	4513	4310	3998	3798	
5	West Bengal	9704	8401	7033	6210	
6	Sikkim	119	116	0	0	
7	Bhutan	181	181	2325	2325	
8	ISGS/IPPs	810	810	15771	11533	
	Total ER	26808	23662	35850	28906	
Ш	WESTERN REGION					
1	Maharashtra	17405	16509	11624	10789	
2	Gujarat	13918	11320	8601	7246	
3	Madhya Pradesh	9254	8534	3596	3845	
4	Chattisgarh	4309	3965	2531	2835	
5	Daman and Diu	276	236	0	0	
6	Dadra and Nagar Haveli	744	870	0	0	
7	Goa-WR	534	420	0	0	
8	ISGS/IPPs	1784	3263	36712	32338	
	Total WR	48224	45117	63064	57053	
IV	SOUTHERN REGION					
1	Andhra Pradesh	8024	7220	6268	5204	
2	Telangana	9100	8117	5196	5078	
3	Karnataka	8396	6654	6023	4850	
4	Tamil Nadu	15210	13068	7256	6376	
5	Kerala	3778	2349	1614	961	
6	Pondy	264	264	0	0	
7	Goa-SR	82	82	0	0	
8	ISGS/IPPs	37	37	14805	14794	
	Total SR	44891	37791	41162	37263	
V	NODTH EASTEDN DECION					
1	NORTH-EASTERN REGION	140	95	118	118	
2	Arunachal Pradesh	1849			574	
	Assam		1588	615		
3	Manipur Maghalaya	207	86	105	103	
4 5	Meghalaya	315	255	302	229	
	Mizoram	150	55	60	60	
6	Nagaland	173	155	96	93	
7	Tripura	435	260	300	300	
8	ISGS/IPPs	0	0	2371	2370	
	Total NER	3269	2494	3967	3847	
	Total All India	186067	169164	194946	176088	