#### National Load Despatch Centre Total Transfer Capability for May 2015

Revision No. 6

Issue Time: 1830 hrs

Issue Date: 30/04/2015

						Long Term	Margin	Changes		
Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Access (LTA)/ Medium Term Open Access (MTOA) #	Available for Short Term Open Access (STOA)	in TTC w.r.t. Last Revision	Comments	
NR-WR *	1st May 2015 to 31st May 2015	00-24	2500	500	2000	706	1294			
	1st May 2015	00-07 07-24'	5100 4850	500	4600 4350	5157	0	-250		
	2nd May 2015 to	00-17 23-	4850	500	4350	5157	0		Revised due to shutdown of HVDC Vindhyachal BTB Block-2.	
WR-NR*	3rd May 2015	24 17-23	4850	500	4350	5157	0	-250		
	4th May 2015 to	00-17 23-24	5100	500	4600	5157	0			
	31st May 2015	17-23	5100		4600		0			
NR-ER*	1st May 2015 to 31st May 2015	00-06 06-18'	2000 2000	200	1800 1800	293 358	1507 1442			
	-	18-24 00-17	2000		1800	293	1507			
ER-NR*	1st May 2015 to 31st May 2015	23-24	3400	300	3100	2431	669			
		17-23	3400		3100		669			
W3-ER <sup>\$</sup>	1st May 2015 to 31st May 2015	00-24					is being specified. allowed via W3-El	R-NR.		
ER-W3	1st May 2015 to 31st May 2015	00-24	1000	300	700	874	0			
		05-22	2100		1350		0	-200	Revised due to shutdown of 765kV	
WR-SR	1st May 2015	00-05 22-24	2500	750	1750	1350	400	-200	Pune-Sholapur S/C and considering the present Maharashtra Demand pattern.	
	2nd May 2015 to	05-22	2300		1550		200		Revised considering the present	
	31st May 2015	00-05 22-24	2700	750	1950	1350	600	400	Maharashtra Demand pattern.	
SR-WR *	1st May 2015 to 31st May 2015	00-24				No limit i	s being Specified.			
ER-SR	1st May 2015 to	00-06 18- 24	2650	0	2650	2385	265			
EK-5K	31st May 2015	06-18'	2050	0	2030	2450	200			
SR-ER *	1st May 2015 to 31st May 2015	00-24				No limit i	s being Specified.			
	1st May 2015 to	00-17	1170		1130		920	520	Revised due to LGBR changes and	
ER-NER	31st May 2015	23-24 17-23	1150	40	1110	210	900	430	addition of new elements.	
NER-ER	1st May 2015 to 31st May 2015	00-24				No limit i	s being Specified.			
						I				
S1-S2	1st May 2015	00-24	3220	320	2900	2583	317	300	Due to Extension of Vallur Unit -3	
	2nd Mey 2015	00-12	3220	320	2900	2583	317	300	Outage	
	2nd May 2015	12'-24	2920	320	2600	2474	126			
	3rdMay 2015 to 31st May 2015	00-24	2920	320	2600	2474	126			
Import of Punjab	1st May 2015 to 31st May 2015	00-24	5700	300	5400	3790	1610			
Import TTC for DD & DNH	1st May 2015 to 31st May 2015	00-24	1200	0	1200		OA as per ex-pp edule			
W3 zone Injection	1st May 2015 to 31st May 2015	00-17 23-24	9400	200	9200	7094	2106			
-	31st May 2015	31st May 2015	17-23	9900		9700		2606		

 1/-23
 9900
 9700
 2606

 \* Fifty Percent (50 % ) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

#### National Load Despatch Centre Total Transfer Capability for May 2015

Issue Time: 1830 hrs

		1				Long Term	Margin	Changes	
		Time	Total Transfer	Reliability	Available Transfer	Access (LTA)/	Available for	in TTC	
Corridor	Date	Period (hrs)		Margin	Capability (ATC)	Medium Term Open Access	Short Term Open Access	w.r.t. Last	Comments
		(110)	(IIC)	IC)	(AIC)	(MTOA) #	(STOA)	Revision	

Revision No. 6

\$ As per Simulations, predominant direction of flow is on West to North Corridor. Hence, in case injection point is in Western Region (W1,W2,W3), STOA/PX transactions from West to North on West-East-North corridor shall not be allowed as such transaction increases congestion in the West to North Corridor.

1) S1 comprises of Telangana, AP and Karnataka: S2 comprises of Tamil Nadu, Kerala and Puducherry

2) W3 comprises of the following regional entities :

a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCL, n)Vandana Vidyut

# The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissionned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown :

1) The TTC value will be revised to normal values after restoration of shutdown.

2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

#### Limiting Constraints

Issue Date: 30/04/2015

Corridor	Constraint
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.
WR-NR	High Loading of 400kV Singrauli-Anpara & High loading of 765 kV Agra-Gwalior (1250 MW SPS setting on each circuit of 765 kV Gwalior-Agra) and Loop flows on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda (power flowing from WR to NR on 765kV Gwalior-Agra D/C and from NR to WR on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda).
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli
ER-NR	(n-1) contingnecy of Kahalgaon-Lakhisarai S/C
ER-W3	1. n-1 of 400 kV Wardha – Parli will lead to 30 degrees angular separation between Wardha and Parli.       2. (n         1) contingency of one circuit of 400kV Parli(PG)-Sholapur(PG)       2.
WR-SR & ER-SR	1. n-1 of 400 kV Wardha – Parli will lead to 30 degrees angular separation between Wardha and Parli.     2. (n     1) contingency of one circuit of 400kV Parli(PG)-Sholapur(PG)     3. ER-SR TTC has been declared assuming more than 1100 MW generation at Talcher Stage-2. In case Talcher     Stage-2 generation goes below 1100 MW, then the ER-SR TTC would be revised downward as constraints     within ER would emerge.
ER-NER	(n-1) contingnecy of Kahalgaon-Lakhisarai S/C
NER-ER	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA ICT at Misa
S1-S2	(n-1) contingency of one circuit of 400 kV Kolar-Hosur D/C
Import of DD & DNH	(n-1) contingency of 400/220KV 315MVA ICT at VAPI
Import of Punjab	(n-1) contingency of ICT at Dhuri and (n-1) contingnecy of 220kV Moga(PG)-Moga(PSTCL)
W3 zone Injection	<ol> <li>n-1 of 400 kV Wardha – Parli will lead to 30 degrees angular separation between Wardha and Parli.</li> <li>(n-1) contingency of one circuit of 400kV Parli(PG)-Sholapur(PG)</li> </ol>
	*Primary constraints

### Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
ER										
		00-07	8500		7700		112			
	1st May 2015	07-24'	8300	800	7450	7588	0	-250	Revised due to shutdown of	
		07-24					0	-230	HVDC Vindhyachal BTB	
	2nd May 2015 to	23-24	8250	800	7450	7588	-138	-250	Block-2.	
NR*	3rd May 2015	17-23	8250		7450	1	-138			
	4th May 2015 to	00-17 23-24	8500	800	7700	7588	112			
	31st May 2015	17-23	8500	1	7700	1	112			
NER	1st May 2015 to	00-17 23-24	1170	40	1130	210	920	520	Revised due to LGBR changes and addition of new elements.	
	31st May 2015	17-23	1150		1110		900	430		
WR										
		00-05	5150		4400	3935	465	200	Revised due to shutdown of	
	1.11.0015	05-06'	4750	750	4000	3935	65	200	765kV Pune-Sholapur S/C	
	1st May 2015	06-18'	4750	750	4000	4000	0	-200	and considering the present	
		18-22	4750		4000	3935	65	200	Maharashtra Demand pattern	
SR		22-24	5150		4400	3935	465	200		
		00-05 05-06'	5350 4950		4600 4200	3935 3935	665 265	400	Desired considering th	
	2nd May 2015 to	05-06	4950	750	4200	<u> </u>	200		Revised considering the present Maharashtra Demand	
	31st May 2015	18-22	4950	750	4200	3935	265		pattern	
		22-24	5350		4200	3935	665	400		

### Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
NR*	1st May 2015 to 31st May 2015	00-06 06-18'	4500	700	3800 3800	999 1064	2801 2736			
	515t May 2015	18-24	4500		3800	999	2801			
NER	1st May 2015 to 31st May 2015	00-17 23-24 17-23		No limit is being Specified.						
WR										
SR *	1st May 2015 to 31st May 2015	00-24		No limit is being Specified.						

\* Fifty Percent (50 % ) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

### Limiting Constraints

		(n-1) contingnecy of Kahalgaon-Lakhisarai S/C
NR	Immout	High loading of 765 kV Agra-Gwalior (1250 MW SPS setting on each circuit of 765 kV Gwalior-Agra) and high loop
	Import	flows on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda (power flowing from WR to NR on 765kV Gwalior-Agra
		D/C and from NR to WR on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda).
	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.
	Export	(n-1) contingency of 400 kV Saranath-Pusauli
NER	Import	(n-1) contingnecy of Kahalgaon-Lakhisarai S/C
IVEN	Export	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other ICT at Misa
		1. n-1 of 400 kV Wardha – Parli will lead to 30 degrees angular separation between Wardha and Parli.
		2. (n-1) contingency of one circuit of 400kV Parli(PG)-Sholapur(PG) D/C.
SR Import		3. ER-SR TTC has been declared assuming more than 1100 MW generation at Talcher Stage-2. In case Talcher Stage-
		2 generation goes below 1100 MW, then the ER-SR TTC would be revised downward as constraints within ER would
		emerge.

\*Primary constraints

# National Load Despatch Centre Total Transfer Capability for May 2015

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor Affected
1	12-02-2015	Whole Month	Margin revised due to cancellation of LTA/MTOA	NR-WR/ ER- W3
2	02-03-2015	Whole Month	STOA Margins revised due to grant of MTOA from Chattisgarh to KSEB by CTU. Revised due to commissioning of Vallur Unit-3	W3-ER/W3 Zone S1-S2
3	31-03-2015	Whole Month	Revised considering the commissioning of Sasan Unit-6 and reviewed HVDC set points. Revised considering the commissioning of 765kV Pune-	WR-NR WR-SR
4	21-04-2015	Whole Month	Sholapur S/C. Revised considering reviwed thermal ratings of the lines in ER and expected flows on ER-NR corridor	ER-NR
5	27-04-2015	Whole Month	Revised due to LGBR changes given in 106th OCC meeting.	S1-S2
		Whole Month	Revised due to shutdown of 765kV Pune-Sholapur S/C and considering the present Maharashtra Demand pattern (1st May) & Revised considering the present Maharashtra Demand pattern (2nd-31st).	WR-SR
6	30-04-2015	01-05-2015 to 03- 05-2015	Revised due to shutdown of HVDC Vindhyachal BTB Block-2.	WR-NR
		Whole Month	on account of addition of new elements in NER Grid and change in load-generation balance.	ER-NER/ NER- ER
		01-05-15 to 02-05-15	Due to Extension of Vallur Unit -3 Outage	S1-S2

## **ASSUMPTIONS IN BASECASE**

		-		Month :	May '15
		Loa	ad	Gener	ation
S.No.	Name of State/Area	Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
I	NORTHERN REGION				
1	Punjab	7577	6617	3463	3477
2	Haryana	5856	5210	2202	2203
3	Rajasthan	7738	7467	4717	4717
4	Delhi	5200	4674	1323	1323
5	Uttar Pradesh	12604	12834	6533	6524
6	Jammu & Kashmir	2166	1404	443	441
7	Uttarakhand	1638	1285	830	496
8	Himachal Pradesh	1383	1127	704	624
9	Chandigarh	292	194	0	0
10	ISGS/IPPs			18480	15160
	Total NR	44454	40812	38695	34965
П	EASTERN REGION				
1	West Bengal	7550	6800	5200	3700
2	Jharkhand	1070	900	470	380
3	Orissa	3950	3200	3400	2500
4	Bihar	2600	2140	180	0
5	Damodar Valley Corporation	2675	2400	3800	3400
6	Sikkim	85	50	-	-
7	Bhutan			250	140
8	ISGS/IPPs			10005	8325
	Total ER	17930	15490	23305	18445
Ш	WESTERN REGION				
1	Chattisgarh	3336	2801	1606	1313
2	Madhya Pradesh	7271	6314	3649	3011
3	Maharashtra	19250	17030	15092	12163
4	Gujarat	13471	1238	10322	8765
5	Goa	438	347		
6	Daman and Diu	288	264		
7	Dadra and Nagar Haveli	687	665		
8	ISGS/IPPs	1058	1058	22774	22774
	Total WR	45799	29717	53443	48026

## **ASSUMPTIONS IN BASECASE**

	[			Month : I	viay 15	
		Loa	ad	Generation		
S.No.	Name of State/Area	Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)	
IV	SOUTHERN REGION					
1	Telangana	5580	5568	2354	2173	
2	Andhra Pradesh					
3	Tamil Nadu	5593 12051	<u>5592</u> 10398	5077 7068	4550 6424	
4	Karnataka	8046	7046	7088	5576	
5	Kerala	3328	2336	1939	770	
6	Pondy	374	2330	1555		
7	Goa	89	89			
8	ISGS/IPPs			9180	9180	
	Total SR	35061	31323	32698	28673	
V	NORTH-EASTERN REGION					
1	Arunachal Pradesh	86	53	0	0	
2	Assam	753	640	215	200	
3	Manipur	83	53	0	0	
4	Meghalaya	296	211	140	92	
5	Mizoram	58	40	4	3	
6	Nagaland	76	63	16	8	
7	Tripura	244	164	110	110	
8	ISGS/IPPs			990	738	
	Total NER	1596	1224	1475	1151	
	Total All India	144840	118566	149616	131260	