National Load Despatch Centre Total Transfer Capability for May 2015

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR-WR *	1st May 2015 to 31st May 2015	00-24	2500	500	2000	706	1294		
	1st May 2015	00-07	5100 4850	500	4600 4350	5157	0		
		00-0730	4850		4350		0		
	2nd May 2015	0730-	4400	500	3900	5157	0		
		1030 1030-24	4850		4350		0		
WR-NR*		00-17							
	3rd May 2015	23-24	4850	500	4350	5157	0		
		17-23 00-17 23-	4850		4350		0		
	4th May 2015 to 31st May 2015	24	5100	500	4600	5157	0		
	31st Way 2013	17-23	5100		4600		0		
	1st May 2015 to	00-06	2000		1800	293	1507		
NR-ER*	31st May 2015 to	06-18'	2000	200	1800	358	1442		
		18-24 00-17	2000		1800	293	1507		
ER-NR*	1st May 2015 to 31st May 2015	23-24	3400	300	3100	2431	669		
		17-23	3400		3100		669	l e	
W3-ER ^{\$}	1st May 2015 to 31st May 2015	00-24					is being specified. allowed via W3-El	R-NR.	
ER-W3	1st May 2015 to 31st May 2015	00-24	1000	300	700	874	0		
		05-22	2100		1250		0		
	1st May 2015	00-05	2100	750	1350	1350	0		
WR-SR		22-24	2500		1750		400		
	2nd May 2015 to	05-22	2300		1550		200		
	31st May 2015	00-05 22-24	2700	750	1950	1350	600		
SR-WR*	1st May 2015 to 31st May 2015	00-24				No limit i	s being Specified.		
	1st May 2015 to	00-06				2385	265		
ER-SR	31st May 2015	18-24	2650	0	2650		200		
SR-ER*	1st May 2015 to 31st May 2015	06-18'				2450 No limit i	s being Specified.		
	4 . 3 4 4 4 4 4	00-17							
ER-NER	1st May 2015 to 31st May 2015	23-24	1170	40	1130	210	920		
	-	17-23	1150		1110		900		
NER-ER	1st May 2015 to 31st May 2015	00-24				No limit i	s being Specified.		
	1st May 2015	00-24	3220	320	2900	2583	317		
	2nd May 2015	00-12	3220	320	2900	2583	317		D : 11 . D :
S1-S2	3rd May 2015	12'-24 00-24	3220 3220	320 320	2900 2900	2583 2583	317 317	300 300	Revised due to Extension of Vallur Unit -3 Outage
	4th May 2015 to	00-24	2920	320	2600	2474	126	500	
Import of Punjab	31st May 2015 1st May 2015 to 31st May 2015	00-24	5700	300	5400	3790	1610		
Import TTC for DD & DNH	1st May 2015 to 31st May 2015	00-24	1200	0	1200		OA as per ex-pp edule		
W3 zone	1st May 2015 to	00-17 23-	9400	200	9200	7094	2106		
Injection	31st May 2015	24 17-23	9900	200	9700	7094	2606		
		23	,,,,,		7.00		2000		

First Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

National Load Despatch Centre Total Transfer Capability for May 2015

Issue Date: 02/05/2015 Issue Time: 01200 hrs Revision No. 8

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
----------	------	-------------------------	------------------------------------------	-----------------------	----------------------------------------------	----------------------------------------------------------------------	----------------------------------------------------------------	-------------------------------------------------	----------

^{\$} As per Simulations, predominant direction of flow is on West to North Corridor. Hence, in case injection point is in Western Region (W1,W2,W3), STOA/PX transactions from West to North on West-East-North corridor shall not be allowed as such transaction increases congestion in the West to North Corridor.

- 1) S1 comprises of Telangana, AP and Karnataka: S2 comprises of Tamil Nadu, Kerala and Puducherry
- 2) W3 comprises of the following regional entities :
- a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak
- $f)\;BALCO,\;g)\;Sterlite\;(\#1,3,4),\;h)\;NSPCL,\;i)\;Korba,\;j)\;Sipat,\;k)\;KSK\;Mahanadi,\;L)DB\;Power,\;m)\;KWPCL,\;n)Vandana\;Vidyut$

The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/Fuel shortage/New units being commissionned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown:

- 1) The TTC value will be revised to normal values after restoration of shutdown.
- 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

Limiting Constraints

Corridor	Constraint					
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.					
WR-NR	High Loading of 400kV Singrauli-Anpara & High loading of 765 kV Agra-Gwalior (1250 MW SPS setting on each circuit of 765 kV Gwalior-Agra) and Loop flows on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda (power flowing from WR to NR on 765kV Gwalior-Agra D/C and from NR to WR on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda).					
NR-ER						
ER-NR	(n-1) contingnecy of Kahalgaon-Lakhisarai S/C					
ER-W3	n-1 of 400 kV Wardha – Parli will lead to 30 degrees angular separation between Wardha and Parli. (n-1) contingency of one circuit of 400kV Parli(PG)-Sholapur(PG)					
WR-SR & ER-SR	1. n-1 of 400 kV Wardha – Parli will lead to 30 degrees angular separation between Wardha and Parli. 2. (n-1) contingency of one circuit of 400kV Parli(PG)-Sholapur(PG) 3. ER-SR TTC has been declared assuming more than 1100 MW generation at Talcher Stage-2. In case Talcher Stage-2 generation goes below 1100 MW, then the ER-SR TTC would be revised downward as constraints within ER would emerge.					
ER-NER	(n-1) contingnecy of Kahalgaon-Lakhisarai S/C					
NER-ER	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA ICT at Misa					
S1-S2	(n-1) contingency of one circuit of 400 kV Kolar-Hosur D/C					
Import of DD & DNH	(n-1) contingency of 400/220KV 315MVA ICT at VAPI					
Import of Punjab	(n-1) contingency of ICT at Dhuri and (n-1) contingnecy of 220kV Moga(PG)-Moga(PSTCL)					
W3 zone Injection	1. n-1 of 400 kV Wardha – Parli will lead to 30 degrees angular separation between Wardha and Parli. 2. (n-1) contingency of one circuit of 400kV Parli(PG)-Sholapur(PG)					

^{*}Primary constraints

Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER									
	1st May 2015	00-07 07-24'	8500 8250	800	7700 7450	7588	112 0		
		00-0730	8250		7450		-138		
	2nd May 2015	0730- 1030	7800	800	7000	7588	0		
NR*		1030-24	8250		7450		-138		
NK.	3rd May 2015	00-17 23-24	8250	800	7450	7588	-138		
		17-23	8250		7450		-138		
	4th May 2015 to 31st May 2015	00-17 23-24	8500	800	7700	7588	112		
		17-23	8500		7700		112		
NER	1st May 2015 to 31st May 2015	00-17 23-24	1170	40	1130	210	920		
	31st Way 2013	17-23	1150		1110		900		
WR									
		00-05	5150		4400	3935	465		
		05-06'	4750		4000	3935	65		
	1st May 2015	06-18'	4750	750	4000	4000	0		
		18-22	4750		4000	3935	65		
SR		22-24	5150		4400	3935	465		
) II		00-05	5350		4600	3935	665		
	2nd May 2015 to	05-06'	4950		4200	3935	265		
	31st May 2015	06-18'	4950	750	4200	4000	200		
		18-22	4950		4200	3935	265		
		22-24	5350		4600	3935	665		

Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
	1st May 2015 to 31st May 2015	00-06	4500	700	3800	999	2801			
NR*		06-18'	4300		3800	1064	2736			
		18-24	4500		3800	999	2801			
	1st May 2015 to 31st May 2015	00-17								
NER		23-24		No limit is being Specified.						
		17-23								
WR									_	
WK										
SR *	1st May 2015 to 31st May 2015	00-24		No limit is being Specified.						

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Limiting Constraints

	,	
		(n-1) contingnecy of Kahalgaon-Lakhisarai S/C
	Import	High loading of 765 kV Agra-Gwalior (1250 MW SPS setting on each circuit of 765 kV Gwalior-Agra) and high loop
NR	Import	flows on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda (power flowing from WR to NR on 765kV Gwalior-Agra
INIX		D/C and from NR to WR on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda).
	Evnout	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.
	Export	(n-1) contingency of 400 kV Saranath-Pusauli
NER	Import	(n-1) contingnecy of Kahalgaon-Lakhisarai S/C
NEK	Export	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other ICT at Misa
		1. n-1 of 400 kV Wardha – Parli will lead to 30 degrees angular separation between Wardha and Parli.
		2. (n-1) contingency of one circuit of 400kV Parli(PG)-Sholapur(PG) D/C.
SR	Import	3. ER-SR TTC has been declared assuming more than 1100 MW generation at Talcher Stage-2. In case Talcher Stage-2
	-	generation goes below 1100 MW, then the ER-SR TTC would be revised downward as constraints within ER would
		emerge.

^{*}Primary constraints

National Load Despatch Centre Total Transfer Capability for May 2015

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor Affected
1	12-02-2015	Whole Month	Margin revised due to cancellation of LTA/MTOA	NR-WR/ER- W3
2	02-03-2015	Whole Month	STOA Margins revised due to grant of MTOA from Chattisgarh to KSEB by CTU.	W3-ER/ W3 Zone
3	31-03-2015	Whole Month	Revised due to commissioning of Vallur Unit-3 Revised considering the commissioning of Sasan Unit-6 and reviewed HVDC set points.	S1-S2 WR-NR
5	31-03-2013	whole Month	Revised considering the commissioning of 765kV Pune-Sholapur S/C.	WR-SR
4	21-04-2015	Whole Month	Revised considering reviwed thermal ratings of the lines in ER and expected flows on ER-NR corridor	ER-NR
5	27-04-2015	Whole Month	Revised due to LGBR changes given in 106th OCC meeting.	S1-S2
		Whole Month	Revised due to shutdown of 765kV Pune-Sholapur S/C and considering the present Maharashtra Demand pattern (1st May) & Revised considering the present Maharashtra Demand pattern (2nd-31st).	WR-SR
6	30-04-2015	01-05-2015 to 03-05-2015	Revised due to shutdown of HVDC Vindhyachal BTB Block-2.	WR-NR
		Whole Month	on account of addition of new elements in NER Grid and change in load-generation balance.	ER-NER/ NER- ER
		01-05-15 to 02-05-15	Due to Extension of Vallur Unit -3 Outage	S1-S2
7	02-05-2015	02-05-2015	Revised due to Emergency shutdown of Rihand-Dadri HVDC Pole-1.	WR-NR
8	02-05-2015	02-05-15 to 03-05-15	Revised due to Extension of Vallur Unit -3 Outage	S1-S2

ASSUMPTIONS IN BASECASE

Month: May '15

	Month: May 15								
		Lo	ad	Generation					
S.No.	Name of State/Area	Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)				
I	NORTHERN REGION								
1	Punjab	7577	6617	3463	3477				
2	Haryana	5856	5210	2202	2203				
3	Rajasthan	7738	7467	4717	4717				
4	Delhi	5200	4674	1323	1323				
5	Uttar Pradesh	12604	12834	6533	6524				
6	Jammu & Kashmir	2166	1404	443	441				
7	Uttarakhand	1638	1285	830	496				
8	Himachal Pradesh	1383	1127	704	624				
9	Chandigarh	292	194	0	0				
10	ISGS/IPPs			18480	15160				
	Total NR	44454	40812	38695	34965				
II	EASTERN REGION								
1	West Bengal	7550	6800	5200	3700				
2	Jharkhand	1070	900	470	380				
3	Orissa	3950	3200	3400	2500				
4	Bihar	2600	2140	180	0				
5	Damodar Valley Corporation	2675	2400	3800	3400				
6	Sikkim	85	50	-					
7	Bhutan			250	140				
8	ISGS/IPPs			10005	8325				
	Total ER	17930	15490	23305	18445				
III	WESTERN REGION								
1	Chattisgarh	3336	2801	1606	1313				
2	Madhya Pradesh	7271	6314	3649	3011				
3	Maharashtra	19250	17030	15092	12163				
4	Gujarat	13471	1238	10322	8765				
5	Goa	438	347						
6	Daman and Diu	288	264						
7	Dadra and Nagar Haveli	687	665						
8	ISGS/IPPs	1058	1058	22774	22774				
	Total WR	45799	29717	53443	48026				

ASSUMPTIONS IN BASECASE

Month: May '15

	World : Way 13							
		Loa	ad	Generation				
S.No.	Name of State/Area	Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)			
IV	SOUTHERN REGION							
1	Telangana	5580	5568	2354	2173			
2	Andhra Pradesh	5593	5592	5077	4550			
3	Tamil Nadu	12051	10398	7068	6424			
4	Karnataka	8046	7046	7080	5576			
5	Kerala	3328	2336	1939	770			
6	Pondy	374	294					
7	Goa	89	89					
8	ISGS/IPPs			9180	9180			
	Total SR	35061	31323	32698	28673			
٧	NORTH-EASTERN REGION							
1	Arunachal Pradesh	86	53	0	0			
2	Assam	753	640	215	200			
3	Manipur	83	53	0	0			
4	Meghalaya	296	211	140	92			
5	Mizoram	58	40	4	3			
6	Nagaland	76	63	16	8			
7	Tripura	244	164	110	110			
8	ISGS/IPPs			990	738			
	Total NER	1596	1224	1475	1151			
	Total All India	444040	440500	4.4004.0	404000			
	Total All India	144840	118566	149616	131260			