## National Load Despatch Centre Total Transfer Capability for May 2016

Issue Date: 30/04/2016 Issue Time: 1400 hrs Revision No. 4

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments					
NR-WR *	1st May 2016 to 31st May 2016	00-24	2500	500	2000	149	1851							
	1st May 2016	00-24	6700	500	6200	6170	30	-700	Revised considering the present high generation in Rajasthan state					
		00-07	6700	500	6200	6170	30	-700						
	2nd May 2016 to 3rd May 2016	07-24'	6300	500	5800	6170	0	-1100	Revised due to shutdown of HVDC Rihand Dadri Bipole and considering present high generation trend in Rajasthan					
WR-NR*	4th May 2016	00-24	6700	500	6200	6170	30		Revised considering the present high generation in Rajasthan state					
	5th May 2016	00-07	6700	500	6200	6170	30	-700	· · · · · · · · · · · · · · · · · · ·					
	· ·	00-24	5850	500	5350	6170	0	-1550	Revised considering Shutdown of					
	6th May 2016 to 10th May 2016	00-24	5850	500	5350	6170	0	-1550	765 kV Phagi - Bhiwani S/C and present high generation in Rajasthan					
	11th May 2016 to 31st May 2016	00-24	6700	500	6200	6170	30	-700	Revised considering the present high generation trend in Rajasthan state					
		00-06	2000		1800	293	1507	1						
NR-ER*	1st May 2016 to	06-18'	2000	200	1800	358	1442							
IVIX-LIX	31st May 2016	18-24	2000	200	1800	293	1507							
ER-NR*	1st May 2016 to 31st May 2016	00-24	3800	300	3500	2431	1069							
	31st Way 2010	<u> </u>	l											
				No limit is being specified. No Re-routing is allowed via W3-ER-NR.										
W3-ER <sup>\$</sup>	1st May 2016 to 31st May 2016	00-24						R-NR.						
W3-ER <sup>\$</sup> ER-W3		00-24			No limit is			R-NR.						
	31st May 2016 1st May 2016 to 31st May 2016 1st May 2016 to		4000	750	No limit is	No Re-routing is		R-NR.						
ER-W3	31st May 2016 1st May 2016 to 31st May 2016 1st May 2016 to 31st May 2016 to 31st May 2016 1st May 2016 to	00-24	4000	750		No Re-routing is being specified.	allowed via W3-EI	R-NR.						
ER-W3 WR-SR	31st May 2016 1st May 2016 to 31st May 2016 1st May 2016 to 31st May 2016 to 31st May 2016	00-24	4000	750		No Re-routing is being specified.	allowed via W3-EI	R-NR.						
ER-W3 WR-SR	31st May 2016 1st May 2016 to 31st May 2016  1st May 2016 to 31st May 2016 to 31st May 2016 1st May 2016 to 31st May 2016 to 31st May 2016	00-24			3250	No Re-routing is being specified.	allowed via W3-EI		Revised considering shutwon of one pole of HVDC Gazuwaka B/B and					
ER-W3 WR-SR	31st May 2016 1st May 2016 to 31st May 2016 1st May 2016 to 31st May 2016 to 31st May 2016 1st May 2016 to	00-24 00-24 00-24	4000	750		No Re-routing is being specified.  3250  No limit is	allowed via W3-Ei  0 s being Specified.	-300	_					
WR-SR SR-WR*	31st May 2016 1st May 2016 to 31st May 2016  1st May 2016 to 31st May 2016 1st May 2016 1st May 2016 to 31st May 2016 1st May 2016	00-24 00-24 00-24 00-06 18-24	2350		3250	No Re-routing is being specified.  3250  No limit is 2585  2650	0 s being Specified.	-300	pole of HVDC Gazuwaka B/B and high valve hall temperature at					
WR-SR SR-WR*	31st May 2016 1st May 2016 to 31st May 2016 1st May 2016 to 31st May 2016 1st May 2016 to 31st May 2016 to 31st May 2016 2nd May 2016 to	00-24 00-24 00-24 00-06 18-24 00-06 18-24			3250	No Re-routing is being specified.  3250  No limit is 2585  2650  2585	0 s being Specified.  0 0 65	-300	pole of HVDC Gazuwaka B/B and high valve hall temperature at					
WR-SR SR-WR*	31st May 2016 1st May 2016 to 31st May 2016 to 31st May 2016 to 31st May 2016 1st May 2016 to 31st May 2016 2nd May 2016 2nd May 2016 to 31st May 2016	00-24 00-24 00-24 00-06 18-24 06-18' 00-06	2350	0	3250 2350	No Re-routing is being specified.  3250  No limit is 2585  2650	0 s being Specified.	-300	pole of HVDC Gazuwaka B/B and high valve hall temperature at					
WR-SR SR-WR*	31st May 2016 1st May 2016 to 31st May 2016 1st May 2016 to 31st May 2016 1st May 2016 to 31st May 2016 to 31st May 2016 2nd May 2016 to	00-24 00-24 00-24 00-06 18-24 00-06 18-24	2350	0	3250 2350	No Re-routing is being specified.  3250  No limit is 2585  2650  2585  2650	0 s being Specified.  0 0 65	-300	pole of HVDC Gazuwaka B/B and high valve hall temperature at					
WR-SR SR-WR*  ER-SR	31st May 2016 1st May 2016 to 31st May 2016 to 31st May 2016 1st May 2016 1st May 2016 1st May 2016 2nd May 2016 2nd May 2016 2nd May 2016 1st May 2016 1st May 2016 2nd May 2016 31st May 2016 1st May 2016 to 31st May 2016	00-24 00-24 00-24 00-06 18-24 06-18' 00-06 18-24 06-18' 00-24	2350	0	2350 2650	No Re-routing is being specified.  3250  No limit is 2585  2650  2585  2650	0 s being Specified.  0 0 5 s being Specified.	-300	pole of HVDC Gazuwaka B/B and high valve hall temperature at					
WR-SR SR-WR*  ER-SR	31st May 2016 1st May 2016 to 31st May 2016 to 31st May 2016 1st May 2016 1st May 2016 1st May 2016 2016 2017 2017 2018 2018 2019 2019 2019 2019 2019 2019 2019 2019	00-24 00-24 00-24 00-06 18-24 00-06 18-24 06-18'	2350	0	3250 2350	No Re-routing is being specified.  3250  No limit is 2585  2650  2585  2650	0 s being Specified.  0 0 65	-300	high valve hall temperature at					
ER-W3 WR-SR SR-WR* ER-SR	31st May 2016 1st May 2016 to 31st May 2016 to 31st May 2016 1st May 2016 1st May 2016 1st May 2016 2nd May 2016 2nd May 2016 2nd May 2016 1st May 2016 1st May 2016 2nd May 2016 31st May 2016 1st May 2016 to 31st May 2016	00-24 00-24 00-24 00-06 18-24 06-18' 00-06 18-24 06-18' 00-24	2350	0	2350 2650	No Re-routing is being specified.  3250  No limit is 2585  2650  No limit is 1600  2585	0 s being Specified.  0 0 5 s being Specified.	-300	pole of HVDC Gazuwaka B/B and high valve hall temperature at					
ER-W3 WR-SR SR-WR* ER-SR	31st May 2016 1st May 2016 to 31st May 2016 to 31st May 2016 1st May 2016 1st May 2016 1st May 2016 1st May 2016 2nd May 2016 2nd May 2016 1st May 2016 1st May 2016 1st May 2016 to 31st May 2016 to 31st May 2016 to 31st May 2016 to	00-24 00-24 00-24 00-06 18-24 06-18' 00-06 18-24 06-18' 00-24	2350 2650	0	2350 2350 2650	No Re-routing is being specified.  3250  No limit is 2585  2650  No limit is 1600  2585	0 s being Specified.  0 0 65 0 s being Specified.	-300	pole of HVDC Gazuwaka B/B and high valve hall temperature at					
ER-W3 WR-SR SR-WR* ER-SR	31st May 2016 1st May 2016 to 31st May 2016 to 31st May 2016 1st May 2016 1st May 2016 1st May 2016 1st May 2016 2nd May 2016 2nd May 2016 1st May 2016	00-24 00-24 00-24 00-06 18-24 06-18' 00-06 18-24 00-17 23-24 17-23 00-17	2350 2650 1430 1240	0 0 45	2350 2350 2650 1385 1195	No Re-routing is being specified.  3250  No limit is 2585  2650  2585  2650  No limit is 210	0 s being Specified.  0 0 65 0 s being Specified.	-300	pole of HVDC Gazuwaka B/B and high valve hall temperature at					
ER-W3 WR-SR SR-WR *  ER-SR  ER-SR  NER-ER	31st May 2016 1st May 2016 to 31st May 2016 to 31st May 2016 1st May 2016 1st May 2016 1st May 2016 1st May 2016 2nd May 2016 2nd May 2016 1st May 2016	00-24 00-24 00-24 00-06 18-24 06-18' 00-06 18-24 06-18' 00-17 23-24 17-23 00-17 23-24	2350 2650 1430 1240 1200 1300	0 0 45 45	3250 2350 2650 1385 1195 1155 1255	No Re-routing is being specified.  3250  No limit is 2585  2650  2585  2650  No limit is 210  0	0 s being Specified.  0 0 65 0 s being Specified.  1175 985 1155 1255	-300	pole of HVDC Gazuwaka B/B and high valve hall temperature at					
ER-W3 WR-SR SR-WR* ER-SR	31st May 2016 1st May 2016 to 31st May 2016 to 31st May 2016 1st May 2016 1st May 2016 1st May 2016 1st May 2016 2nd May 2016 2nd May 2016 1st May 2016 1st May 2016 1st May 2016 to 31st May 2016 to 31st May 2016 to 31st May 2016 to	00-24 00-24 00-24 00-06 18-24 06-18' 00-06 18-24 06-18' 00-17 23-24 17-23 00-17 23-24	2350 2650 1430 1240 1200 1300 No limit is	0 0 45 45 45 s being specifi	3250  2350  2650  1385  1195  1155  1255  ed (in case of s	No Re-routing is being specified.  3250  No limit is 2585  2650  2585  2650  No limit is 210  0	0 s being Specified.  0 65 0 s being Specified.	-300	pole of HVDC Gazuwaka B/B and high valve hall temperature at					

Note: TTC/ATC of S1-S2 corridor, Import of Punjab and Import of DD & DNH is uploaded on NLDC website under Intra-Regional Section in Monthly ATC.

### National Load Despatch Centre Total Transfer Capability for May 2016

Issue Date: 30/04/2016 Issue Time: 1400 hrs Revision No. 4

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
----------	------	-------------------------	------------------------------------------	-----------------------	----------------------------------------------	----------------------------------------------------------------------	----------------------------------------------------------------	-------------------------------------------------	----------

<sup>\*</sup> Fifty Percent (50 % ) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

- \$ As per Simulations, predominant direction of flow is on West to North Corridor. Hence, in case injection point is in Western Region (W1,W2,W3), STOA/PX transactions from West to North on West-East-North corridor shall not be allowed as such transaction increases congestion in the West to North Corridor.
- 1) S1 comprises of Telangana, AP and Karnataka: S2 comprises of Tamil Nadu, Kerala and Puducherry
- 2) W3 comprises of the following regional entities:
- a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak
- f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCL, n)Vandana Vidyut
- # The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/Fuel shortage/New units being commissionned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown:

- 1) The TTC value will be revised to normal values after restoration of shutdown.
- 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

#### **Limiting Constraints**

Corridor	Constraint
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak
WR-NR	1. (n-1) Contingnecy of 765kV Gwalior-Agra one ckt leads to 2750 MW loading on second circuit. 2.High Loading of 400kV Singrauli-Anpara S/C.
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli
ER-NR	n-1 contingency of one cicuit of 400 kV Biharshariff- Lakhisarai leads to high loading on the other cicuit
WR-SR & ER-SR	(n-1) contingency of one circuit of 765 kV Raichur - Sholapur will lead to 2500 MW loading on the other circuit
EK-SK	Low Voltage at Gazuwaka (East) Bus.
ER-NER	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA ICT at Misa. n-1 cntingency of 400/132 kV, 2 x 200 MVA ICTs at Silchar
NER-ER	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA ICT at Misa
W3 zone Injection	

## **Simultaneous Import Capability**

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER									
	1st May 2016	00-24	8400	800	7600	8601	0	-1467	Revised considering the present high generation in Rajasthan state and trend
		00-07	8400	800	7600	8601	0	-1467	of import of NR from WR and ER
	2nd May 2016 to 3rd May 2016	07-24'	7900	800	7100	8601	0	-1967	Revised due to shutdown of HVDC Rihand Dadri Bipole, considering present high generation trend in Rajasthan and trend of import of NR from WR and ER
	4th May 2016	00-24	8400	800	7600	8601	0	-1467	Revised considering the present high generation in Rajasthan state and trend
NR*	5th May 2016	00-07	8400	800	7600	8601	0	-1467	of import of NR from WR and ER
		00-24	7350	800	6550	8601	0	-2517	Revised considering Shutdown of 765 kV Phagi - Bhiwani S/C, present high generation in
	6th May 2016 to 10th May 2016	00-24	7350	800	6550	8601	0	-2517	Rajasthan and trend of import of NR from WR and ER
	11th May 2016 to 31st May 2016	00-24	8400	800	7600	8601	0	-1467	Revised considering the present high generation trend in Rajasthan state and trend of import of NR from WR and ER
NER	1st May 2016 to	00-17 23-24	1430	45	1385	210	1175		
NEK	31st May 2016	17-23	1240	40	1195	210	985		
WR									
		00-06	6350		5600	5835	0		Revised considering
	1st May 2016	06-18'	6350	750	5600	5900	0	-300	shutwon of one pole of HVDC Gazuwaka B/B and high valve hall temperature
SR		18-24	6350		5600	5835	0		at HVDC Gauwaka B/B
	2nd May 2016 to	00-06	6650		5900	5835	65		
	31st May 2016	06-18'	6650	750	5900	5900	0		
		18-24	6650		5900	5835	65		

<sup>\*</sup> Fifty Percent (50%) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

\* For approving STOA Bilateral transactions, margin available in Simultaneous Import of NR would be apportioned on WR-NR Corridor & ER-NR Corridor in the following ratio:

Margin in Simultaneous import of NR = A

WR-NR ATC =B

ER-NRATC = C

Margin for WR-NR applicants = A \* B/(B+C)Margin for ER-NR Applicants = A \* C/(B+C)

### **Simultaneous Export Capability**

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NID÷	1st May 2016 to	00-06	4500	700	3800	442	3358		
NR*	31st May 2016	06-18' 18-24	4500		3800 3800	507 442	3293 3358		
		00-17	4300		3600	772	3336		
NER	1st May 2016 to 31st May 2016	23-24	1200	45	1155	0	1155		
		17-23	1300		1255		1255		
WR									
WK									
SR *	1st May 2016 to 31st May 2016	00-24		No limit is being Specified.					

<sup>\*</sup> Fifty Percent (50 % ) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

#### **Limiting Constraints**

	0						
		(n-1) contingency of one circuit of 400 kV Biharshariff- Lakhisarai leads to high loading on the other circuit					
	Import	1. (n-1) Contingnecy of 765kV Gwalior-Agra one ckt leads to 2750 MW loading on second circuit.					
NR		2.High Loading of 400kV Singrauli-Anpara S/C.					
	Evmont	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.					
	Export	(n-1) contingency of 400 kV Saranath-Pusauli					
		(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA					
NER	Import	ICT at Misa. n-1 entingency of 400/132 kV, 2 x 200 MVA ICTs at Silchar					
NEK	·	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA					
	Export	ICT at Misa.					
SR	Immont	(n-1) contingency of one circuit of 765 kV Raichur - Sholapur will lead to 2500 MW loading on the other circuit					
SK	Import	Low Voltage at Gazuwaka (East) Bus.					

# National Load Despatch Centre Total Transfer Capability for May 2016

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor Affected	
1	1/3/2016	Whole Month	STOA Margin revised considering the completion of ISGS Allocation towards SR.	NR-WR/ Export of NR	
2	31/3/2016	Whole Month	STOA Margin revised considering the grant of of MTOA.	WR-NR	
3	12/4/2016	Whole Month	STOA Margin revised due to allocation of power from NR ISGS to SR Constituents	NR-WR/ Export of NR	
	30/4/2016	Revised considering the present high generation in Rajasthan state and trend of import of NR from WR and ER		WR-NR/ Import of NR	
		1/5/2016	Revised considering shutwon of one pole of HVDC Gazuwaka B/B and high valve hall temperature at HVDC Gauwaka B/B	WR-SR / Import of SR	
4		30/4/2016	2/5/2016 to 3/5/2016	Revised due to shutdown of HVDC Rihand Dadri Bipole, considering present high generation trend in Rajasthan and trend of import of NR from WR and ER	
			4/5/2016	Revised considering the present high generation in Rajasthan state and trend of import of NR from WR and ER	WR-NR/
		5/5/2016 to 10/5/2016	Revised considering Shutdown of 765 kV Phagi - Bhiwani S/C, present high generation in Rajasthan and trend of import of NR from WR and ER	Import of NR	
			11/5/2016 to 31/5/2016	Revised considering the present high generation trend in Rajasthan state and trend of import of NR from WR and ER	

ASSU	MPTIONS IN BASECASE				
				Month : May '16	
S.No.	Name of State/Area		Load	Gene	eration
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
- 1	NORTHERN REGION				
1	Punjab	6191	5617	2395	2423
2	Haryana	6958	6342	2256	2256
3	Rajasthan	8173	7964	4722	4722
4	Delhi	4850	4752	1117	1117
5	Uttar Pradesh	13236	12912	6416	6087
6	Uttarakhand	1591	1325	724	730
7	Himachal Pradesh	1149	921	864	771
8	Jammu & Kashmir	2220	1595	753	735
9	Chandigarh	258	187	0	0
10	ISGS/IPPs	0	0	19254	16602
	Total NR	44627	41614	38500	35442
П	EASTERN REGION				
1	Bihar	3004	2153	210	100
2	Jharkhand	1140	881	470	300
3	Damodar Valley Corporation	2652	2202	3463	2943
4	Orissa	3838	2931	2849	1818
5	West Bengal	7169	5199	4850	3600
6	Sikkim	98	64	0	0
7	Bhutan	215	215	757	427
8	ISGS/IPPs	629	626	10995	9916
	Total ER	18745	14270	23594	19104
Ш	WESTERN REGION				
	Maharashtra	19564	14106	14568	10078
	Gujarat	13686	12793	10999	9783
3	Madhya Pradesh	8365	5488	4654	3091
	Chattisgarh	3699	2994	2392	1932
	Daman and Diu	298	250	0	0
6	Dadra and Nagar Haveli	776	656	0	0
	Goa-WR	478	281	0	0
8	ISGS/IPPs	1074	1073	27268	23418
	Total WR	47941	37639	59880	48301

IV	SOUTHERN REGION				
1	Andhra Pradesh	6930	5771	6047	5570
2	Telangana	7271	6232	2651	2111
3	Karnataka	9132	7475	6868	5269
4	Tamil Nadu	15237	13449	8546	6146
5	Kerala	3924	2824	1608	655
6	Pondy	391	309	0	0
7	Goa-SR	89	89	0	0
8	ISGS/IPPs	0	0	13286	11952
	Total SR	42621	35840	39006	31703
V	NORTH-EASTERN REGION				
1	Arunachal Pradesh	115	44	0	0
2	Assam	1008	699	308	170
3	Manipur	112	59	0	0
4	Meghalaya	268	182	185	80
5	Mizoram	72	44	4	4
6	Nagaland	90	69	16	8
7	Tripura	246	157	87	87
8	ISGS/IPPs	0	0	1396	956
	Total NER	1902	1249	1996	1305
	Total All India	155837	130612	162976	135856